

PROPOSED AMENDED RULES 1147 AND 1100 WORKING GROUP MEETING #6

MAY 14, 2020
SOUTH COAST AQMD
DIAMOND BAR, CA

Zoom Meeting: <https://scaqmd.zoom.us/j/91164890213>
Meeting ID: 911 6489 0213

Conference Call: 1 (669) 900-6833 US (San Jose)
1 (346) 248-7799 US (Houston)

1

AGENDA

- Clarification and Correction to Previous Working Group
- BARCT Analysis
 - Additional Analysis of New Equipment Categories
 - Cost-Effectiveness Methodology
- Cost-Effectiveness Analysis
 - Oven, Dryer, Heater, Furnace, Kiln, and Heated Process Tank
- Next Steps



2


PREVIOUS WORKING GROUP RECAP

Working Group #5

- Compared requirements of Rule 1147 with existing regulatory requirements of other agencies located across the United States
- Presented assessments of available pollution control technologies
- Presented initial BARCT limits for applicable equipment categories going into cost-effectiveness analysis
- Identified three potential new equipment categories (autoclaves, absorption chillers, and microturbines)

3

REVISION AND FURTHER ASSESSMENT DIESEL FIRED TAR POT



4

ASSESSMENT REVISION

DIESEL FIRED TAR POT

Initial BARCT Emission Limit

Previous Working Group:

- Identified diesel fired tar pots in RECLAIM as subject to Rule 1146.2 due to size

Correction:

- Rule 1146.2 is only applicable to natural gas fired equipment
- Diesel fired tar pot will be evaluated under PAR 1147

Initial BARCT assessment will be conducted under PAR 1147 from available equipment information and current Rule 1147 limit for liquid fuels

5

FURTHER ASSESSMENT

DIESEL FIRED TAR POT

Initial BARCT Emission Limit

Operating Temp	Existing Units ⁺		Rule 1147 Limit [*]	Other Regulatory [#]	BARCT Technology Review [^]	Initial BARCT Limit [^]
	Source Test Results	Units Meeting Initial BARCT Limit				
<1,200° F	N/A	N/A	40 ppm	114 ppm [^] (~20 lb/mgal)	40 ppm	40 ppm
≥1,200° F	N/A	N/A	40 ppm	114 ppm [^] (~20 lb/mgal)	40 ppm	40 ppm

Unable to identify existing source test results

Applicable rule limit from existing Rule 1147



South Coast AQMD AER Reporting Factor²



Based on existing Rule 1147 limit for liquid fuels

Cost-Effectiveness Analysis is needed

^{*} Emissions data collected from source test results
[^] NOx concentrations are corrected to 3% O₂ dry
[#] Oxygen corrections for NOx concentrations vary depending on regulatory agency
² South Coast AQMD Annual Emissions Reporting (AER) emission factor derived from either US EPA AP-42 or Ventura APCD:
http://www3.aqmd.gov/webappl/help/newaer/index.html?external_combustion.htm

6





OVERVIEW OF INITIAL BARCT LIMITS PRESENTED AT PREVIOUS WORKING GROUP MEETING

Initial BARCT Emission Limit

Equipment Category	Operating Temperature	Equipment Size	Current Rule Limit [^]	Initial BARCT Limit [^]	Cost-Effectiveness Analysis
Oven, Dryer, Heater, Furnace, Kiln, and Heated Process Tank	<1,200°F	≥40 MMBtu/hr	30 ppm	5 ppm	Pending
		<40 MMBtu/hr	30 ppm	20 ppm	Pending
	≥1,200°F	≥40 MMBtu/hr	60 ppm	5 ppm	Pending
		<40 MMBtu/hr	60 ppm	30 ppm	Pending
Afterburner, Thermal Oxidizer, RTO, and Oxidizer	All	All	60 ppm	20 ppm	Pending
Evaporator, Fryer, Heated Process Tank, and Parts Washer	All	All	60 ppm	30 ppm	Pending
Burn-off Furnace, Burnout Oven, Incinerator, Crematory with or without Integrated Afterburner	All	All	60 ppm	30 ppm	Pending
Tenter Frame, Fabric or Carpet Dryer	All	All	30 ppm	20 ppm	Pending
Other Unit and Process Temperature	<1,200°F	All	30 ppm	No Change	Pending ¹¹
	≥1,200°F	All	60 ppm		

[^] NOx concentrations are corrected to 3% O₂ dry

BARCT ANALYSIS PROGRESS OF BARCT ANALYSIS


Initial BARCT Emission Limit

- Completed the technology assessment and presented initial BARCT limits for six equipment categories
- Based on stakeholder input, three additional equipment categories were identified:
 - ✓ Micro-turbines (Natural Gas and Diesel)
 - ✓ Absorption Chillers
 - ✓ Autoclaves
- Next Steps:
 - Evaluate newly identified equipment categories to determine initial BARCT limits



12

[^] NOx concentrations are corrected to 3% O₂ dry



FURTHER EVALUATION OF NEWLY IDENTIFIED CATEGORIES

Initial BARCT Emission Limit

New equipment categories were introduced during previous working group

- Categories were determined with stakeholder and internal staff input
- Further evaluation of each category is necessary to determine initial BARCT limit

Equipment Category	Operating Temperature	Equipment Size	Current Rule Limit [^]	Initial BARCT Limit [^]
Absorption Chillers	All	All	30 ppm	Pending Assessment
Micro-Turbines (Natural Gas)	All	All	N/A	Pending Assessment
Micro-Turbines (Diesel)	All	All	40 ppm	Pending Assessment
Auto-Claves	All	All	30 ppm	Pending Assessment

[^] NOx concentrations are corrected to 3% O₂ dry
^{*} NOx concentrations are corrected to 15% O₂ dry

FURTHER EVALUATION
ABSORPTION CHILLERS

Initial BARCT Emission Limit

- ❑ Absorption chillers are currently considered as “other unit or process temperature”
 - Three permitted natural gas fired units in RECLAIM
 - One permitted natural gas fired unit in non-RECLAIM
- ❑ All identified units have permit limits of 20 ppm[^]
 - Permit limits are in line with Best Available Control Technology (BACT)
 - Three available source test results from RECLAIM units show emissions between 4 to 10 ppm[^]
 - Unable to identify source test for non-RECLAIM unit

[^] NOx concentrations are corrected to 3% O₂ dry

15

INITIAL BARCT NOX LIMIT
ABSORPTION CHILLERS

Initial BARCT Emission Limit

Operating Temp	Existing Units [^]		Rule 1147 Limit [^]	Other Regulatory [#]	BARCT Technology Review [^]	Initial BARCT Limit [^]
	Source Test Results	Units Meeting Initial BARCT Limit				
<1,200° F	4 to 10 ppm	3 of 3 RECLAIM	30 ppm	30 ppm [^]	20 ppm	20 ppm
		No Source Test for Non-RECLAIM				

Applicable rule limit from existing Rule 1147

Applicable rule limit from SMAQMD¹

Based on existing equipment permit limits and burner technology

No further action required for identified units

^{*} Emissions data collected from source test results

[^] NOx concentrations are corrected to 3% O₂ dry

[#] Oxygen corrections for NOx concentrations vary depending on regulatory agency

¹ Sacramento Metropolitan AQMD Rule 419: <http://www.airquality.org/ProgramCoordination/Documents/rule419.pdf>

16

FURTHER EVALUATION

MICROTURBINES

Initial BARCT Emission Limit

- ❑ Permitted micro-turbines are not currently subject to any command and control rule
 - Below Rule 1134 applicability of ≥ 0.3 MW
 - Not applicable to Rule 219(b)(1) exemption
- ❑ Identified 29 permitted micro-turbines (17 RECLAIM and 12 non-RECLAIM) potentially impacted by PAR 1147
 - ✓ 26 natural gas fired (9 ppm permit limit*)
 - Source tested between 3 to 6 ppm
 - ✓ 3 diesel fired (77 ppm permit limit*) – **All in RECLAIM**
 - Source tested between 65 to 68 ppm

* NOx concentrations are corrected to 15% O₂ dry

17

INITIAL BARCT NOX LIMIT

MICRO-TURBINES (NATURAL GAS)

Initial BARCT Emission Limit

Fuel Type	Existing Units*		Rule 1147 Limit [^]	Other Regulatory [^]	BARCT Technology Review [^]	Initial BARCT Limit [^]
	Source Test Results	Units Meeting Initial BARCT Limit				
Natural Gas	3 to 6 ppm	6 of 6 RECLAIM	N/A	43 ppm* (~54.4 lb/mmscf)	9 ppm	9 ppm
		11 of 11 Non-RECLAIM				

Unable to identify existing rule requirements from South Coast AQMD



South Coast AQMD AER Reporting Factor²


Based on turbine technologies from OEM guarantees

Cost-Effectiveness Analysis is needed

^{*} Emissions data collected from source test results
[^] NOx concentrations are corrected to 15% O₂ dry
[^] Oxygen corrections for NOx concentrations vary depending on regulatory agency
²South Coast AQMD Annual Emissions Reporting (AER) emission factor derived from either US EPA AP-42 or Ventura APCD:
http://www3.aqmd.gov/webappl/help/newaer/index.html?internal_combustion.htm

18







OVERVIEW OF INITIAL BARCT LIMITS NEWLY IDENTIFIED CATEGORIES

Initial BARCT Emission Limit

Equipment Category	Operating Temperature	Equipment Size	Current Rule Limit [^]	Initial BARCT Limit [^]	Cost-Effectiveness Analysis
Absorption Chillers	All	All	30 ppm	20 ppm	Pending
Micro-Turbines (Natural Gas)	All	All	N/A	9 ppm*	Pending
Micro-Turbines (Diesel)	All	All	40 ppm	40 to 77 ppm*	Pending
Auto-Claves	All	All	30 ppm	30 ppm	Pending

[^] NOx concentrations are corrected to 3% O₂ dry
^{*} NOx concentrations are corrected to 15% O₂ dry



22



EMISSION CONTROL TECHNOLOGIES

Cost-Effectiveness Analysis

- ❑ Cost-effectiveness will be conducted based on anticipated technologies available to achieve the initial BARCT limits
- ❑ Technology will be determined by equipment size and baseline emissions
- ❑ Pollution control technologies:
 - Low-NO_x Burners
 - Selective Catalytic Reduction



LOW-NO_x BURNER COST ASSUMPTIONS

Cost-Effectiveness Analysis

Burner Replacement (Low-NO_x)

- Burner and installation costs to be evaluated based off of equipment application
- Analysis assumes that burners are replaced at 15 years
- No additional operating & maintenance costs for replacing burners with low NO_x burners

* Rule 301. <http://www.aqmd.gov/docs/default-source/rule-book/reg-iii/rule-301-July-2019.pdf>

SELECTIVE CATALYTIC REDUCTION COST ASSUMPTIONS

Cost-Effectiveness Analysis

Selective Catalytic Reduction (SCR)

- Costs for SCR systems and installation are obtained through the US EPA SCR Cost Manual¹ and the 2018 Rule 1146 Staff Report²
- Analysis assumes 25 year useful life of the SCR system
- Costs associated with this technology includes operating & maintenance as well as consumables such as reagent & catalyst

27

¹EPA SCR Cost Manual- https://www3.epa.gov/ttn/ecas/docs/SCRCostManualchapter7thEdition_2016.pdf

²Board Package for 2018 Amendment of Rule 1146 dated December 7, 2018- <http://www.aqmd.gov/docs/default-source/Agendas/Governing-Board/2018/2018-dec7-028.pdf?sfvrsn=6>

OTHER COST ASSUMPTIONS


Cost-Effectiveness Analysis

Interest Rate and Permitting

- 4% nominal interest rate
- Rule 301* Schedule A specifies a one-time modification permit processing fee of between \$3,000 - \$8,000
- Assume no change in annual renewal costs

28

*Rule 301- <http://www.aqmd.gov/docs/default-source/rule-book/reg-iii/rule-301-July-2019.pdf>



COST-EFFECTIVENESS CALCULATIONS

Cost-Effectiveness Analysis

Discounted Cash Flow (DCF) Method

ULNB Cost Calculations

Cost-Effectiveness =

$$\frac{\text{Capital Costs} + (\text{Increased Annual Operating Costs} * \text{Equipment Life})}{\text{Emissions Reduced Over Equipment Life}}$$



SCR Cost Calculations

Cost-Effectiveness (SCR) =

$$\frac{\text{Capital Costs} * (\text{Capital Recovery Factor}) + \text{Annual Operating Costs}}{\text{Emissions Reduced Per Year}}$$

Capital Recovery Factor for annualizing equipment cost = $\frac{i * (1+i)^n}{(1+i)^n - 1}$

- i = nominal interest rate
- n = equipment useful life



COST-EFFECTIVENESS APPROACH

Cost-Effectiveness Analysis

Based on a “bottom up approach” using actual emissions data for each unit to calculate the cost-effectiveness for each unit

Calculated the average cost-effectiveness for each class and category of equipment, based on the data from each unit

Initial sensitivity assessments were conducted to remove outliers that were >> \$50,000 per ton of NOx reduced

Outliers to be addressed through either a different implementation approach or possible exemption

33

EXISTING RULE 1147 COMPLIANCE PATHWAY

Cost-Effectiveness Analysis



```

graph LR
    Rule1147[Rule 1147] --> BTU1[<325,000 BTU/HR]
    Rule1147 --> BTU2[≥325,000 BTU/HR]
    BTU1 --> NotSubject[Not Subject to Rule Limits]
    BTU2 --> P1[≥1 Pound/Day]
    BTU2 --> P2[<1 Pound/Day]
    P1 --> FixedDate[Fixed Date]
    P1 --> PhaseIn1[Phase-In]
    P2 --> PhaseIn2[Phase-In]
    FixedDate --> 15Years[When Unit is 15 Years Old]
    FixedDate --> Burner1[At Burner Replacement]
    PhaseIn1 --> 15Years
    PhaseIn1 --> Burner1
    PhaseIn2 --> 35Years[When Unit is 35 Years Old*]
    PhaseIn2 --> Burner2[At Burner Replacement]
    
```

- ❑ Compliance for existing Rule 1147 divides applicable equipment between <1 LB/Day and ≥1 LB/Day
- ❑ Rule 1147 was adopted on December 5, 2008 with first set of permitting requirements by December 1, 2011 (roughly 3 years after rule adoption)
 - PAR 1147 and 1100 will follow a similar approach

34

*In-use units may continue to operate beyond 35 years of age provided facility conduct bi-ennial emissions test no later than 180 days before the unit becomes 35 years of age;
 Rule 1147(c)(16)(B) - <http://www.aqmd.gov/docs/default-source/rule-book/reg-xi/rule-1147.pdf>





Cost-Effectiveness Analysis

COST-EFFECTIVENESS ANALYSIS

Oven, Dryer, Heater, Furnace, Kiln, and Heated Process Tank

37

SUMMARY OF INITIAL BARCT LIMIT OVEN, DRYER, HEATER, FURNACE, KILN, AND HEATED PROCESS TANK

Cost-Effectiveness Analysis

Operating Temp	Existing Units ⁺⁺		Rule 1147 Limit [*]	Other Regulatory [#]	Technology Assessment ⁺⁺		Initial BARCT NOx Limit ⁺⁺	
	Source Test Results	Units Meeting Initial BARCT Limit			≥40 MMBtu/hr	<40 MMBtu/hr	≥40 MMBtu/hr	<40 MMBtu/hr
<1,200° F	5 to 54 ppm	11 of 31 RECLAIM	30 ppm	30 to 175 ppm	5 ppm (via SCR [*])	30 ppm (via LNB ¹)	5 ppm (via SCR [*])	20 ppm (via LNB ¹)
		76 of 169 Non-RECLAIM						
≥1,200° F	10 to 80 ppm	1 of 8 RECLAIM	60 ppm	30 to 175 ppm	5 ppm (via SCR [*])	30 ppm (via LNB ¹)	5 ppm (via SCR [*])	30 ppm (via LNB ¹)
		3 of 4 Non-RECLAIM						

^{*} Emissions data collected from source test results
^{**} Staff assumption of 95% efficiency for SCR reductions from default emission factor of 130 lb/mmssc (~102 ppm)
⁺ NOx concentrations are corrected to 3% O₂ dry
[#] Oxygen corrections for NOx concentrations vary depending on regulatory agency
¹ Low NOx Burner (LNB) technology assessment is based off of vendor guarantees. Source test results analyzed demonstrate burners can achieve lower concentrations


Cost-Effectiveness Analysis is needed ³⁸

BASIS FOR BURNER COSTS

OVEN, DRYER, HEATER, FURNACE, KILN, AND HEATED PROCESS TANK

Cost-Effectiveness Analysis

- ❑ Burner costs were obtained from two burner manufacturers
 - Staff utilized a conservative approach and utilized higher cost figures for cost-effectiveness analysis
 - Costs for larger equipment were extrapolated from provided cost figures
- ❑ Staff utilized installation cost from Rule 1146 equipment as a conservative estimate to installation costs of Rule 1147 applicable equipment




39


COST-EFFECTIVENESS ANALYSIS

OVEN, DRYER, HEATER, FURNACE, KILN, AND HEATED PROCESS TANK


Cost-Effectiveness Analysis



Average Cost-Effectiveness		\$1.07B/Ton
	Initial BARCT Limit	Units
⊗	Source Test or Permit Limit ≤20 ppm	107
	Source Test or Permit Limit ≤30 ppm	322
	Low-Use (<1 LB NOx/Day)	75



Average Cost-Effectiveness		\$4.69M/Ton
	Initial BARCT Limit	Units
⊗	Source Test or Permit Limit ≤20 ppm	107
⊗	Source Test or Permit Limit ≤30 ppm	322
	Low-Use (<1 LB NOx/Day)	75



Average Cost-Effectiveness		\$12.635/Ton
	Initial BARCT Limit	Units
⊗	Source Test or Permit Limit ≤20 ppm	107
⊗	Source Test or Permit Limit ≤30 ppm	322
⊗	Low-Use (<1 LB NOx/Day)	75

* Excludes equipment rated ≥ 40 MMBtu/hr

40

PROPOSED NO_x BARCT LIMIT AND IMPLEMENTATION APPROACH FOR OVEN, DRYER, HEATER, FURNACE, KILN, AND HEATED PROCESS TANK

Cost-Effectiveness Analysis



Operating Temp	Existing Units <40 MMBtu/hr	# of Units*	No Further Action	Meet 20 PPM at Burner Replacement	Meet 20 PPM by Specified Date
<1,200° F	Source Tested or Permit Limit ≤20 ppm	107	✓		
	Source Tested or Permit Limit ≤30 ppm and >20 ppm	322		✓	
	Low-Use (<1 LB NO _x /Day)	75		✓	
	Remaining Units	204			✓

Average Cost-Effectiveness: \$12,635/Ton

*Excludes equipment rated ≥40 MMBtu/hr

COST-EFFECTIVENESS ANALYSIS
OVEN, DRYER, HEATER, FURNACE, KILN, AND HEATED PROCESS TANK

Cost-Effectiveness Analysis



Average Cost-Effectiveness \$14,054/Ton

	Initial BARCT Limit	Units
✘	Source Test or Permit Limit ≤30 ppm	4
	Source Test or Permit Limit ≤60 ppm	4

Average Cost-Effectiveness \$5,565/Ton

	Initial BARCT Limit	Units
✘	Source Test or Permit Limit ≤30 ppm	4
✘	Source Test or Permit Limit ≤60 ppm	4 ⁴²

* Excludes equipment rated ≥ 40 MMBtu/hr

PROPOSED NO_x BARCT LIMIT AND IMPLEMENTATION APPROACH FOR OVEN, DRYER, HEATER, FURNACE, KILN, AND HEATED PROCESS TANK

Cost-Effectiveness Analysis

Operating Temp	Existing Units <40 MMBtu/hr	# of Units*	No Further Action	Meet 30 PPM at Burner Replacement	Meet 30 PPM by Specified Date
≥1,200° F	Source Tested or Permit Limit ≤30 ppm	4	✓		
	Source Tested or Permit Limit ≤60 ppm and >30 ppm	4		✓	
	Remaining Units	9			✓

Average Cost-Effectiveness: \$5,565/Ton

43

*Excludes equipment rated ≥40 MMBtu/hr

COST-EFFECTIVENESS ANALYSIS
OVEN, DRYER, HEATER, FURNACE, KILN, AND HEATED PROCESS TANK

Cost-Effectiveness Analysis

Identified two units rated >40 MMBtu/hr, both in RECLAIM, none in Non-RECLAIM

Equipment	Size	Operating Temperature	Current Permit Limit	Annual NO _x Emission*		Proposed BARCT	Cost-Effectiveness (\$/Ton)
				Lbs/Yr	Tons/Yr		
Kiln (Major Source)	84 MMBtu/hr	≥1,200° F	9.47 ppm (CEMS Max)	14,980	7.49	5 ppm (via SCR)	Pending
Furnace[^] (Large Source)	50 MMBtu/hr	<1,200° F	130 lbs/mmscf	679	0.34	5 ppm (via SCR)	

*Annual NO_x emissions obtained from 2018 to 2019 RECLAIM Audit
[^]Unit does not see continuous operation

Additional cost assessment is required ⁴⁴

SUMMARY

OVEN, DRYER, HEATER, FURNACE, KILN, AND HEATED PROCESS TANK




Cost-Effectiveness Analysis

Equipment Category	Operating Temperature	Equipment Size	Rule 1147 Limit [^]	Initial BARCT Limit [^]	Proposed BARCT Limit [^]
Oven, Dryer, Heater, Furnace, Kiln, and Heated Process Tank	<1,200°F	≥40 MMBtu/hr	30 ppm	5 ppm	Pending
		<40 MMBtu/hr	30 ppm	20 ppm	20 ppm (Via LNB¹)
	≥1,200°F	≥40 MMBtu/hr	60 ppm	5 ppm	Pending
		<40 MMBtu/hr	60 ppm	30 ppm	30 ppm (Via LNB¹)

[^] NOx concentrations are corrected to 3% O₂ dry

¹ Low NOx Burner (LNB) technology assessment is based off of vendor guarantees. Source test results analyzed demonstrate burners can achieve lower concentrations

NEXT STEPS

-  Conduct cost-effectiveness analysis for remaining categories
-  Continue to hold stakeholder meetings
-  Next Working Group Meeting – Late June

CONTACTS

General RECLAIM Questions

- Gary Quinn, P.E.
Program Supervisor
909-396-3121
gquinn@aqmd.gov
- Kevin Orellana
Program Supervisor
909-396-3492
korellana@aqmd.gov

Proposed Amended Rules 1147, 1100 and Proposed Rule 1147.1

- Shawn Wang
Air Quality Specialist
909-396-3319
swang@aqmd.gov
- Gary Quinn, P.E.
Program Supervisor
909-396-3121
gquinn@aqmd.gov

Proposed Amended Rule 1147, 1100 and Proposed Rule 1147.2

- James McCreary
Assistant Air Quality Specialist
909-396-2451
jmccreary@aqmd.gov
- Uyen-Uyen Vo
Program Supervisor
909-396-2238
uvo@aqmd.gov

Proposed Amended Rule 1147, 1100 and Proposed Rule 1147.3

- Yanrong Zhu
Air Quality Specialist
909-396-3289
yzhu1@aqmd.gov
- Gary Quinn, P.E.
Program Supervisor
909-396-3121
gquinn@aqmd.gov

47