



September 4, 2019

Mr. Michael Garibay  
Source Test Manager  
South Coast Air Quality Management District  
21865 Copley Drive  
Diamond Bar, CA 91765

Subject: AQMD Metal Melting Test Program "Facility A"

Dear Mr. Garibay:

Please find enclosed an electronic copy of the source test report on the emissions of Particulate Matter (PM) and selected metals from the metals (chromium alloy) melting facility located in [REDACTED] California. Additionally, two hard copies of the report have been mailed to your attention. Testing was conducted on May 21 through 23, 2019.

If you have any questions or comments regarding the enclosed package, please contact us at 714-889-4000.

Sincerely,

A handwritten signature in black ink, appearing to read "Charles M. Figueroa".

Charles M. Figueroa  
Senior Project Manager  
Almega Environmental



## SOURCE TEST REPORT

### Emissions Testing of Metal Melting "Facility A" for Selected Metals and Particulate Matter

**Facility ID:** [REDACTED]

**Prepared for:**  
South Coast Air Quality Management District  
21865 Copley Drive  
Diamond Bar, CA 91765

**Equipment Location:**  
Metal Melting Facility A  
[REDACTED] CA [REDACTED]


Test Date(s): May 21-23, 2019

Report Date: September 4, 2019

Project No.: 10562

Prepared by:

**Almega Environmental & Technical Services**  
10602 Walker Street  
Cypress, CA 90630

Prepared by & Title:   
Tulasi Gyawali, QA Engineer


Reviewed by & Title:   
Charles Figueroa, Sr. Project Manager

TABLE OF CONTENTS

1.0	Executive Summary .....	1
2.0	Introduction .....	4
2.1	Document Outline .....	5
3.0	Equipment and Process Description .....	5
3.1	Process Description.....	6
3.2	Operating Conditions During Test.....	6
3.3	Sampling Locations.....	7
4.0	Sampling and Analytical Procedures .....	11
4.1	SCAQMD Methods 1.1-4.1 - Stack Gas Parameters and Sampling Locations .....	11
4.2	SCAQMD Method 5.1 - Particulate Matter Emissions .....	14
4.3	SCAQMD Method 10.1 - Integrated Gas Sampling (O <sub>2</sub> /CO <sub>2</sub> ) .....	16
4.4	CARB Method 425 - Determination of Chromium & Hexavalent Chromium Emissions .....	16
4.5	CARB Method 436 - Determination of Multiple Metals Emissions .....	18
4.6	Collection/Capture Efficiency.....	19
5.0	Quality Assurance / Quality Control.....	20
5.1	Quality Assurance Program - Overview .....	20
5.2	Project Specific QA/QC .....	20
6.0	Test Results and Discussion.....	23
6.1	Discussion.....	23
6.2	Others .....	24
6.3	Test Chronology .....	25

FIGURES

Figure 3-1:	Process Schematic.....	5
Figure 3-2:	Stack Schematic .....	10
Figure 4-1:	SCAQMD Method 5.1 Sampling Apparatus .....	15
Figure 4-2:	CARB Method 425 Sampling Apparatus.....	17
Figure 4-3:	CARB Method 436 Sampling Apparatus.....	19

TABLES

Table 1-1.	Summary of Test Results (Tables 1-1 & 1-2).....	2
Table 6-1 .	Detail Test Results (Table 6-1 through 6-9).....	26

## TABLE OF CONTENTS - Continued

### APPENDICES

Appendix A - General Calculations and Formulae

Appendix B - Approvals and Certifications

B1 - SCAQMD and CARB Testing Approvals

B2 - Certification of No Conflict of Interest

Appendix C - CARB Method 436 – Multiple Metals Emissions

C1 - Multiple Metals – Results and Calculations

C2 - Multiple Metals – Field Data

C3 - Multiple Metals – Laboratory Data

C4 - SCAQMD Method 10.1– O<sub>2</sub>/CO<sub>2</sub> Laboratory Data

C5 - SCAQMD Methods 1.1-4.1 – Inlet 2 Flows

Appendix D - CARB Method 425 – Hexavalent Chromium Emissions

D1 - Hexavalent Chromium – Results and Calculations

D2 - Hexavalent Chromium – Field Data

D3 - Hexavalent Chromium – Laboratory Data

D4 - SCAQMD Method 10.1– O<sub>2</sub>/CO<sub>2</sub> Laboratory Data

Appendix E - SCAQMD Method 5.1 – Particulate Matter Emissions

E1 - Particulate Matter Emissions – Results and Calculations

E2 - Particulate Matter Emissions – Field Data

E3 - Particulate Matter Emissions – Laboratory Data

E4 - SCAQMD Method 10.1– O<sub>2</sub>/CO<sub>2</sub> Laboratory Data

Appendix F - Collection/Capture Efficiency Test

Appendix G - Test Equipment Calibration Data

Appendix H - Facility Process Data

Appendix I - SCAQMD Source Test Plan

Appendix J - Standard Checklist for Source Test Reports

## 1.0 EXECUTIVE SUMMARY

Key project information is provided in the summary below. Test results are summarized in Table 1-1.

Customer:	South Coast Air Quality Management District (SCAQMD) 21865 East Copley Drive Diamond Bar, CA 91765-4182 Contact: Mr. Michael Garibay, (909) 396-2249
Facility & Location:	Metal Melting Facility A [REDACTED] CA
Facility ID:	[REDACTED]
Equipment:	Inlets (Furnace and Upstream to Baghouse) / HEPA Baghouse Outlet
Test Objective:	To determine the Particulate Matter (PM), Arsenic, Cadmium, Nickel, Chromium, and Hexavalent Chromium (Cr <sup>6+</sup> ) emissions from the chromium alloy melting operations
Test Requested by:	South Coast Air Quality Management District (SCAQMD)
Test Date(s):	May 21-23, 2019
Test Personal	Neal Conroy, Morgan Nguyen, Dorian Johnson, Cody Harwood, James Odulio, and Tim Ta of Almega Environmental & Technical Services
Testing Firm:	Almega Environmental & Technical Services 10602 Walker Street Cypress, CA 90630 Contact: Mr. Charles Figueroa, tel (714) 889-4000
Regulatory Agency:	South Coast Air Quality Management District (SCAQMD) 21865 East Copley Drive Diamond Bar, CA 91765-4182 Contact: Mr. Brian Speaks, (909) 396-3212
Measurements: Volumetric flow rates Selected Metals (As, Cd, Cr, & Ni) Chromium (Hex/Total) Particulate Matter (PM)	SCAQMD Methods 1.1 - 4.1 CARB Method 436 CARB Method 425 SCAQMD Method 5.1

**TABLE 1-1. SUMMARY OF TEST RESULTS**

**Facility:** Metal Melting Facility A  
**City, State:** ██████████ CA  
**Test Location:** Baghouse Outlet & Inlets  
**Test Date(s):** May 21-23, 2019

Test Data	Units	Baghouse Outlet	Inlet 1 Furnace (Inside)	Inlet 1 (Upstream to Baghouse)
<b><u>CARB Method 436</u></b>				
<b><u>Sampling Data</u></b>				
Stack Temperature	°F	3-Run Avg. 05/21-22/19 86	3-Run Avg. 05/21-22/19 130	3-Run Avg. 05/21-22/19 87
Sample Volume	dscf	94	87	89
Stack Flow Rate	acfm	-	3,187	40,074
Stack Flow Rate	dscfm	47,648*	2,703	36,750
<b><u>Concentration (CARB 436)</u></b>				
Arsenic	ug/dscm	< 0.377	0.630	< 0.400
Cadmium	ug/dscm	< 0.377	0.415	< 0.415
Chromium	ug/dscm	5.42	118	12.3
Nickel	ug/dscm	2.12	24.5	9.56
<b><u>Mass Emissions (CARB 436)</u></b>				
Arsenic	lb/hr	< 6.72E-05	6.38E-06	< 5.50E-05
Cadmium	lb/hr	< 6.72E-05	4.45E-06	< 5.69E-05
Chromium	lb/hr	9.51E-04	1.19E-03	1.70E-03
Nickel	lb/hr	3.78E-04	2.48E-04	1.32E-03
<b><u>CARB Method 425</u></b>				
<b><u>Sampling Data</u></b>				
Stack Temperature	°F	3-Run Avg. 05/22-23/19 87	3-Run Avg. 05/22-23/19 140	3-Run Avg. 05/22-23/19 86
Sample Volume	dscf	91	103	104
Stack Flow Rate	acfm	-	3,226	41,147
Stack Flow Rate	dscfm	48,533*	2,683	37,621
<b><u>Concentration (CARB 425)</u></b>				
Chromium VI	ug/dscm	< 0.021	9.76	0.89
Total Chromium	ug/dscm	< 0.776	77.1	4.58
<b><u>Mass Emissions (CARB 425)</u></b>				
Chromium VI	lb/hr	< 3.76E-06	9.81E-05	1.25E-04
Total Chromium	lb/hr	< 1.41E-04	7.80E-04	6.45E-04
<b><u>SCAQMD Method 5.1</u></b>				
<b><u>Sampling Data</u></b>				
Stack Temperature	°F	Single Run 05/23/19 87	Single Run 05/23/19 128	Single Run 05/23/19 84
Sample Volume	dscf	89	102	101
Stack Flow Rate	acfm	-	3,142	40,129
Stack Flow Rate	dscfm	47,272*	2,629	36,230
Particulate Catch	mg	3.32	60.4	16.3
Particulate Concentration	gr/dscf	0.000574	0.00916	0.00250
Particulate Emission Rates	lb/hr	0.233	0.206	0.775
	lb/day	5.59	4.95	18.60

Flags

ND or "<" - Not detected, reporting limit reported.

\*The total flows from inlet 1 (upstream to Baghouse) and inlet 3 (only flows) was utilize the outlet mass emissions calculations.

**TABLE 1-2. SUMMARY OF TEST RESULTS  
(INLET 1 INSIDE)**

Facility: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Test Data	Units	Source Test Results			Average
		Run 1	Run 2	Run 3	
Run Number	--				
<b>CARB Method 436</b>					
<u>Sampling Data</u>		<u>05/21/19</u>	<u>05/21/19</u>	<u>05/22/19</u>	<u>3-Run Avg.</u>
Stack Temperature	°F	123	134	132	<b>130</b>
Sample Volume	dscf	75	81	104	<b>87</b>
Stack Flow Rate	acfm	3,027	3,311	3,224	<b>3,187</b>
Stack Flow Rate	dscfm	2,599	2,795	2,716	<b>2,703</b>
Material Charged (SS316)	lbs/hr	1125	1125	900	<b>1050</b>
<b>CARB Method 436</b>					
<u>MASS EMISSION RATE</u>		<u>Total</u>	<u>Total</u>	<u>Total</u>	
Arsenic	lb/hr	ND 4.60E-06	ND 4.55E-06	1.00E-05	<b>6.38E-06</b>
Cadmium	lb/hr	ND 4.60E-06	ND 4.55E-06	4.21E-06	<b>4.45E-06</b>
Chromium	lb/hr	1.01E-03	1.80E-04	2.37E-03	<b>1.19E-03</b>
Nickel	lb/hr	2.66E-04	2.73E-05	4.44E-04	<b>2.46E-04</b>
<b>Emissions Factor (lb/lbs)</b>					
Arsenic	lb-As/lb-316ss	< 4.09E-09	< 4.04E-09	1.11E-08	<b>1.55E-05</b>
Cadmium	lb-Cd/lb-316ss	< 4.09E-09	< 4.04E-09	4.67E-09	<b>1.29E-06</b>
Chromium	lb-Cr/lb-316ss	8.94E-07	1.60E-07	2.64E-06	<b>9.84E-07</b>
Nickel	lb-Ni/lb-316ss	2.36E-07	2.43E-08	4.93E-07	<b>5.65E-07</b>
<b>CARB Method 425</b>					
<u>Sampling Data</u>		<u>05/22/19</u>	<u>05/22/19</u>	<u>05/23/19</u>	<u>3-Run Avg.</u>
Stack Temperature	°F	152	138	128	<b>140</b>
Sample Volume	dscf	103	100	106	<b>103</b>
Stack Flow Rate	acfm	3,272	3,179	3,227	<b>3,226</b>
Stack Flow Rate	dscfm	2,661	2,644	2,743	<b>2,683</b>
Material Charged (SS316)	lbs/hr	1125	1125	900	<b>1050</b>
<b>Mass Emissions (CARB 425)</b>					
Chromium VI	lb/hr	2.01E-04	1.32E-05	8.05E-05	<b>9.81E-05</b>
Total Chromium	lb/hr	9.63E-04	1.91E-04	1.19E-03	<b>7.80E-04</b>
<b>Emissions Factor (lb/lbs)</b>					
Chromium VI	lb-Cr+6/lb-316ss	1.78E-07	1.18E-08	8.95E-08	<b>9.32E-08</b>
Total Chromium	lb-Cr/lb-316ss	8.56E-07	1.70E-07	1.32E-06	<b>7.81E-07</b>
<b>SCAQMD Method 5.1</b>					
<u>Sampling Data</u>		<u>05/23/19</u>			<u>Single Run</u>
Stack Temperature	°F	128			<b>128</b>
Sample Volume	dscf	102			<b>102</b>
Stack Flow Rate	acfm	3,142			<b>3,142</b>
Stack Flow Rate	dscfm	2,629			<b>2,629</b>
Material Charged (SS316)	lbs/hr	1125			<b>1125</b>
<b>PM Emissions</b>					
Emission Rate	lb/hr	0.206			<b>2.06E-01</b>
<b>Emissions Factor (lb/lbs)</b>					
PM Emissions	lb-PM/lb-316ss	1.84E-04			<b>1.84E-04</b>

## 2.0 INTRODUCTION

Almega Environmental & Technical Services (Almega) was contracted by South Coast Air Quality Management District (SCAQMD) to conduct stationary source emissions testing of the baghouse serving the chromium alloy melting operations at facility designated as “Facility A” located in ██████████ California. The purpose of the test program is to determine the Particulate Matter (PM), Arsenic, Cadmium, Nickel, Chromium, and Hexavalent Chromium (Cr<sup>6+</sup>) emissions from chromium alloy melting operations.

Due to the rising level of hexavalent chromium in the ambient air in the city of Paramount and its vicinity, SCAQMD staff initiated the rule development process to amend Rule 1407 to address toxic air contaminant emissions from ferrous metal melting operations and update existing requirements for non-ferrous metal melting operations currently regulated under the rule. Through working group meetings with industry stakeholders, it was requested that the rule be separated in to two rules for ferrous and non-ferrous metal melting. After additional input and working group meetings, the SCAQMD staff decided to bifurcate the rule and reclassify characterization into (1) non-chromium alloy (Rule 1407) and (2) chromium alloy (Rule 1407.1) metal melting. In regards to the chromium alloy melting, additional data from melting operations of metals with a chromium content greater than 0.5% is needed to quantify the conversion rate of chromium to hexavalent chromium and quantify toxic air contaminant emissions from these facilities to aid in the rulemaking process. Three facilities have agreed to allow source testing for the purposes of collecting this data [Ref. SCAQMD Source Test Plan to be conducted at Metal Melting facilities].

Almega was selected as a third-party source test contractor to perform this testing. The test matrix employed during the testing is presented in Table 2-1.

TABLE 2-1. TEST MATRIX

PARAMETER	TEST METHOD	# OF TEST RUNS	TEST TIME	LOCATION
Traverse Points	SCAQMD Methods 1.1 & 2.1	3 Per Location	≥ 120 min.	Simultaneous testing at the outlet and two inlets of the HEPA/ Baghouse
Molecular Weight and Excess Air	SCAQMD Method 10.1	1 per day, each Location	60 min.	
Moisture Content	Method 4.1 (Inclusive in the CARB M436, M425, & SCAQMD M5.1)	3 Per Location	≥ 120 min.	
Hexavalent and Total Chromium	CARB Method 425	3 Per Location	≥ 120 min.	
Selected Metals (As, Cd, Cr, & Ni)	CARB Method 436	3 Per Location	≥ 120 min.	
Particulate Matter (PM)	SCAQMD Method 5.1	3 Per Location		
Fugitive Emissions	Determination of overall capture efficiency	--	n/a	HEPA/ Baghouse Inlets



Almega performed source testing at the outlet and two designated inlets of the baghouse simultaneously over a three-day period May 21-23, 2019. The sampling was conducted in triplicate at each of the three (3) sampling locations for metals and chromium with just a single test conducted for the particulate matter. Testing was conducted as specified in the reference methods and Source Test Plan prepared by SCAQMD. The source test plan is included in the Appendix I for reference. Capture/Collection efficiency test was conducted by the SCAQMD personal and provided to Almega for the inclusion in the source test report. All pertinent process data was collected and provided by the facility and included in the Appendix H.


## 2.1 Document Outline

This report is organized as follows. Section 1.0 is a summary of the project and test results. Section 2.0 describes the project, its objectives and approach. Section 3.0 describes the equipment tested and applicable sampling locations. Section 4.0 describes the sampling and analysis procedures used to conduct the testing. Section 5.0 describes Quality Assurance and Quality Control activities performed, and section 6.0 discusses test results. The Appendices contain test results, calculated data, raw field data, analytical data, calibration records, and certification documents.

## 3.0 EQUIPMENT AND PROCESS DESCRIPTION

The metal melting facility A uses electric induction furnaces for the processing of materials including brass, zinc, steel, stainless steel, iron, aluminum, cobalt and nickel. A general schematic of the test locations follows:

Facility A - Basic Process Flow Diagram



**Note: Courtesy of SCAQMD Source Test Plan**

### 3.1 Process and Equipment Description

The facility has eight electric induction furnaces in three sizes as follows:

800 lb material capacity with a power rating of 250 kW

3,000 lb material capacity with a power rating of 350 kW

4,500 lb material capacity with a power rating of 1,000 kW (shared power supply)

[REDACTED] A heat cycle (or “heat”) begins when the metal is placed in the electric induction furnace. Electrical current is applied and the material becomes molten. Stainless steel materials are typically melted in one of the 4,500 lb furnaces with typical temperatures in the 3000°F range. During the melting process emissions are captured by an exhaust system which mounts to the furnace lid and utilizes a slot design. Suction is provided by the blower which is part of the baghouse/HEPA system. The HEPA filters are mounted in an enclosure above the baghouse and exhaust through two rectangular openings on either side of the enclosure. Because the exhaust does not exit through a typical exhaust stack design, special consideration was applied for the outlet testing.

[REDACTED] A typical heat cycle lasts for approximately 2 hours. Each furnace has individual exhaust ducting allowing for testing during a specific heat before being combined into a common exhaust header.

The baghouse and HEPA filter system controls emissions from the eight electric induction furnaces, five casting machines, one Hawley system, four mold spray and coating stations [REDACTED] [Ref. SCAQMD Source Test Plan to be conducted at Metal Melting facilities].

### 3.2 Operating Conditions during Test

Testing was performed during the processing of 316 stainless steel in one of the 4,500 lb capacity furnaces (Furnace 7). The individual exhaust duct that vents Furnace 7 was designated as “Inlet 1”. The control device is a slot exhaust system mounted on the base of the furnace’s lid. Furnaces No. 2, 3, and 7 were operated during the test program. The Inlet 2 (Upstream to Baghouse) location is the general inlet that vents all eight furnaces to the control device.

[REDACTED] The total inlet flow to the baghouse/HEPA system was the sum of Inlet 2 and a third inlet location designated as Inlet 3. This third inlet provided auxiliary facility process emissions to the baghouse/HEPA system not associated the specific with the metal melting process.

The process data including process material, baghouse differential pressure, HEPA filter differential pressure, ambient conditions, etc are included in the Appendix H.

### 3.3 Sampling Locations

#### **Inlet 1 (Inside):**

The reference method sampling locations meet the following specifications:

Sampling Location Configuration – Inlet Furnace (Inlet Inside)	
Distance from Upstream Disturbance	16.5 in. (1.6 duct diameter)-B
Distance from Downstream Disturbance	25 in. (2.5 duct diameter)-A
Port Length	3.5 in. (measured from outside wall)-L
Port Inside Diameter	3 in. - d
Number of sampling ports	2 (located at 90° intervals)
Stack Diameter	10 in. (internal diameter)-D

Sampling locations comply with the requirements of SCAQMD Method 1.2.

#### **Inlet 2 (Upstream to Baghouse):**

Sampling Location Configuration – Inlet 1 Outside (Upstream of Baghouse)	
Distance from Upstream Disturbance	48.5 in. (1.4 duct diameter)-B
Distance from Downstream Disturbance	87 in. (2.4 duct diameter)-A
Port Length	2 in. (measured from outside wall)-L
Port Inside Diameter	2.5 in.-d
Number of sampling ports	2 (located at 90° intervals)
Stack Diameter	36 in. (internal diameter)-D

Sampling locations comply with the requirements of SCAQMD Method 1.1.

#### **Inlet 3 (Flows Only):**

The reference method sampling locations are located on the rectangular inlet stack. The stack measured 21” x 25” and consists of five 3” diameter port. The sampling location complies with the requirements of SCAQMD Method 1.1.


#### **Exhaust**

Exhaust of the baghouse/HEPA system is through openings that are 154 inches tall by 46 inches wide. Prior to testing, a complete traverse was conducted at the Inlet 2 and Inlet 3. These flows (scfm) were summed and assumed to be the flow exhaust from the system (SCFM). The theoretical dP values were back calculated from the total flows of Inlet 2 and 3 and utilized to calculate the nozzle sizes for CARB Method 436, Method 425, and SCAQMD Method 5.1 testing.

The exhaust test location was accessed from a manlift for one side of the exhaust system and a platform was installed bridging the roof and the stack for the other side.



**Figure 3-1. General Stack Schematic**

146 inches divided by 4, and then by 2  
 36.50 Div 4  
 18.25 Div 2  
 54.75 Sum  
 60 minutes at 5 minutes a point




Note: Sampled 9 Points from roof side & 12 points from lot side.

Figure 3-2. Stack Schematic & Sampling Locations



**Note: Courtesy of SCAQMD Source Test Plan**

Figure 3-3. General Stack Schematic



## 4.0 SAMPLING AND ANALYTICAL PROCEDURES

Test measurements were performed according to sampling and analysis procedures promulgated by the South Coast Air Quality Management District (SCAQMD), California Air Resources Board (CARB), or US Environmental Protection Agency (EPA). The sampling and analysis procedures used for this test program are summarized below. Any modifications or deviations not addressed herein are discussed in Section 3 of this report.

- 4.1 SCAQMD Methods 1.1-4.1 – Determination of Stack Gas Volumetric Flow Rate, Molecular Weight, and Moisture Content
  - 4.1.1 SCAQMD Method 1.1 – Sampling Traverse Points
  - 4.1.2 SCAQMD Method 2.1 – Stack Gas Flow Rate
  - 4.1.3 SCAQMD Method 3.1 – Stack Gas Molecular Weight
  - 4.1.4 SCAQMD Method 4.1 – Stack Gas Moisture Content
- 4.2 SCAQMD Method 5.1 – Particulate Matter (PM)
- 4.3 SCAQMD Method 10.1 – Integrated Gas Sampling (O<sub>2</sub>/CO<sub>2</sub>)
- 4.4 CARB Method 425 – Total and Hexavalent Chromium
- 4.5 CARB Method 436 – Multiple Metal Emissions
- 4.6 Capture/Collection Efficiency

### 4.1 SCAQMD Methods 1.1-4.1 – Determination of Stack Gas Volumetric Flow Rate, Molecular Weight, and Moisture Content

The flue gas flow characteristics (i.e. flow rate, molecular weight, and moisture content) were determined according to SCAQMD Methods 1.1 through 4.1. The testing was conducted as follows:

#### 4.1.1 SCAQMD Method 1.1/1.2 – Sampling and Velocity Traverse Points

The number and location of traverse points are determined according to SCAQMD Method 1.1/1.2 based on the physical dimensions of the sampling location and process parameters. In principle, the stack cross-section is divided into equal areas, each of which is represented by a “traverse point”. Generally, the number of traverse points diminishes as the flow profile at the sampling location becomes uniform. In most cases, the maximum number of sampling points is 24 for particulate/metals testing and 16 for velocity traverses. Fewer traverse points are permitted as described in the method.

#### 4.1.2 SCAQMD Method 2.1 – Gas Velocity and Traverse Points

The velocity and volumetric flow rate of the laser exhaust was determined according to SCAQMD Method 2.1. In this method, the velocity head (differential pressure) and temperature is measured at the required traverse points. The stack gas differential pressure head was determined using an "S" type Pitot tube and inclined liquid manometer. The temperature was measured using a type "K" thermocouple and digital temperature readout.

Prior to testing, the measurement system was set-up and leak-checked. Then the velocity head

and temperature was recorded at predetermined traverse points. After the last traverse is completed, the system was again leak-checked. After completion of the traverse, the static pressure in the stack was determined near the centroid of the stack. The stack gas velocity was calculated using the velocity head, and stack gas temperature, pressure and molecular weight.

QA/QC for the method included field performance checks, and periodic calibrations of test equipment including the Pitot tube, differential pressure gauge, TC and TC-readout. A swirl check was also performed to assess cyclonic flow.

#### 4.1.3 SCAQMD Method 3.1 - Gas Molecular Weight

The stack gas molecular weight (MW) was calculated based on the fraction of its major constituents including: oxygen (O<sub>2</sub>), carbon dioxide, (CO<sub>2</sub>), nitrogen (N<sub>2</sub>), carbon monoxide (CO), and water (H<sub>2</sub>O). The dry MW was calculated based on the partial fractions of O<sub>2</sub>, CO<sub>2</sub>, N<sub>2</sub>, and CO. Specifically, the O<sub>2</sub> and CO<sub>2</sub> fractions were determined by CEMS, integrated sampling, or grab sampling, and the balance was assumed to be N<sub>2</sub> and CO. The wet MW was calculated based on the fractions of dry gas and water vapor. The dry and wet MW were calculated according to the following equations:

$$MW_{\text{DRY}} = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (\%N_2 + \%CO)$$

$$MW_{\text{WET}} = 0.18 \times \%H_2O + MW_{\text{DRY}} \times (1 - \%H_2O/100)$$

where: MW<sub>DRY</sub> = stack gas molecular weight, dry-basis  
 MW<sub>WET</sub> = stack gas molecular weight, wet-basis  
 0.32 = molecular weight fraction for O<sub>2</sub>  
 0.44 = molecular weight fraction for CO<sub>2</sub>  
 0.28 = molecular weight fraction for N<sub>2</sub> and CO  
 0.18 = molecular weight fraction for H<sub>2</sub>O (water vapor)  
 %X = fraction of X in stack gas, dry basis, where X = O<sub>2</sub>, CO<sub>2</sub>, N<sub>2</sub>, CO  
 %H<sub>2</sub>O = fraction of water vapor in stack gas, wet-basis

For this test, single bag sample was collected at each test location/each day over a period of 60 minutes. These samples were analyzed for oxygen and carbon dioxide via SCAQMD Method 10.1. The analysis of those bag samples shows that the O<sub>2</sub>/CO<sub>2</sub> concentration for all sampling locations is in ambient level. In case of the bag leaks or some anomalies the default ambient level O<sub>2</sub>/CO<sub>2</sub> was used for gas density calculations.

#### 4.1.4 SCAQMD Method 4.1- Gas Moisture Content

The stack gas moisture content was determined according to SCAQMD Method 4.1. In this method, water vapor is collected in a condenser while the dry stack gas volume is measured using a dry gas meter. The volume of water vapor was calculated from the amount of water condensed and the total gas volume is the sum of water vapor plus dry stack gas. The moisture content was determined as a fraction of the total wet stack gas volume. The following calculations were used.



$$B_{WS} = \frac{V_{W,Std}}{V_{M,Std} + V_{W,Std}}$$

$$V_{W,Std} = K_1 \times V_{H_2O}$$

$$V_{M,Std} = T_{Std}/P_{Std} \times Y_M \times V_M \times P_M/T_M$$

- where:
- $B_{WS}$  = Fraction of water vapor in stack gas
  - $V_{W,Std}$  = Volume of water vapor (scf)
  - $V_{M,Std}$  = Volume of stack gas sampled (dscf)
  - $K_1$  = Unit volume of water vapor (0.04707 scf @68°F or 0.0464 scf @60°F)
  - $T_{Std}$  = Standard Temperature (528°R or 520°R)
  - $P_{Std}$  = Standard Pressure, 29.92 in. Hg
  - $Y_M$  = Dry gas meter calibration factor
  - $V_M$  = Measured volume of stack gas sampled
  - $P_M$  = Dry gas meter pressure (in. Hg)
  - $T_M$  = Dry gas meter temperature (°R)

The moisture content was simultaneously determined if sampling was performed isokinetically otherwise performed as follows:

Moisture was collected in a sampling train consisting of a probe, TFE line, four impingers in an ice bath, a leak-free pump, a vacuum gauge and a dry gas meter. Figure 4-1 is a schematic of a typical moisture train. Initially, impingers #1 and #2 contained 100 ml of water, impinger #3 was empty, and impinger #4 contained a known amount (approximately 300 g) of desiccant (e.g. Silica Gel). Prior to sampling, a leak check of the sampling train was performed. Then, the sampling probe was inserted into the centroid of the stack, the initial meter readings (volume, temperatures, etc.) were recorded, the sample pump is started and the sampling rate is adjusted to the desired sampling rate (typically 0.75 dry cfm). Sampling was conducted until at least 22 dry cubic feet were collected. After sampling, the final meter readings were recorded and the impinger train was recovered. The change in volume and/or weight of the impinger train components was used to determine the amount of moisture condensed. The volume of water vapor and the corrected volume of dry gas sampled were used to calculate the moisture fraction as described above.

## 4.2 SCAQMD Method 5.1 - Total Particulate Matter

Measurements to determine total particulate matter were performed according to SCAQMD Method 5.1. In this method, a stack gas sample is isokinetically extracted from the stack through a stainless-steel nozzle and probe and transported to an impinger train in an ice bath. Entrained particulates were collected in the impingers and on a back-up filter placed between the 3<sup>rd</sup> and 4th impingers. Figure 4-3 is a schematic of the sampling apparatus.

Prior to testing, a series of measurements were made to determine location and number of traverse points, gas velocity, MW, and moisture content. The results of these measurements were used to determine the appropriate nozzle size for isokinetic sampling. The sampling rate was adjusted to maintain isokinetic conditions based on pitot and TC measurements.


The sampling train was prepared by charging impingers # 1 and # 2 with 100 ml of D.I. water and impinger # 4 with approximately 200 g of silica gel. Impinger # 3 was left empty. Finally, the sampling train was sealed, transported to the sampling location, and leak-checked. Sampling was performed at each traverse point. After completing the test, the Method 5.1 sample was taken to a secured area (i.e., Mobile test van or Almega's laboratory) and recovered.

The recovered samples were entered into Almega's Sample Custody Program and delivered to the laboratory for analysis. At the laboratory, samples were analyzed as follows:

The filter was removed and placed in a desiccator until completely dry. Following drying, the filter was weighed to determine the fraction of sample acquired on the filter. The probe, nozzle, sampling lines, and impingers were washed with deionized water and methylene chloride, and the washing solutions were combined with the impinger solutions. The combined solution was extracted with methylene chloride. The aqueous fraction was heated to boil off water, and the organic fraction was allowed to evaporate at room temperature. Residues from both fractions were weighed and combined with the sample weight from the filter to determine the total particulate sample weight. Samples were stored at 4 °C until analyzed at the Almega in-house laboratory.

Field and laboratory data were used to calculate sample volume corrected to standard conditions, stack gas flow rate, and particulate emissions. Emissions were reported in gr/dscf and lb/hr.

Figure 4-1. Sampling Apparatus for Particulate Matter



- |  |  |
|--|--|
| 1. Temperature Sensor                    | 11. Ice Bath                                 |
| 2. Nozzle                                | 12. Filter                                   |
| 3. Glass Lined Stainless Steel Probe     | 13. Sealed Pump (Leak Free)                  |
| 4. S-type Pitot Tube                     | 14. Filter for Pump                          |
| 5. Stack Wall                            | 15. Metering Valve                           |
| 6. Temperature Sensor Meter              | 16. Vacuum Gauge                             |
| 7. Pitot Tube Inclined Manometer         | 17. By-pass Valve                            |
| 8. Impinger with 100 ml H <sub>2</sub> O | 18. Temperature Compensated<br>Dry Gas Meter |
| 9. Empty Bubbler                         | 19. Orifice                                  |
| 10. Bubbler with Silica Gel              | 20. Orifice Inclined Manometer               |

#### **4.3 SCAQMD METHOD 10.1 – INTEGRATED GAS SAMPLING (O<sub>2</sub> & CO<sub>2</sub>)**

In this method, gaseous components of the stack gas (e.g. O<sub>2</sub>, & CO<sub>2</sub>) are measured using integrated sampling in accordance with the procedures specified in SCAQMD Method 10.1. Sample was collected in a Tedlar bag for each test event and analyzed by Almega's in-house laboratory via GC.

#### **4.4 Total and Hexavalent Chromium (CARB Method 425)**

Hexavalent chromium and total chromium were measured according to CARB Method 425. The sampling was conducted isokinetically for 2-hours in order to achieve target detection limits. After sampling, the sampling train was recovered and analyzed for both total chromium and hexavalent chromium.


The sampling apparatus included a glass probe, a Teflon union, a flexible Teflon sample line from the probe to the first impinger, two Greenburg-Smith impingers each containing 100 ml of 0.1N NaHCO<sub>3</sub> solution, an empty modified impinger, and a modified impinger containing silica gel. The glass probe is fitted with a glass nozzle for isokinetic sampling. The remaining components of the sampling apparatus included an umbilical line, a vacuum pump, a dry gas meter, and a calibrated orifice connected to an inclined manometer. The sampling train is shown in Figure 4-3.

The volume of the impinger solution and the weight of the silica gel were recorded before and after the tests to determine the moisture content of the stack gas. All sample weights were recorded on the sampling data sheet during charging and sample recovery. Leak checks were performed before and after each test.

Volumetric flow rates at the sampling locations were calculated from the measured velocity head and the cross-sectional area of the duct. As each traverse point was sampled, the velocity head of the flue gas was measured with an S-type pitot tube connected to an inclined manometer, and the temperature of the flue gas was measured with a type "K" thermocouple and a digital readout (SCAQMD Method 2.1). This information was used to adjust the sampling rate to isokinetic conditions.

After the test, the contents of the impingers were recovered as described in the method and stored in pre-cleaned sample bottles. The final pH of the sample was verified using multiple-field pH paper. The samples were then stored at 4°C or less until delivered to the Laboratory for analysis. Samples were analyzed for hexavalent chromium as described in the method. Hexavalent chromium was determined by ion chromatography (IC) by Weck Laboratories, Inc. located in City of Industry, California. A reagent blank was provided to determine background levels of target analytes for blank corrections, if applicable. All samples are accompanied by a chain of custody until disposed.

**Figure 4-2 CARB Method 425 Sampling**



Note: 0.1NaHCO<sub>3</sub> was used instead 0.1NaOH.

#### **4.5 CARB METHOD 436 - DETERMINATION OF MULTIPLE METALS EMISSIONS**

Multiple metals samples were collected isokinetically in accordance with CARB Method 436, “Determination of Multiple Metals Emissions from Stationary Sources.” Stack sample was withdrawn from the source, with particulate emissions collected in the probe and on a heated filter and gaseous emissions collected in a series of chilled impingers containing an aqueous solution of dilute nitric acid combined with dilute hydrogen peroxide in two impingers.


A schematic of the sampling apparatus is shown in Figure 4-2. The sampling train consists of a nozzle, heated probe, heated filter, and a series of three impingers immersed in an ice bath and a silica gel impinger. The probe is made of borosilicate glass with a heating system of maintaining an exit gas temperature during sampling of  $248 \pm 25^\circ\text{F}$ .

The Teflon line was used to transfer the sample from the filter to the impingers. The impinger train was setup as follows: the first and second impingers each contained 100 mL of a nitric acid/hydrogen peroxide solution (5%  $\text{HNO}_3$ /10%  $\text{H}_2\text{O}_2$ ), the third was empty, the last impinger contained silica gel (for moisture collection), and an umbilical line connected to an isokinetic sampling console. The sampling console includes a vacuum pump, a dry gas meter, and additional monitors and controls for collecting a sample. A thermometer capable of measuring to within  $1^\circ\text{C}$  ( $2^\circ\text{F}$ ) was placed at the outlet of the last impinger.

Sampling train components were recovered into separate front and back half fractions and acid digested using conventional digestion techniques to dissolve inorganic and to remove organic constituents that created analytical interferences. After digestion, portions of the probe catch, filter catch, and nitric acid/hydrogen peroxide catch were combined into a single composite sample and analyzed for all target metals according to ICP/MS as prescribed by the Method. Sample analyses were performed by Weck Laboratory in City of Industry, California.

Quality assurance samples include field blanks and reagent blanks. Quality control samples include laboratory method blanks and duplicates. Field sampling and laboratory data were used to calculate emissions concentrations and mass emission rates as described in the Method. Final test results were corrected for background levels found in reagent blanks. Results are reported for concentration in milligram per dry standard cubic meter (mg/dscm). Analysis results that are below the limit of detection (i.e. not detected or ND) were substituted for the one-half of detection limit in calculating three-run averages.

Figure 4-3. CARB Method 436 Sampling Apparatus



Note: Impingers 5 and 6 containing 4% KMnO<sub>4</sub>/10% H<sub>2</sub>SO<sub>4</sub> were not used in actual sampling since Mercury was not measured.

#### 4.6 Verification of Capture/Collection Efficiency

SCAQMD conducted the verification of capture efficiency test and documented prior to the source test. Detail summary test report can be found in Appendix F. The smoke test video recording is also included in a CD-ROM and will be submitted with the report.

## **5.0 QUALITY ASSURANCE AND QUALITY CONTROL**

Almega applies stringent quality assurance and quality control (QA/QC) procedures to ensure the validity of measurements for all test methods. The following section discusses general and project-specific QA/QC measures.

### **5.1 General QA/QC**

Almega's QA/QC procedures follow guidelines from the "Quality Assurance Handbook for Air Pollution Measurement Systems," Volume I through III. And, procedures for pretest preparation and calibration of sampling equipment are followed. Standardized written procedures, calculator programs, and computer spreadsheets are used for test planning, pre-survey, equipment checklist, preliminary calculations, testing, data analysis, and reporting. Pretest equipment preparation and maintenance include organization of the following equipment prior to testing:

- Mobile RM CEM test van: Check fluids, fuel, mechanical conditions, verify operation of CEM instruments, sample lines and sample conditioner prior to the date of the source test.
- Sampling Equipment: Check meter boxes, pitot tubes, manometers and thermocouples to ensure in good working conditions and in proper calibrations. Preclean sampling trains and seal all openings prior to use.

Calibrations are performed in accordance with Chapter III of the SCAQMD Source Test Manual (March 1989). Table 5-1 shows the test equipment calibration schedules. Table 5-2 shows the test equipment maintenance schedules.

### **5.2 Project-Specific QA/QC**

This project included specific QA/QC activities required to validate the test results. These QA/QC activities are based on the test methods discussed in Section 5 and generally acceptable test procedures. Reference Methods used for source testing are promulgated by the South Coast Air Quality Management District (SCAQMD), the California Air Resource Board (CARB), or the US Environmental Protection Agency (EPA). Any deviations from published Methods are approved in advance by the regulatory agency (i.e. SCAQMD), prior to implementation if possible. Project-specific QA/QC activities and results that may impact test results are discussed in Section 3.



TABLE 5-1. TEST EQUIPMENT CALIBRATION SCHEDULE

<b>Equipment</b>	<b>Calibration Period</b>	<b>Standard or Method of Calibration</b>
Thermocouples	6 Months and 2 Months	Mercury Thermometer, three point (ice, boiling water, hot oil)
Dry Gas Meters	6 Months and 2 Months	Critical orifice
Field Barometers	6 Months, Check prior to usage	Mercury Barometer
S-Type Pitot	6 Months Check prior to usage	EPA Method 2, Measure physical configuration. Reshape pitot tips or calibrate if configuration does not meet the limits.
Pressure gauges	6 Months	Five-point calibration against manometer
	2 Months	Three-point check
Temp. Meters	6 Months	Precision Potentiometer
CEM Systems	Bimonthly, or as needed	Specified by Manufacturer

TABLE 5-2. TEST EQUIPMENT MAINTENANCE

<b>Equipment</b>	<b>Check For</b>	<b>Correction</b>	<b>Frequency</b>
CEM Systems	Absence of malfunction, noise, drift, conversion efficiency for NOx anlzr.	As required by the manufacture, or depending on performance	Bimonthly
Pumps	Absence of leakage, flow, proper vacuum	Replace parts, inspect, clean	300 hours of usage
Flow Devices	Levelling, zeroing, obstruction, deformation	Clean, replace, or re-calibrate	300 hours of usage
Calibration Gases	Expiration date, tank pressure	Re-certify, order new gases	2 months and prior to field testing
Regulators	Malfunction, Gauge precision	Repair or replace	3 months and prior to field testing
Gas Divider	Malfunction, precision	Repair or replace	Monthly and before field testing
Condensers	Leakage, temperature	Repair or replace	Monthly and before field testing
Heated lines	Leakage, temperature, cleanliness	Repair, replace, clean	Monthly and before field testing

## 6.0 TEST RESULTS AND DISCUSSION

The testing was conducted on May 21 through 23, 2019. The sampling locations and equipment were prepared prior to initiating the sampling activities. Testing was conducted after the arrival of Almega's test personnel and set-up of test equipment.

### 6.1 DISCUSSION

The scope of work included the testing to determine the emissions of Particulate Matter (PM) and selected metals (As, Cd, Ni, Cr, and Cr<sup>+6</sup>) at the two designated inlets and the outlet of the baghouse/HEPA system. The metals testing were conducted in triplicate with just a single run conducted for PM.

Test calculations are corrected to 68°F for CARB methods and 60°F for SCAQMD methods. The sampling system was setup on May 20, 2019. Sampling was conducted for all three locations on May 21 through 23, 2019.

The metals and PM emissions in the stack gas effluent were reported in micrograms per dry standard cubic meter ( $\mu\text{g}/\text{dscm}$ ), microgram per dry standard cubic feet ( $\mu\text{g}/\text{dscf}$ ), and pounds per hours ( $\text{lbs}/\text{hr}$ ). The results are summarized in Table 1-1. Test-specific results for all three sampling locations are presented in Tables 6-1 through 6-9. Supporting data including calculations, field test data, laboratory analysis reports, and QA/QC data are found in the Appendices.

#### 6.1.1 TEST RESULTS – CARB METHOD 436 MULTIPLE METALS

Sampling and analysis for Multiple Metals was conducted for the select metals in triplicate according to CARB Method 436. The mercury testing option was not used. The CARB Method 436 sampling was conducted simultaneously for all three locations. The sampling duration for each run was two hours. The first and second runs were conducted on May 21 and the third run was conducted on May 22, 2019. The field blank was prepared and collected on May 21 before Run 1. Only Arsenic, Cadmium, Chromium, and Nickel were analyzed as purpose in this testing program. One set of reagent blank was analyzed for those selected metals and the reported results are corrected with the detectable results.

The detailed test results are presented in Table 6-1 for the outlet and Tables 6-4 and 6-7 for the inlets.

#### 6.1.2 TEST RESULTS – CARB M425 HEXAVALENT CHROMIUM AND TOTAL CHROMIUM

Sampling and analysis for hexavalent chromium and total chromium was conducted in triplicate according to CARB Method 425 simultaneously at all three locations. The sampling duration for each run was two hours. The first run was conducted on May 22 with the remaining two runs conducted on May 23, 2019. The field blank was prepared and collected on May 22 before Run 1. The CARB Method 425 test method used was modified to include the absorbing solution of 0.1N

sodium bicarbonate. One set of reagent blank was analyzed for hexavalent chromium and total chromium, the reagent blank results were not detected and no correction was necessary.

These samples were analyzed within the holding time recommended by the method. However, the samples were re-analyzed to achieve a lower reporting limit without dilution and that second analysis exceeded the recommended holding time (see detail in CARB Method 425 lab report).

The detailed test results are presented in Table 6-2 for the outlet and Tables 6-5 and 6-8 for the inlets.

### 6.1.3 TEST RESULTS – PARTICULATE MATTER

The single run sampling and analysis for particulate matter was conducted according to SCAQMD Method 5.1. The sampling duration for the test run was two hours. The sampling for PM was conducted simultaneously for all three locations on May 24, 2019. The field blank was prepared and collected prior to sampling.

The detailed test results are presented in Table 6-3 for the outlet and Tables 6-6 and 6-9 for the inlets.

### 6.2 OTHERS

- Filter and probe temperatures were maintained at  $248 \pm 25^{\circ}\text{F}$  for CARB Method 436 isokinetic sampling.
- Each impinger solution was maintained at a pH greater than eight (8) for CARB Method 425, and this was documented on the field data sheets.
- Impinger trains and XAD temperatures, where applicable, were maintained below  $68^{\circ}\text{F}$  for all sampling event.
- Percent (%) Isokinetics was within the allowable range of 90-110% for all isokinetic sampling events.
- Cyclonic flow check was performed prior to sampling. No cyclonic flow was found.
- The single bag sample was collected at each test location/each day over a period of 60 minutes. These samples were analyzed for oxygen and carbon dioxide via SCAQMD Method 10.1. The analysis of those bag samples shows that the  $\text{O}_2/\text{CO}_2$  concentration for all sampling locations is in ambient level. In cases where the bag leaked or other issue the default ambient level  $\text{O}_2/\text{CO}_2$  was used for gas density calculations.
- The baghouse outlet does not have a traditional stack or duct and the exhaust exits from the HEPA filter enclosure from two sides horizontal directions. Based EPA Method 5D, the exhaust differential velocity pressure was determined by applying the inlet flow to the

entire area of the HEPA filter enclosure (see Appendix C5). The calculated differential pressure was then used for nozzle selection and corresponding isokinetic sampling rate. No corrections were made for temperature.

- No unusual operating conditions or field-testing observations were reported. Field data and calculations for all the emissions are presented in respective appendices.

Testing was performed as specified in the reference methods and the SCAQMD Source Test Plan. No modifications to proposed sampling and analysis procedures other than those noted above were required.

### 6.3 TEST CHRONOLOGY

All testing was conducted during the periods listed below:

Parameter Measurement	Test Date	Time	Run No.
CARB Method 436 Baghouse Outlet, Inlet 1 (inside), and Inlet 1 (Outside)	05/21/19	12:10 – 14:33	Run 1
	05/21/19	15:10 – 17:40	Run 2
	05/22/19	08:30 – 10:48	Run 3
CARB Method 425 Baghouse Outlet, Inlet 1 (inside), and Inlet 1 (Outside)	05/22/19	11:50 – 14:15	Run 1
	05/24/19	14:38 – 16:53	Run 2
	05/23/19	08:25 – 10:45	Run 3
SCAQMD Method 5.1 Baghouse Outlet, Inlet 1 (inside), and Inlet 1 (Outside)	05/23/19	11:20 – 13:36	Run 1

**TABLE 6-1. TEST RESULTS  
CARB 436 (Multiple Metals)**

Facility: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Outlet

Test Data	Units	Source Test Results			Average
		Run 1	Run 2	Run 3	
Run Number	--				
Test Date	mm/dd/yy	05/21/19	05/21/19	05/22/19	--
Test Time	hh:mm	12:10 - 14:33	15:10 - 17:40	08:30 - 10:48	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	85.0	86.2	86.6	<b>85.9</b>
Moisture	%	1.3	1.2	1.6	<b>1.4</b>
Sample Volume	dscf	95.0	95.0	91.3	<b>93.8</b>
Oxygen**	% v/v	20.9	20.9	20.9	<b>20.9</b>
Carbon Dioxide**	% v/v	< 0.04	< 0.04	< 0.04	<b>&lt; 0.04</b>
Stack Flow Rate	dscfm	46,646	48,131	48,166	<b>47,648</b>
<b><u>CARB Method 436</u></b>					
<b><u>CONCENTRATION</u></b>					
		<u>Total</u>		<u>Total</u>	
Arsenic	ug/dscm	ND 0.372	ND 0.372	ND 0.387	< <b>0.377</b>
	ug/dscf	ND 0.0105	ND 0.0105	ND 0.0109	< <b>0.011</b>
Cadmium	ug/dscm	ND 0.372	ND 0.372	ND 0.387	< <b>0.377</b>
	ug/dscf	ND 0.0105	ND 0.0105	ND 0.0109	< <b>0.011</b>
Chromium	ug/dscm	14.7	RL 0.781	RL 0.812	<b>5.42</b>
	ug/dscf	0.416	RL 0.0221	RL 0.0230	<b>0.154</b>
Nickel	ug/dscm	2.27	RL 2.01	RL 2.09	<b>2.12</b>
	ug/dscf	0.0642	RL 0.0569	RL 0.0591	<b>0.0601</b>
<b><u>CARB Method 436</u></b>					
<b><u>MASS EMISSION RATE</u></b>					
		<u>Total</u>		<u>Total</u>	
Arsenic	lbs/hr	ND 6.49E-05	ND 6.71E-05	ND 6.98E-05	< <b>6.72E-05</b>
Cadmium	lbs/hr	ND 6.49E-05	ND 6.71E-05	ND 6.98E-05	< <b>6.72E-05</b>
Chromium	lbs/hr	2.56E-03	RL 1.41E-04	RL 1.46E-04	<b>9.51E-04</b>
Nickel	lbs/hr	3.96E-04	RL 3.62E-04	RL 3.77E-04	<b>3.78E-04</b>

Notes:

\* Performed during isokinetic sampling (e.g. CARB Method 436).

\*\*SCAQMD Method 10.1 Tedlar bag sample was leaked, ambient level O2/CO2 was used for gas density calculations.

ND or "<" - Not detected, reporting limit reported.

**TABLE 6-2. TEST RESULTS**  
**CARB 425 (Hexavalent & Total Chromium)**

Facility: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Outlet

TEST DATA	UNITS	TEST RESULTS			AVERAGE
		Run 1	Run 2	Run 3	
Run Number	-				
Test Date	mm/dd/yy	5/22/19	5/22/19	5/23/19	--
Test Time	hh:mm	11:50 - 14:15	14:38 - 16:53	8:25 - 10:45	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	87.2	86.9	86.5	<b>86.9</b>
Moisture	%	1.8	1.7	1.7	<b>1.7</b>
Sample Volume	dscf	91.2	91.2	90.7	<b>91.0</b>
Oxygen**	% v/v	20.9	20.9	20.9	<b>20.9</b>
Carbon Dioxide**	% v/v	0.04	0.04	0.04	<b>0.04</b>
Stack Flow Rate	acfm	-	-	-	-
Stack Flow Rate	dscfm	47,814	48,789	48,995	<b>48,533</b>
<b><u>Total Catch (CARB 425)</u></b>					
Chromium VI	ug	< 0.0460	< 0.0420	< 0.0720	< <b>0.0533</b>
Total Chromium	ug	< 2.000	< 2.000	< 2.000	< <b>2.00</b>
<b><u>Concentration (CARB 425)</u></b>					
Chromium VI	ug/dscm	< 0.0178	< 0.0163	< 0.0280	< <b>0.0207</b>
	ug/dscf	< 0.000504	< 0.000461	< 0.000794	< <b>0.000586</b>
Total Chromium	ug/dscm	< 0.7742	< 0.7748	< 0.7786	< <b>0.776</b>
	ug/dscf	< 0.0219	< 0.0219	< 0.0220	< <b>0.022</b>
<b><u>Mass Emissions (CARB 425)</u></b>					
Chromium VI	ug/hr	< 1446	< 1349	< 2333	< <b>1710</b>
Chromium VI	mg/hr	< 1.45	< 1.35	< 2.33	< <b>1.71</b>
Chromium VI	lb/hr	< 3.2E-06	< 3.0E-06	< 5.1E-06	< <b>3.77E-06</b>
Total Chromium	ug/hr	< 62890	< 64226	< 64816	< <b>63977</b>
Total Chromium	mg/hr	< 62.89	< 64.23	< 64.82	< <b>64.0</b>
Total Chromium	lb/hr	< 1.4E-04	< 1.4E-04	< 1.4E-04	< <b>1.41E-04</b>

Notes:

\* Performed during isokinetic sampling by CARB 425.

\*\* SCAQMD Method 10.1 sample reported error values, ambient O2/CO2 used for gas density calculations.

"<" Indicates an analytical result of non-detect (ND) and the use of laboratory MRL for emission calculations.

**TABLE 6-3. TEST RESULTS  
SCAQMD Method 5.1 (Particulate Matter)**

**Facility: AQMD Facility A**

**City: ██████████ CA**

**Source: Baghouse**

**Location: Outlet**

Run Number	1	
Run Date	05/23/19	
Run Start Time	11:20	
Run Stop Time	13:30	
<b>Test Train Parameters</b>		<b>AVERAGE</b>
Volume of Dry Gas Sample, SCF*	89.20	89.20
<b>Flue Gas Parameters</b>		
CO2, Percent By Volume, Dry**	0.04	0.04
O2, Percent By Volume, Dry**	20.90	20.90
Temperature, Degrees F	86.7	86.7
Moisture, %	1.86	1.86
Air Flow Rate, ACFM	-	-
Air Flow Rate, Dry SCFM*	47,272	47,272
<b>Total Particulate</b>		
Catch, mg	3.32	3.32
Concentration, Gr/DSCF	0.000574	0.000574
Emission Rate, lb/hr	0.233	0.233

\* 60 Degrees F and 29.92 Inches of Mercury

\*\* Ambient O2/CO2 was used in gas density calculations.



**TABLE 6-4. TEST RESULTS  
CARB 436 (Multiple Metals)**

Facility: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Test Data	Units	Source Test Results			Average
		Run 1	Run 2	Run 3	
Run Number	--				
Test Date	mm/dd/yy	05/21/19	05/21/19	05/22/19	--
Test Time	hh:mm	12:10 - 14:30	15:10 - 17:40	08:30 - 10:45	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	123.4	133.6	132.1	<b>129.7</b>
Moisture	%	1.4	1.4	1.1	<b>1.3</b>
Sample Volume	dscf	74.7	81.3	104.2	<b>86.7</b>
Oxygen**	% v/v	20.0	19.9	20.2	<b>20.0</b>
Carbon Dioxide**	% v/v	< 0.3	< 0.3	< 0.3	<b>&lt; 0.3</b>
Gas Velocity	ft/min	5,549	6,070	5,910	<b>5,843</b>
Stack Flow Rate	acfm	3,027	3,311	3,224	<b>3,187</b>
Stack Flow Rate	dscfm	2,599	2,795	2,716	<b>2,703</b>
<b><u>CARB Method 436</u></b>					
<b><u>CONCENTRATION</u></b>					
		<u>Total</u>	<u>Total</u>	<u>Total</u>	
Arsenic	ug/dscm	ND 0.47	ND 0.43	0.98	<b>0.63</b>
	ug/dscf	ND 0.013	ND 0.012	0.028	<b>0.018</b>
Cadmium	ug/dscm	ND 0.473	ND 0.435	0.339	<b>0.415</b>
	ug/dscf	ND 0.027	ND 0.025	0.019	<b>0.024</b>
Chromium	ug/dscm	103.3	17.2	233	<b>118</b>
	ug/dscf	2.93	0.49	6.61	<b>3.34</b>
Nickel	ug/dscm	27.3	2.61	43.6	<b>24.5</b>
	ug/dscf	0.772	0.074	1.235	<b>0.694</b>
<b><u>CARB Method 436</u></b>					
<b><u>MASS EMISSION RATE</u></b>					
		<u>Total</u>	<u>Total</u>	<u>Total</u>	
Arsenic	lb/hr	ND 4.60E-06	ND 4.55E-06	1.00E-05	<b>4.86E-06</b>
Cadmium	lb/hr	ND 4.60E-06	ND 4.55E-06	4.21E-06	<b>2.93E-06</b>
Chromium	lb/hr	1.01E-03	1.80E-04	2.37E-03	<b>1.19E-03</b>
Nickel	lb/hr	2.66E-04	2.73E-05	4.44E-04	<b>2.46E-04</b>

Notes:

\* Performed during isokinetic sampling (e.g. CARB Method 436).

\*\* Measured via SCAQMD Method 10.1.

ND or "<" - Not detected, reporting limit reported.

**TABLE 6-5. TEST RESULTS  
CARB 425 (Hexavalent & Total Chromium)**

Facility: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

TEST DATA	UNITS	TEST RESULTS			AVERAGE
		Run 1	Run 2	Run 3	
Run Number	-				
Test Date	mm/dd/yy	5/22/19	5/22/19	5/23/19	--
Test Time	hh:mm	11:50 - 14:15	14:38 - 16:53	8:25 - 10:45	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	152.3	138.0	128.4	<b>139.6</b>
Moisture	%	1.2	1.3	1.5	<b>1.4</b>
Sample Volume	dscf	102.7	100.5	105.9	<b>103.0</b>
Oxygen**	% v/v	19.9	19.9	20.2	<b>20.0</b>
Carbon Dioxide**	% v/v	0.30	0.30	0.30	<b>0.30</b>
Gas Velocity	ft/min	6,000.0	5,828.0	5,917.3	<b>5,915</b>
Stack Flow Rate	acfm	3,272	3,179	3,227	<b>3,226</b>
Stack Flow Rate	dscfm	2,661	2,644	2,743	<b>2,683</b>
<b><u>Total Catch (CARB 425)</u></b>					
Chromium VI	ug	58.5	3.8	23.5	<b>28.6</b>
Total Chromium	ug	281	55	346	<b>227</b>
<b><u>Concentration (CARB 425)</u></b>					
Chromium VI	ug/dscm	20.12	1.34	7.84	<b>9.76</b>
	ug/dscf	0.570	0.038	0.222	<b>0.276</b>
Total Chromium	ug/dscm	96.64	19.29	115.44	<b>77.1</b>
	ug/dscf	2.74	0.55	3.27	<b>2.18</b>
<b><u>Mass Emissions (CARB 425)</u></b>					
Chromium VI	ug/hr	90955	6000	36528	<b>44494</b>
Chromium VI	mg/hr	91.0	6.00	36.5	<b>44.5</b>
Chromium VI	lb/hr	2.01E-04	1.32E-05	8.05E-05	<b>9.81E-05</b>
Total Chromium	ug/hr	436895	86678	537974	<b>353849</b>
Total Chromium	mg/hr	437	87	538	<b>354</b>
Total Chromium	lb/hr	9.63E-04	1.91E-04	1.19E-03	<b>7.80E-04</b>

Notes:

\* Performed during isokinetic sampling by CARB 425.

\*\* O2/CO2 was measured via SCAQMD Method 10.1 by GC.

**TABLE 6-6. TEST RESULTS  
SCAQMD Method 5.1 (Particulate Matter)**

**Facility: AQMD Facility A**

**City: ██████████ CA**

**Source: Baghouse**

**Location: Inlet 1 Furnace (Inside)**

Run Number	1	
Run Date	05/23/19	
Run Start Time	11:20	
Run Stop Time	13:36	
<b>Test Train Parameters</b>		<b>AVERAGE</b>
Volume of Dry Gas Sample, SCF*	101.79	101.79
<b>Flue Gas Parameters</b>		
CO2, Percent By Volume, Dry**	< 0.30	< 0.30
O2, Percent By Volume, Dry**	20.20	20.20
Temperature, Degrees F	128.0	128.0
Moisture, %	1.55	1.55
Air Flow Rate, Wet ACFM	3,142	3,142
Air Flow Rate, Dry SCFM*	2,629	2,629
<b>Total Particulate</b>		
Catch, mg	60.42	60.42
Concentration, Gr/DSCF	0.009160	0.009160
Emission Rate, lb/hr	0.206	0.206

\* 60 Degrees F and 29.92 Inches of Mercury

\*\* O2/CO2 was sampled in Tedlar bag and analysed via SCAQMD Method 10.1 by GC.

**TABLE 6-7. TEST RESULTS  
CARB 436 (Multiple Metals)**

Facility: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Inlet 1 (Upstream to Baghouse)

Test Data	Units	Source Test Results			Average			
		Run 1	Run 2	Run 3				
Run Number	--							
Test Date	mm/dd/yy	05/21/19	05/21/19	05/22/19	--			
Test Time	hh:mm	12:10 - 14:30	15:10 - 17:40	08:30 - 10:40	--			
<b><u>Sampling Data*</u></b>								
Stack Temperature	°F	90	84	87	<b>87</b>			
Moisture	%	1.4	1.3	1.2	<b>1.3</b>			
Sample Volume	dscf	80	85	102	<b>89</b>			
Oxygen**	% v/v	20.1	20.1	20.2	<b>20.1</b>			
Carbon Dioxide**	% v/v	< 0.3	< 0.3	< 0.3	<b>&lt; 0.3</b>			
Gas Velocity	ft/min	5,534	5,695	5,778	<b>5,669</b>			
Stack Flow Rate	acfm	39,119	40,259	40,843	<b>40,074</b>			
Stack Flow Rate	dscfm	35,723	37,208	37,320	<b>36,750</b>			
<b><u>CARB Method 436</u></b>								
<b><u>CONCENTRATION</u></b>								
			<u>Total</u>	<u>Total</u>	<u>Total</u>			
Arsenic	ug/dscm	ND	0.44	ND	0.42	ND	0.34	< <b>0.40</b>
	ug/dscf	ND	0.012	ND	0.012	ND	0.010	< <b>0.011</b>
Cadmium	ug/dscm		0.483	ND	0.416	ND	0.345	<b>0.415</b>
	ug/dscf		0.014	ND	0.012	ND	0.010	<b>0.012</b>
Chromium	ug/dscm		13.4		3.41		20.2	<b>12.3</b>
	ug/dscf		0.379		0.097		0.571	<b>0.349</b>
Nickel	ug/dscm		9.09		4.87		14.7	<b>9.56</b>
	ug/dscf		0.257		0.138		0.417	<b>0.27</b>
<b><u>CARB Method 436</u></b>								
<b><u>MASS EMISSION RATE</u></b>								
			<u>Total</u>	<u>Total</u>	<u>Total</u>			
Arsenic	lb/hr	ND	5.88E-05	ND	5.80E-05	ND	4.82E-05	< <b>5.50E-05</b>
Cadmium	lb/hr		6.47E-05	ND	5.80E-05	ND	4.82E-05	<b>5.69E-05</b>
Chromium	lb/hr		1.79E-03		4.75E-04		2.82E-03	<b>1.70E-03</b>
Nickel	lb/hr		1.22E-03		6.78E-04		2.06E-03	<b>1.32E-03</b>

Notes:  
 \* Performed during isokinetic sampling (e.g. CARB Method 436).  
 \*\* Measured via SCAQMD Method 10.1.  
 ND or "<" - Not detected, reporting limit reported.

**TABLE 6-8. TEST RESULTS  
CARB 425 (Hexavalent & Total Chromium)**

Facility: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet 2 (Upstream to Baghouse)

TEST DATA	UNITS	TEST RESULTS			AVERAGE
		Run 1	Run 2	Run 3	
Run Number	-				
Test Date	mm/dd/yy	5/22/19	5/22/19	5/23/19	--
Test Time	hh:mm	11:50 - 14:12	14:38 - 16:50	8:25 - 10:42	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	91	85	81	<b>86</b>
Moisture	%	1.4	1.5	1.5	<b>1.5</b>
Sample Volume	dscf	102.2	105.0	105.0	<b>104.1</b>
Oxygen**	% v/v	20.2	20.2	19.9	<b>20.1</b>
Carbon Dioxide**	% v/v	0.30	0.30	0.30	<b>0.30</b>
Gas Velocity	ft/min	5,774.9	5,873.0	5,815.4	<b>5,821</b>
Stack Flow Rate	acfm	40,820	41,514	41,106	<b>41,147</b>
Stack Flow Rate	dscfm	36,968	37,943	37,953	<b>37,621</b>
<b><u>Total Catch (CARB 425)</u></b>					
Chromium VI	ug	4.30	0.52	3.04	<b>2.62</b>
Total Chromium	ug	13.7	5.1	21.7	<b>13.5</b>
<b><u>Concentration (CARB 425)</u></b>					
Chromium VI	ug/dscm	1.49	0.17	1.02	<b>0.89</b>
	ug/dscf	0.042	0.005	0.029	<b>0.025</b>
Total Chromium	ug/dscm	4.73	1.72	7.30	<b>4.58</b>
	ug/dscf	0.13	0.05	0.21	<b>0.13</b>
<b><u>Mass Emissions (CARB 425)</u></b>					
Chromium VI	ug/hr	93299	11274	65907	<b>56827</b>
Chromium VI	mg/hr	93.3	11.3	65.9	<b>56.8</b>
Chromium VI	lb/hr	2.1E-04	2.5E-05	1.5E-04	<b>1.25E-04</b>
Total Chromium	ug/hr	297255	110574	470457	<b>292762</b>
Total Chromium	mg/hr	297.26	110.57	470.46	<b>292.8</b>
Total Chromium	lb/hr	6.6E-04	2.4E-04	1.0E-03	<b>6.45E-04</b>

Notes:

\* Performed during isokinetic sampling by CARB 425.

\*\*O2/CO2 was measured via SCAQMD Method 10.1 by GC.

**TABLE 6-9. TEST RESULTS  
SCAQMD Method 5.1 (Particulate Matter)**

**Facility: AQMD Facility A**

**City: ██████████ CA**

**Source: Baghouse**

**Location: Inlet 1 (Upstream to Baghouse)**

Run Number	1	
Run Date	05/23/19	
Run Start Time	11:20	
Run Stop Time	13:36	
<b>Test Train Parameters</b>		<b>AVERAGE</b>
Volume of Dry Gas Sample, SCF*	100.62	100.62
<b>Flue Gas Parameters</b>		
CO2, Percent By Volume, Dry**	< 0.30	< 0.30
O2, Percent By Volume, Dry**	19.90	19.90
Temperature, Degrees F	83.7	83.7
Moisture, %	1.84	1.84
Air Flow Rate, Wet ACFM	40,129	40,129
Air Flow Rate, Dry SCFM*	36,230	36,230
<b>Total Particulate</b>		
Catch, mg	16.27	16.27
Concentration, Gr/DSCF	0.002495	0.002495
Emission Rate, lb/hr	0.775	0.775

\* 60 Degrees F and 29.92 Inches of Mercury

\*\* O2/CO2 was sampled in Tedlar bag and analysed via SCAQMD Method 10.1 by GC.

## APPENDICES

**APPENDIX A**  
**GENERAL CALCULATIONS AND FORMULAE**



## GENERAL CALCULATIONS

Standard conditions: 29.92 in.Hg, 68 °F for CARB, 60°F for SCAQMD

Gas Moisture at standard conditions (scf):  $V_{WTR} = K2 * V_{COND}$   
 $K2 = 0.04707 @ 68 °F, 0.0464 @ 60 °F$

Sample volume at standard conditions (scf):  
 $V_{mstd} = K1 * V_{macf} * Y_m * (P_{bar} + dH/13.6) / (T_m + 460)$   
 $K1 = 17.64 @ 68 °F, 17.38 @ 60 °F$

Percent of water:  $\%H_2O = 100 * V_{mstd} / (V_{mstd} + V_{wtr})$

Dry molecular weight:  $M_d = (44 * \%CO_2 + 32 * \%O_2 + 28 * (\%N_2 + \%CO)) / 100$

Wet molecular weight:  $M_w = M_d * (1 - \%H_2O / 100) + 18 * (\%H_2O / 100)$

Stack gas pressure (In. Hg):  $P_{stk} = P_{bar} + P_{sta} / 13.6$

Average velocity head:  $Ave. dP = \{SQRT(dP)\}^2$

Stack gas velocity (fps):  $V = 85.49 * C_p * SQRT(dP) * SQRT((T_s + 460) / (P_{STK} * M_w))$

Percent of excess air:  $\%EXCA = 100 * (\%O_2 - 0.5\%CO) / (0.264(\%N_2 - (\%O_2 - 0.5\%CO)))$

Stack gas flow (scfm):  $Q_{STK} = 60(1 - \%H_2O / 100) * V * A * (528 / (T_s + 460)) * P_{stk} / 29.92$

Concentration at 3% O<sub>2</sub>:  $PPM @ 3\% O_2 = PPM_{measured} * 17.9 / (20.9 - \%O_2)$

Emissions lb/MMBtu:  
 $lb/MMBtu = PPM * 10^{-6} * (MW \text{ lb/lb-mole}) / SV \text{ Mole} * F_d * 20.9 / (20.9 - \%O_2)$

Emissions lb/hr:  
 $lb/hr = PPM * 10^{-6} * ((MW \text{ lb/lb-mole}) / SV) * F_d * FF * (1050 \text{ Btu/scf}) * 20.9 / (20.9 - \%O_2)$

Concentration (ug/dscm),  $C_i = M_i / V_{mStd} * 35.315$

Metals Mass Emission Rate (ug/hr),  $E_{i,m} = C_i * Q_{sdm} * 60,$

Metals Mass Emission Rate (lbs/hr) =  $E_i / 453.6 / 1000000$

DEFINITIONS

A:	Stack cross area, Square feet
Cp:	Pitot coefficient
@h:	Orifice Pressure, In. H2O
MW:	Molecular weight
Md:	Dry molecular weight of flue gas
Mw:	Wet molecular weight of flue gas
Pbar:	Barometric pressure, In. Hg
Psta:	Static Pressure, In. H2O
Pstk:	Stack pressure, In, Hg
P:	Stack differential pressure, In. H2O
Qstk:	Stack gas flow, scfm
Tm:	Meter temperature, F
Ts:	Stack gas temperature, F
Vcond:	Volume of water condensation, ml
Vm:	Meter volume, acf
Vmstd:	Sample gas at standard conditions, scf
Vwtr:	Water vapor volume, scf
Ym:	Meter correction factor
SV:	Specific molar volume, 379.5 dscf/Lb.mole at 60F, or 385.3 dscf/Lb.mole at 68F
FF:	Fuel Flow Rate (SCF/HR)
Fd:	Dry Fuel Factor, for natural gas $F_d=8710 \text{ Dscf/MMBTU}$ at 68F.

**APPENDIX B**  
**APPROVALS AND CERTIFICATIONS**

**APPENDIX B1**  
**SCAQMD AND CARB TESTING APPROVALS**



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 · www.aqmd.gov



May 29, 2019

Mr. John W. Phillips  
Almega Environmental  
10602 Walker Street  
Cypress, CA 90630

Subject: LAP Approval Notice  
Reference # 93LA0827

Dear Mr. Phillips:

We completed our review of the renewal application you submitted for approval under the South Coast Air Quality Management District's Laboratory Approval Program (LAP). We are pleased to inform you that your firm is approved for the period beginning June 30, 2019, and ending June 30, 2020 for the following methods, subject to the requirements in the LAP Conditions For Approval Agreement and conditions listed in the attachment to this letter:

SCAQMD Methods 1-4	SCAQMD Method 7.1
SCAQMD Method 10.1	SCAQMD Rule 1121/ 1146.2 Protocols
SCAQMD Method 100.1	SCAQMD Rule 1420/1420.1/ 1420.2 – (Lead) Source Sampling
SCAQMD Method 25.1 (Sampling)	SCAQMD Rule 1420/1420.1/ 1420.2 – (Lead) Ambient Sampling
SCAQMD Method 25.1 (Analysis)	SCAQMD Rule 462 Testing
SCAQMD Method 25.3 (Analysis)	ASTM D6522-00/ USEPA CTM-030
SCAQMD Methods 5.1 and 6.1	

Thank you for participating in the LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Glenn Kasai. He may be reached by telephone at (909) 396-2271, or via e-mail at [gkasai@aqmd.gov](mailto:gkasai@aqmd.gov).

Sincerely,

Dipankar Sarkar  
Program Supervisor  
Source Test Engineering

GK/gk

190529 LapRenewal.doc

**ATTACHMENT**  
**Conditions For Almega Environmental's**  
**LAP Approval**

- 1) **Almega shall adhere to the following requirements when conducting portable analyzer tests using CTM-030 or ASTM D6522:**
  - a) **Deviations to CTM-030 or ASTM D6522 shall be documented in the Test Critique section of the test report;**
  - b) **The test report shall be formatted and organized in a manner consistent with the example portable analyzer test report, dated September 24, 2011, and the Source Test Manual, Chapter II; and,**
  - c) **NO<sub>2</sub> measurements may be quantified to 10% of the NO<sub>2</sub> span under the following conditions:**
    - **Calibrations shall be conducted per Sections 7.3 and 7.6 of CTM-030 at the span, mid-span (40-60% of span), low-span (10% of span), and zero level. The low-span calibration shall satisfy the requirements in Section 4.2 of CTM-030;**
    - **A linearity check shall be conducted once every five days using the low-span calibration gas; and,**
    - **If the measured NO<sub>2</sub> emission is less than 10% of the NO<sub>2</sub> span, it shall be reported as less than 10% of the span, and added to the NO emission to determine the total NO<sub>x</sub> concentration.**

State of California  
**Air Resources Board**  
Approved Independent Contractor  
**Almega Environmental & Technical Services, Incorporated**

This is to certify that the company listed above has been approved by the California Air Resources Board to conduct compliance testing pursuant to California Code of Regulations, Title 17, section 91207, through June 30, 2020, for the test methods listed below:



Catherine Dunwoody, Chief  
Monitoring and Laboratory Division

State of California  
**Air Resources Board**  
Approved Independent Contractor  
**Almega Environmental & Technical Services, Incorporated**

This is to certify that the company listed above has been approved by the California Air Resources Board to conduct compliance testing pursuant to California Code of Regulations, title 17, section 91207, through June 30, 2020, for the test method listed below:



Visible Emissions Evaluation

Catherine Dunwoody, Chief  
Monitoring and Laboratory Division



**APPENDIX B2**

**CERTIFICATION OF NO CONFLICT-OF-INTEREST**

### Certification of No Conflict-of-Interest

Almega Environmental & Technical Services  
10602 Walker Street  
Cypress, CA 90630

I certify that I am responsible for the testing operations of Almega and am authorized to sign this certificate on the Company's behalf.

Almega may conduct tests as an independent tester pursuant to SCAQMD Rule 304(k). I further certify that Almega has no conflict-of-interests and is not related or owned in any way to the company being tested.

Company being tested: Metal Melting Facility A

Facility Location: [REDACTED]

Facility ID: n/a

Signature: 

Name (printed or typed): Charles M. Figueroa

Title: Senior Project Manager

Date: September 4, 2019

**APPENDIX C**

**CARB METHOD 436 – MULTIPLE METAL EMISSIONS**

**APPENDIX C1**

**MULTIPLE METAL EMISSIONS – RESULTS AND CALCULATIONS**

Location: Baghouse Outlet

## TEST RESULTS

### CARB 436 (Multiple Metals)

Facility: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Outlet

Test Data	Units	Source Test Results			Average
Run Number	--	Run 1	Run 2	Run 3	
Test Date	mm/dd/yy	05/21/19	05/21/19	05/22/19	--
Test Time	hh:mm	12:10 - 14:33	15:10 - 17:40	08:30 - 10:48	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	85.0	86.2	86.6	<b>85.9</b>
Moisture	%	1.3	1.2	1.6	<b>1.4</b>
Sample Volume	dscf	95.0	95.0	91.3	<b>93.8</b>
Oxygen**	% v/v	20.9	20.9	20.9	<b>20.9</b>
Carbon Dioxide**	% v/v	< 0.04	< 0.04	< 0.04	<b>&lt; 0.04</b>
Stack Flow Rate	dscfm	46,646	48,131	48,166	<b>47,648</b>
<b><u>CARB Method 436</u></b>					
<b><u>CONCENTRATION</u></b>					
		<u>Total</u>	<u>Total</u>	<u>Total</u>	
Arsenic	ug/dscm	ND 0.372	ND 0.372	ND 0.387	< <b>0.377</b>
	ug/dscf	ND 0.0105	ND 0.0105	ND 0.0109	< <b>0.011</b>
Cadmium	ug/dscm	ND 0.372	ND 0.372	ND 0.387	< <b>0.377</b>
	ug/dscf	ND 0.0105	ND 0.0105	ND 0.0109	< <b>0.011</b>
Chromium	ug/dscm	14.7	RL 0.781	RL 0.812	<b>5.42</b>
	ug/dscf	0.416	RL 0.0221	RL 0.0230	<b>0.154</b>
Nickel	ug/dscm	2.27	RL 2.01	RL 2.09	<b>2.12</b>
	ug/dscf	0.0642	RL 0.0569	RL 0.0591	<b>0.0601</b>
<b><u>CARB Method 436</u></b>					
<b><u>MASS EMISSION RATE</u></b>					
		<u>Total</u>	<u>Total</u>	<u>Total</u>	
Arsenic	lbs/hr	ND 6.49E-05	ND 6.71E-05	ND 6.98E-05	< <b>6.72E-05</b>
Cadmium	lbs/hr	ND 6.49E-05	ND 6.71E-05	ND 6.98E-05	< <b>6.72E-05</b>
Chromium	lbs/hr	2.56E-03	RL 1.41E-04	RL 1.46E-04	<b>9.51E-04</b>
Nickel	lbs/hr	3.96E-04	RL 3.62E-04	RL 3.77E-04	<b>3.78E-04</b>

**Notes:**

\* Performed during isokinetic sampling (e.g. CARB Method 436).

\*\*SCAQMD Method 10.1 Tedlar bag sample was leaked, ambient level O2/CO2 was used for gas density calculations.

ND or "<" - Not detected, reporting limit reported.

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A      Test Date(s): 05/21-22/2019  
 City: ██████████ CA      Operator: CH/NC  
 Source: Baghouse      Entered by: TG  
 Location: Outlet      Checked by: CF

<b>Metals Catch, Mi</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	<b>Reagent Blank</b>
Fraction		Results		Results		Results		Results	Results
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.00
Cadmium	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.00
Chromium	ug		41.0		2.5		2.1		1.50
Nickel	ug		7.4		1.8		1.9		1.30

<b>Reagent Blank</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	
Fraction		Results		Results		Results		Results	
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Cadmium	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Chromium	ug		1.5		1.5		1.50		1.5
Nickel	ug		1.3		1.3		1.30		1.3

<b>Reagent Blank Corrected Values</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	<b>Reporting Limit</b>
Fraction		Results		Results		Results		Results	
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Cadmium	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Chromium	ug		39.5		<del>1.0</del>		<del>0.6</del>		2.10
Nickel	ug		6.1		<del>0.5</del>		<del>0.6</del>		5.40

These value should be considered as in the "noise of the sampling method" and will be reported as below the reporting limit  
 Reporting limit is based on three times the FB values.

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant:	AQMD Facility A	Test Date(s):	05/21-22/2019
City:	████████ CA	Operator:	CH/NC
Source:	Baghouse	Entered by:	TG
Location:	Outlet	Checked by:	CF

<b>Metals Catch, Mi</b>		<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Field Blank</b>
Fraction		Total	Total	Total	Total
Arsenic	ug	ND 1.0	ND 1.0	ND 1.0	ND 1.0
Cadmium	ug	ND 1.0	ND 1.0	ND 1.0	ND 1.0
Chromium	ug	B 39.5	RL 2.1	RL 2.1	0.7
Nickel	ug	B 6.1	RL 5.4	RL 5.4	1.8
<b>Metals Molecular Weight, MW</b>		<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	
Fraction		Total	Total	Total	
Arsenic	g/g-mole	74.92	74.92	74.92	
Cadmium	g/g-mole	112.41	112.41	112.41	
Chromium	g/g-mole	51.995	51.995	51.995	
Nickel	g/g-mole	58.69	58.69	58.69	
<b>Concentration (ug/dscm), Ci = Mi/VmStd *35.315e-3cf/dscm</b>					
Fraction		Total	Total	Total	
Arsenic	ug/dscm	ND 0.37	ND 0.37	ND 0.39	
Cadmium	ug/dscm	ND 0.3716	ND 0.3719	ND 0.3867	
Chromium	ug/dscm	14.677	RL 0.781	RL 0.812	
Nickel	ug/dscm	2.2666	RL 2.0084	RL 2.088	
<b>Metals Mass Emission Rate (ug/hr), Ei,m Ei,m = Ci*Qsdm*60</b>					
Fraction		Total	Total	Total	
Arsenic	ug/hr	ND 2.94E+04	ND 3.04E+04	ND 3.16E+04	
Cadmium	ug/hr	ND 2.94E+04	ND 3.04E+04	ND 3.16E+04	
Chromium	ug/hr	1.16E+06	RL 6.39E+04	RL 6.65E+04	
Nickel	ug/hr	1.80E+05	RL 1.64E+05	RL 1.71E+05	
<b>Metals Mass Emission Rate (lb/hr), Ei Ei = Ci*Qsdm*60/453600/1000</b>					
Fraction		Total	Total	Total	
Arsenic	lb/hr	ND 6.49E-05	ND 6.71E-05	ND 6.98E-05	
Cadmium	lb/hr	ND 6.49E-05	ND 6.71E-05	ND 6.98E-05	
Chromium	lb/hr	2.56E-03	RL 1.41E-04	RL 1.46E-04	
Nickel	lb/hr	3.96E-04	RL 3.62E-04	RL 3.77E-04	

Flags

ND or "<" - Not detected, reporting limit reported.

Reported at below the reporting limit

NDb - Reagent blank corrected result is less than RL. RL is substituted.



CARB METHOD 436 DATA AND CALCULATIONS



Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Outlet

Test Date(s): 05/21-22/2019  
 Operator: CH/NC  
 Entered by: TG  
 Checked by: CF

DATA ENTRY	Symbol	units	05/21/19 DATA	05/21/19 DATA	05/22/19 DATA
Run Number			Run 1	Run 2	Run 3
Stack Dimensions: Round Stack Diameter	Ds	in.			
Rectangular Stack, Length	L	in.			
Width	W	in.			
Nozzle Diameter	Dn	in.	0.528	0.528	0.513
Standard Temperature	Tstd	°F	68	68	68
Universal (molar) Gas Constant	Renglish	in. Hg-cu.ft/ °R-lbmole	21.85	21.85	21.85
Average Stack Temperature (measured)	Fs	°F	85.0	86.2	86.6
Average Meter Temperature (measured)	Fm	°F	82.2	79.2	73.5
Standard Pressure	Pstd	in.Hg	29.92	29.92	29.92
Barometric Pressure	Pbar	in.Hg	29.83	29.83	29.62
Stack Static Pressure	Pg	in.WC	-	-	-
Average Meter Orifice Head (Delta-H)	dH	in.WC	1.97	1.95	1.80
Average RMS Velocity Head (Delta-P)	dP	in.WC	-	-	-
Pitot Coefficient	Cp	—	-	-	-
Net Volume of Gas Metered	Vm	cu.ft.	93.894	93.291	89.431
Dry Gas Meter Calibration Factor (gamma, Y)	Y	—	1.0376	1.0376	1.0376
NET Sampling Time	min	min.	123	123	123
Stack Gas: Oxygen Content *	O2,m	%	20.9	20.9	20.9
Carbon Dioxide Content *	CO2,m	%	0.04	0.04	0.04
Total Impinger Gain	Ww	g	26.0	25.1	31.0
<b>CALCULATED DATA</b>					
Nozzle Area: $An = \pi/4 \cdot dn^2$	An	sq.in.	0.2190	0.2190	0.2067
Stack Area (round): $As = \pi/576 \cdot ds^2$	As	sq.ft.			
(rectangular): $As = L \cdot W/144$					
Absolute Stack Temperature: $Ts = Fs + 460$	Ts	°R	545.0	546.2	546.6
Absolute Meter Temperature: $Tm = Fm + 460$	Tm	°R	542.2	539.2	533.5
Standard Temperature: $Tstdr = Tstd + 460$	Tstdr	°R	528.0	528.0	528.0
Gas Sample Volume at Standard Conditions: $Vm(std) = Y \cdot (Vm/Tm) \cdot (Pbar + dH/13.6 \text{ in H}_2\text{O/in Hg}) \cdot (Tstdr/Pstd)$	VmStd	cu.ft.	95.040	94.952	91.327
Vol. of Water Vapor, $Vw(std) = Ww/453.59 \cdot Renglish/18 \cdot Tstdr / Pstd$	VwStd	cu. ft.	1.228	1.185	1.464
Moisture Fraction: $Bws = VwStd/(VmStd+VwStd)$	Bws	—	0.013	0.012	0.016
Stack Gas MW, Dry Basis: $Md = 0.32 \cdot O_{2,m} + 0.44 \cdot CO_{2,m} + 0.28 \cdot (100 - O_{2,m} - CO_{2,m})$	Md	g/mole	28.84	28.84	28.84
Stack Gas MW, Wet Basis: $Mw = Md \cdot (1 - Bws) + 18 \cdot Bws$	Mw	g/mole	28.70	28.71	28.67
Stack Pressure: $Ps = Pbar + Pg/13.6$	Ps	in.Hg	-	-	-
Stack Gas Velocity, measured $vs = 85.49 \cdot Cp \cdot \sqrt{(dP \cdot Ts / Ps / Mw)}$	vs	ft/s	-	-	-
$vm = 0.3048 \text{ m/ft} \cdot vs$	vsm	m/s	-	-	-
Stack Gas Volumetric Flow Rate: $Q = 60 \cdot vs \cdot As$	Q	acfm	-	-	-
Stack Gas Volumetric Flow Rate, corrected: $Qsd = Q \cdot (1 - Bws) \cdot (Ps / Ts) \cdot (Tstdr / Pstd)$	Qsd**	dscfm	46,646	48,131	48,166
$Qsdm = Qsd / 35.315$	Qsdm	dscmm	1,320.9	1,362.9	1,363.9
Isokinetic Sampling Rate: $I = 144 \cdot 100 \cdot Ts \cdot Vmstd \cdot Pstd / [60 \cdot Tstdr \cdot vs \cdot \min \cdot An \cdot Ps \cdot (1 - Bws)]$	I	%	-	-	-

\*SCAQMD Method 10.1 Tedlar bag sample was leaked, ambient level O2/CO2 was used for gas density calculations.

\*\*Baghouse outlet flow was assumed to be equal to the inlet. The inlet 1 outside and inlet 2 flows were added and utilized for outlet mass emission calculations.

CARB METHOD 436 DATA AND CALCULATIONS



ISOKINETIC CALCULATION ONLY

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Outlet

Test Date(s): 05/21-22/2019  
 Operator: CH/NC  
 Entered by: TG  
 Checked by: CF

DATA ENTRY	Symbol	units	05/21/19	05/21/19	05/22/19
			DATA	DATA	DATA
Run Number			Run 1	Run 2	Run 3
Stack Dimensions: Round Stack Diameter	Ds	in.			
Rectangular Stack, Length	L	in.	154	154	154
Width	W	in.	46	46	46
Nozzle Diameter	Dn	in.	0.528	0.528	0.513
Standard Temperature	Tstd	°F	68	68	68
Universal (molar) Gas Constant	Renglish	in. Hg-cu.ft/ °R-lbmole	21.85	21.85	21.85
Average Stack Temperature (measured)	Fs	°F	85.0	86.2	86.6
Average Meter Temperature (measured)	Fm	°F	82.2	79.2	73.5
Standard Pressure	Pstd	in.Hg	29.92	29.92	29.92
Barometric Pressure	Pbar	in.Hg	29.83	29.83	29.62
Stack Static Pressure	Pg	in.WC	N/A	N/A	N/A
Average Meter Orifice Head (Delta-H)	dH	in.WC	1.97	1.95	1.80
Average RMS Velocity Head (Delta-P)	dP	in.WC	0.0245	0.0245	0.0256
Pitot Coefficient	Cp	—	0.84	0.84	0.84
Net Volume of Gas Metered	Vm	cu.ft.	93.894	93.291	89.431
Dry Gas Meter Calibration Factor (gamma, Y)	Y	—	1.0376	1.0376	1.0376
NET Sampling Time	min	min.	123	123	123
Stack Gas: Oxygen Content *	O2,m	%	20.9	20.9	20.9
Carbon Dioxide Content *	CO2,m	%	0.04	0.04	0.04
Total Impinger Gain	Ww	g	26.0	25.1	31.0
<b>CALCULATED DATA</b>					
Nozzle Area: $An = \pi/4 \cdot dn^2$	An	sq.in.	0.2190	0.2190	0.2067
Stack Area (round): $As = \pi/576 \cdot ds^2$	As	sq.ft.			
(rectangular): $As = L \cdot W/144 (x2)$			98.389	98.389	98.389
Absolute Stack Temperature: $Ts = Fs+460$	Ts	°R	545.0	546.2	546.6
Absolute Meter Temperature: $Tm = Fm+460$	Tm	°R	542.2	539.2	533.5
Standard Temperature: $Tstdr = Tstd+460$	Tstdr	°R	528.0	528.0	528.0
Gas Sample Volume at Standard Conditions: $Vm(std) = Y \cdot (Vm/Tm) \cdot (Pbar + dH/13.6 \text{ in H}_2\text{O/in Hg}) \cdot (Tstdr/Pstd)$	VmStd	cu.ft.	95.040	94.952	91.327
Vol. of Water Vapor, $Vw(std) = Ww/453.59 \cdot Renglish/18 \cdot Tstdr / Pstd$	VwStd	cu. ft.	1.228	1.185	1.464
Moisture Fraction: $Bws = VwStd/(VmStd+VwStd)$	Bws	—	0.013	0.012	0.016
Stack Gas MW, Dry Basis: $Md = 0.32 \cdot O_{2,m} + 0.44 \cdot CO_{2,m} + 0.28 \cdot (100 - O_{2,m} - CO_{2,m})$	Md	g/mole	28.84	28.84	28.84
Stack Gas MW, Wet Basis: $Mw = Md \cdot (1 - Bws) + 18 \cdot Bws$	Mw	g/mole	28.70	28.71	28.67
Stack Pressure: $Ps = Pbar + Pg/13.6$	Ps	in.Hg	29.83	29.83	29.62
Stack Gas Velocity, measured $vs = 85.49 \cdot Cp \cdot \sqrt{(dP \cdot Ts / Ps / Mw)}$ $vm = 0.3048 \text{ m/ft} \cdot vs$	vs	ft/s	8.97	8.98	9.22
	vsm	m/s	2.73	2.74	2.81
Stack Gas Volumetric Flow Rate: $Q = 60 \cdot vs \cdot As$	Q	acfm	52,939	52,991	54,418
Stack Gas Volumetric Flow Rate, corrected: $Qsd = Q \cdot (1 - Bws) \cdot (Ps / Ts) \cdot (Tstdr / Pstd)$ $Qsdm = Qsd / 35.315$	Qsd**	dscfm	50,481	50,445	51,215
	Qsdm	dscmm	46,646	48,131	48,166
			1,320.9	1,362.9	1,363.9
Isokinetic Sampling Rate: $I = 144 \cdot 100 \cdot Ts \cdot Vmstd \cdot Pstd / [60 \cdot Tstdr \cdot vs \cdot \min \cdot An \cdot Ps \cdot (1 - Bws)]$	I	%	99.0	99.0	99.4
			based on estimated dP		

Flow Rate - Estimated (based on preflow calculation and back calculated dP)	50,481	50,445	51,215
Flow Rate based on sum of two inlet flows (as measured during test)	46,646	48,131	48,166
Flow - Percent Difference	108%	105%	106%
Corrected isokinetic sampling rate based on actual flows	107%	104%	106%

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Outlet

dP based on inlet pre flows Back-calculated for the this outlet location
--

Run No.: 1  
 Test Date: 05/21/19  
 Times: 12:10 - 14:33

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	72	8.5	0.0245	0.1565	2.01	80	80
2	80	8.9	0.0245	0.1565	1.98	80	80
3	92	9.6	0.0245	0.1565	1.94	80	80
4	84	9.2	0.0245	0.1565	1.97	81	81
5	81	9.0	0.0245	0.1565	1.98	82	82
6	91	9.5	0.0245	0.1565	1.95	83	83
7	100	10.0	0.0245	0.1565	1.92	83	83
8	90	9.5	0.0245	0.1565	1.96	84	84
9	84	9.2	0.0245	0.1565	1.98	84	84
10	82	9.1	0.0245	0.1565	1.99	85	85
11	84	9.2	0.0245	0.1565	1.98	85	85
12	86	9.3	0.0245	0.1565	1.98	86	86
B-1	78	8.8	0.0245	0.1565	1.98	79	79
2	82	9.1	0.0245	0.1565	1.97	79	79
3	87	9.3	0.0245	0.1565	1.95	80	80
4	85	9.2	0.0245	0.1565	1.97	81	81
5	83	9.1	0.0245	0.1565	1.98	82	82
6	86	9.3	0.0245	0.1565	1.97	82	82
7	90	9.5	0.0245	0.1565	1.95	83	83
8	84	9.2	0.0245	0.1565	1.98	84	84
9	86	9.3	0.0245	0.1565	1.97	84	84
<b>Average:</b>	<b>85.0</b>		<b>0.0245</b>		<b>1.97</b>		<b>82.2</b>

DGM Reading (cu.ft.):	Final-1:	687.957
	Initial-1:	642.123
	Final-2:	736.394
	Initial-2:	688.334
	Final-3:	
	Initial-3:	
	Final-4:	
	Initial-4:	
	Final-5:	
	Initial-5:	
	Volume:	<b>93.894</b>

Impinger Weight (g):	#1 Final:	778.1
	#1 Initial:	776.8
	#2 Final:	632.5
	#2 Initial:	625.0
	#3 Final:	629.2
	#3 Initial:	627.7
	#4 Final:	927.0
	#4 Initial:	911.3
	#5 Final:	
	#5 Initial:	
	#6 Final:	
	#6 Initial:	
	#7 Final:	
	#7 Initial:	
	#8 Final:	
	#8 Initial:	
<b>Total wt of impingers:</b>		<b>26.0</b>

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Outlet

dP based on inlet pre flows  
 Back-calculated for the  
 this outlet location

Run No.: 2  
 Test Date: 05/21/19  
 Times: 15:10 - 17:40

point	Stack Temp (°F)		Velocity Head (in. WC)		dH (in. WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	91	9.5	0.0245	0.1565	1.93	76	76
2	87	9.3	0.0245	0.1565	1.95	78	78
3	84	9.2	0.0245	0.1565	1.96	78	78
4	89	9.4	0.0245	0.1565	1.94	79	79
5	86	9.3	0.0245	0.1565	1.96	80	80
6	83	9.1	0.0245	0.1565	1.97	80	80
7	87	9.3	0.0245	0.1565	1.96	81	81
8	89	9.4	0.0245	0.1565	1.95	82	82
9	85	9.2	0.0245	0.1565	1.97	82	82
B-1	87	9.3	0.0245	0.1565	1.94	76	76
2	89	9.4	0.0245	0.1565	1.93	76	76
3	85	9.2	0.0245	0.1565	1.95	77	77
4	82	9.1	0.0245	0.1565	1.97	78	78
5	87	9.3	0.0245	0.1565	1.95	78	78
6	88	9.4	0.0245	0.1565	1.95	79	79
7	85	9.2	0.0245	0.1565	1.96	80	80
8	82	9.1	0.0245	0.1565	1.97	80	80
9	87	9.3	0.0245	0.1565	1.95	80	80
10	86	9.3	0.0245	0.1565	1.96	81	81
11	82	9.1	0.0245	0.1565	1.98	81	81
12	89	9.4	0.0245	0.1565	1.95	82	82
<b>Average:</b>	<b>86.2</b>		<b>0.0245</b>		<b>1.95</b>		<b>79.2</b>

DGM Reading (cu.ft.):	Final-1:	784.771
	Initial-1:	736.990
	Final-2:	830.792
	Initial-2:	785.282
	Final-3:	
	Initial-3:	
	Final-4:	
	Initial-4:	
	Final-5:	
	Initial-5:	
	Volume:	<b>93.291</b>

Impinger Weight (g):	#1 Final:	730.5
	#1 Initial:	736.2
	#2 Final:	756.7
	#2 Initial:	747.5
	#3 Final:	628.3
	#3 Initial:	625.9
	#4 Final:	871.4
	#4 Initial:	852.2
	#5 Final:	
	#5 Initial:	
	#6 Final:	
	#6 Initial:	
	#7 Final:	
	#7 Initial:	
	#8 Final:	
	#8 Initial:	
<b>Total wt of impingers:</b>		<b>25.1</b>

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Outlet

dP based on inlet pre flows Back-calculated for the this outlet location
--

Run No.: 3  
 Test Date: 05/22/19  
 Times: 08:30 - 10:48

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	76	8.7	0.0256	0.1600	1.81	64	64
2	84	9.2	0.0256	0.1600	1.79	65	65
3	87	9.3	0.0256	0.1600	1.78	66	66
4	89	9.4	0.0256	0.1600	1.78	67	67
5	90	9.5	0.0256	0.1600	1.78	69	69
6	86	9.3	0.0256	0.1600	1.80	71	71
7	92	9.6	0.0256	0.1600	1.79	72	72
8	87	9.3	0.0256	0.1600	1.81	74	74
9	84	9.2	0.0256	0.1600	1.82	75	75
10	89	9.4	0.0256	0.1600	1.81	76	76
11	85	9.2	0.0256	0.1600	1.83	77	77
12	84	9.2	0.0256	0.1600	1.83	77	77
B-1	86	9.3	0.0256	0.1600	1.80	73	73
2	91	9.5	0.0256	0.1600	1.79	74	74
3	88	9.4	0.0256	0.1600	1.80	75	75
4	93	9.6	0.0256	0.1600	1.79	76	76
5	87	9.3	0.0256	0.1600	1.81	77	77
6	84	9.2	0.0256	0.1600	1.82	78	78
7	88	9.4	0.0256	0.1600	1.81	79	79
8	85	9.2	0.0256	0.1600	1.82	79	79
9	85	9.2	0.0256	0.1600	1.82	79	79
<b>Average:</b>	<b>86.6</b>		<b>0.0256</b>		<b>1.80</b>		<b>73.5</b>

DGM Reading (cu.ft.):	Final-1:	875.022
	Initial-1:	831.607
	Final-2:	921.550
	Initial-2:	875.534
	Final-3:	
	Initial-3:	
	Final-4:	
	Initial-4:	
	Final-5:	
	Initial-5:	
	Volume:	<b>89.431</b>

Impinger Weight (g):	#1 Final:	766.0
	#1 Initial:	776.0
	#2 Final:	638.9
	#2 Initial:	625.2
	#3 Final:	634.1
	#3 Initial:	628.8
	#4 Final:	902.0
	#4 Initial:	880.0
	#5 Final:	
	#5 Initial:	
	#6 Final:	
	#6 Initial:	
	#7 Final:	
	#7 Initial:	
	#8 Final:	
	#8 Initial:	
<b>Total wt of impingers:</b>		<b>31.0</b>

Location: Inlet 1 (Inside)

## TEST RESULTS CARB 436 (Multiple Metals)

Facility: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Test Data	Units	Source Test Results			Average
Run Number	--	Run 1	Run 2	Run 3	
Test Date	mm/dd/yy	05/21/19	05/21/19	05/22/19	--
Test Time	hh:mm	12:10 - 14:30	15:10 - 17:40	08:30 - 10:45	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	123.4	133.6	132.1	<b>129.7</b>
Moisture	%	1.4	1.4	1.1	<b>1.3</b>
Sample Volume	dscf	74.7	81.3	104.2	<b>86.7</b>
Oxygen**	% v/v	20.0	19.9	20.2	<b>20.0</b>
Carbon Dioxide**	% v/v	< 0.3	< 0.3	< 0.3	<b>&lt; 0.3</b>
Gas Velocity	ft/min	5,549	6,070	5,910	<b>5,843</b>
Stack Flow Rate	acfm	3,027	3,311	3,224	<b>3,187</b>
Stack Flow Rate	dscfm	2,599	2,795	2,716	<b>2,703</b>
<b><u>CARB Method 436</u></b>					
<b><u>CONCENTRATION</u></b>					
		<u>Total</u>	<u>Total</u>	<u>Total</u>	
Arsenic	ug/dscm	ND 0.47	ND 0.43	0.98	<b>0.63</b>
	ug/dscf	ND 0.013	ND 0.012	0.028	<b>0.018</b>
Cadmium	ug/dscm	ND 0.473	ND 0.435	0.339	<b>0.415</b>
	ug/dscf	ND 0.027	ND 0.025	0.019	<b>0.024</b>
Chromium	ug/dscm	103.3	17.2	233	<b>118</b>
	ug/dscf	2.93	0.49	6.61	<b>3.34</b>
Nickel	ug/dscm	27.3	2.61	43.6	<b>24.5</b>
	ug/dscf	0.772	0.074	1.235	<b>0.694</b>
<b><u>CARB Method 436</u></b>					
<b><u>MASS EMISSION RATE</u></b>					
		<u>Total</u>	<u>Total</u>	<u>Total</u>	
Arsenic	lb/hr	ND 4.60E-06	ND 4.55E-06	1.00E-05	<b>4.86E-06</b>
Cadmium	lb/hr	ND 4.60E-06	ND 4.55E-06	4.21E-06	<b>2.93E-06</b>
Chromium	lb/hr	1.01E-03	1.80E-04	2.37E-03	<b>1.19E-03</b>
Nickel	lb/hr	2.66E-04	2.73E-05	4.44E-04	<b>2.46E-04</b>

Notes:

\* Performed during isokinetic sampling (e.g. CARB Method 436).

\*\* Measured via SCAQMD Method 10.1.

ND or "<" - Not detected, reporting limit reported.

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A      Test Date(s): 05/21-22/2019  
 City: ██████████ CA      Operator: CH/NC  
 Source: Baghouse      Entered by: TG  
 Location: Inlet 1 (Inside)      Checked by: CF

<b>Metals Catch, Mi</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	<b>Reagent Blank</b>
Fraction		Results		Results		Results		Results	Results
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.00
Cadmium	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.00
Chromium	ug		220.0		41.0		690.0	2.2	1.50
Nickel	ug		59.0		7.3		130.0	3.1	1.30

<b>Reagent Blank</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	
Fraction		Results		Results		Results		Results	
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Cadmium	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Chromium	ug		1.5		1.5		1.50	1.5	
Nickel	ug		1.3		1.3		1.30	1.3	

<b>Reagent Blank Corrected Values</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	<b>Reporting Limit</b>
Fraction		Results		Results		Results		Results	
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Cadmium	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Chromium	ug		218.5		39.5		688.5	0.7	2.10
Nickel	ug		57.7		6.0		128.7	1.8	5.40

These value should be considered as in the "noise of the sampling method" and will be reported as below the reporting limit  
 Reporting limit is based on three times the FB values.



**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A Test Date(s): 05/21-22/19  
 City: ████████ CA Operator: T. Ta/NC  
 Source: Baghouse Entered by: TG  
 Location: Inlet 1 Furnace (Inside) Checked by: CF

<b>Metals Catch, Mi</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	<b>Reagent Blank</b>
Fraction		Total		Total		Total		Total	Total
Arsenic	ug	ND	1.0	ND	1.0		2.9	ND 1.00	ND 1.00
Cadmium	ug	ND	1.0	ND	1.0		1.0	ND 1.00	ND 1.00
Chromium	ug	B	218.5	B	39.5	B	688.5	2.2	1.50
Nickel	ug	B	57.7	B	6.0	B	128.7	3.1	1.30
<b>Metals Molecular Weight, MW</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>			
Fraction		Total		Total		Total			
Arsenic	g/g-mole		74.92		74.92		74.92		
Cadmium	g/g-mole		112.41		112.41		112.41		
Chromium	g/g-mole		51.995		51.995		51.995		
Nickel	g/g-mole		58.69		58.69		58.69		
<b>Concentration (ug/dscm), Ci = Mi/VmStd *35.315e-3cf/dscm</b>									
Fraction		Total		Total		Total			
Arsenic	ug/dscm	ND	0.47	ND	0.43		0.98		
Cadmium	ug/dscm	ND	0.4728	ND	0.4346		0.3390		
Chromium	ug/dscm		103.300		17.166		233.384		
Nickel	ug/dscm		27.2788		2.6075		43.626		
<b>Metals Mass Emission Rate (ug/hr), Ei,m Ei,m = Ci*Qsdm*60</b>									
Fraction		Total		Total		Total			
Arsenic	ug/hr	ND	2.09E+03	ND	2.06E+03		4.54E+03		
Cadmium	ug/hr	ND	2.09E+03	ND	2.06E+03		1.56E+03		
Chromium	ug/hr		4.56E+05		8.15E+04		1.08E+06		
Nickel	ug/hr		1.20E+05		1.24E+04		2.01E+05		
<b>Metals Mass Emission Rate (lb/hr), Ei Ei = Ci*Qsdm*60/453600/1000</b>									
Fraction		Total		Total		Total			
Arsenic	lb/hr	ND	4.60E-06	ND	4.55E-06		1.00E-05		
Cadmium	lb/hr	ND	4.60E-06	ND	4.55E-06		3.45E-06		
Chromium	lb/hr		1.01E-03		1.80E-04		2.37E-03		
Nickel	lb/hr		2.66E-04		2.73E-05		4.44E-04		

Flags  
 ND or "<" - Not detected, reporting limit reported.  
 B - Reagent blank corrected value.  
 NDb - Reagent blank corrected result is less than RL. RL is substituted.

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Test Date(s): 05/21-22/19  
 Operator: T. Ta/NC  
 Entered by: TG  
 Checked by: CF

DATA ENTRY	Symbol	units	05/21/19	05/21/19	05/22/19
			DATA	DATA	DATA
Run Number			Run 1	Run 2	Run 3
Stack Dimensions: Round Stack Diameter	Ds	in.	10.0	10.0	10.0
Rectangular Stack, Length	L	in.			
Width	W	in.			
Nozzle Diameter	Dn	in.	0.155	0.155	0.180
Standard Temperature	Tstd	°F	68	68	68
Universal (molar) Gas Constant	Renglish	in. Hg-cu.ft/ °R-lbmole	21.85	21.85	21.85
Average Stack Temperature (measured)	Fs	°F	123.4	133.6	132.1
Average Meter Temperature (measured)	Fm	°F	94.3	90.8	90.6
Standard Pressure	Pstd	in.Hg	29.92	29.92	29.92
Barometric Pressure	Pbar	in.Hg	29.83	29.83	29.62
Stack Static Pressure	Pg	in.WC	-14.1	-14.1	-14.3
Average Meter Orifice Head (Delta-H)	dH	in.WC	1.35	1.48	2.53
Average RMS Velocity Head (Delta-P)	dP	in.WC	2.35	2.76	2.61
Pitot Coefficient	Cp	—	0.84	0.84	0.84
Net Volume of Gas Metered	Vm	cu.ft.	76.302	82.465	106.146
Dry Gas Meter Calibration Factor (gamma, Y)	Y	—	1.0274	1.0274	1.0274
NET Sampling Time	min	min.	120	120	120
Stack Gas: Oxygen Content *	O2,m	%	20.0	19.9	20.2
Carbon Dioxide Content *	CO2,m	%	< 0.3	< 0.3	< 0.3
Total Impinger Gain	Ww	g	22.4	24.1	23.7
<b>CALCULATED DATA</b>					
Nozzle Area: $An = \pi/4 \cdot dn^2$	An	sq.in.	0.0189	0.0189	0.0254
Stack Area (round): $As = \pi/576 \cdot ds^2$ (rectangular): $As = L \cdot W/144$	As	sq.ft.	0.55	0.55	0.55
Absolute Stack Temperature: $Ts = Fs+460$	Ts	°R	583.4	593.6	592.1
Absolute Meter Temperature: $Tm = Fm+460$	Tm	°R	554.3	550.8	550.6
Standard Temperature: $Tstd = Tstd+460$	Tstd	°R	528.0	528.0	528.0
Gas Sample Volume at Standard Conditions: $Vm(std) = Y \cdot (Vm/Tm) \cdot (Pbar + dH/13.6 \text{ in H}_2\text{O/in Hg}) \cdot (Tstd/Pstd)$	VmStd	cu.ft.	74.698	81.263	104.182
Vol. of Water Vapor, $Vw(std) = Ww/453.59 \cdot Renglish/18 \cdot Tstd / Pstd$	VwStd	cu.ft.	1.058	1.138	1.119
Moisture Fraction: $Bws = VwStd/(VmStd+VwStd)$	Bws	—	0.014	0.014	0.011
Stack Gas MW, Dry Basis: $Md = 0.32 \cdot O_{2,m} + 0.44 \cdot CO_{2,m} + 0.28 \cdot (100 - O_{2,m} - CO_{2,m})$	Md	g/mole	28.85	28.84	28.86
Stack Gas MW, Wet Basis: $Mw = Md \cdot (1 - Bws) + 18 \cdot Bws$	Mw	g/mole	28.70	28.69	28.74
Stack Pressure: $Ps = Pbar + Pg/13.6$	Ps	in.Hg	28.79	28.79	28.57
Stack Gas Velocity, measured $vs = 85.49 \cdot Cp \cdot \sqrt{(dP \cdot Ts / Ps / Mw)}$ $vm = 0.3048 \text{ m/ft} \cdot vs$	vs	ft/s	92.48	101.17	98.51
	vsm	m/s	28.19	30.84	30.02
Stack Gas Volumetric Flow Rate: $Q = 60 \cdot vs \cdot As$	Q	acfm	3,027	3,311	3,224
Stack Gas Volumetric Flow Rate, corrected: $Qsd = Q \cdot (1 - Bws) \cdot (Ps / Ts) \cdot (Tstd / Pstd)$ $Qsdm = Qsd / 35.315$	Qsd	dscfm	2,599	2,795	2,716
	Qsdm	dscmm	73.6	79.1	76.9
Isokinetic Sampling Rate: $I = 144 \cdot 100 \cdot Ts \cdot Vmstd \cdot Pstd / [60 \cdot Tstd \cdot vs \cdot \min \cdot An \cdot Ps \cdot (1 - Bws)]$	I	%	99.7	100.9	98.7

\* O2/CO2 is based on SCAQMD Method 10.1 analysis.

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Run No.: 1  
 Test Date: 05/21/19  
 Times: 12:10 - 14:30

point	Stack Temp (°F)		Velocity Head (in. WC)		dH (in. WC)	DGM Temperature (°F)		
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out	
A-1	107	10.3	2.50	1.5811	1.36	89	89	
2	109	10.4	2.70	1.6432	1.46	89	89	
3	100	10.0	2.70	1.6432	1.49	90	90	
4	100	10.0	2.60	1.6125	1.44	90	90	
5	128	11.3	3.00	1.7321	1.58	92	92	
6	144	12.0	3.20	1.7889	1.65	93	93	
7	149	12.2	3.50	1.8708	1.79	93	93	
8	134	11.6	3.80	1.9494	1.99	94	94	
9	113	10.6	3.10	1.7607	1.69	95	95	
10	126	11.2	3.50	1.8708	1.87	96	96	
11	134	11.6	3.60	1.8974	1.89	96	96	
12	128	11.3	3.10	1.7607	1.65	97	97	
B-1	145	12.0	3.30	1.8166	1.70	93	93	
2	128	11.3	3.40	1.8439	1.80	94	94	
3	120	11.0	3.40	1.8439	1.83	95	95	
4	146	12.1	2.70	1.6432	1.39	95	95	
5	127	11.3	3.10	1.7607	1.65	96	96	
6	133	11.5	2.90	1.7029	1.53	97	97	
7	128	11.3	1.80	1.3416	1.03	97	97	
8	135	11.6	1.10	1.0488	0.62	97	97	
9	105	10.2	0.43	0.6557	0.26	97	97	
10	118	10.9	0.39	0.62	0.23	97	97	
11	108	10.4	0.45	0.67	0.27	96	96	
12	107	10.3	0.52	0.72	0.31	95	95	
<b>Average:</b>	<b>123.4</b>		<b>2.3491</b>		<b>1.35</b>		<b>94.3</b>	
DGM Reading (cu.ft.):			Final-1:	349.415	Impinger Weight (g):		#1 Final:	760.0
			Initial-1:	273.113			#1 Initial:	757.2
			Final-2:				#2 Final:	604.8
			Initial-2:				#2 Initial:	598.7
			Final-3:				#3 Final:	660.3
			Initial-3:				#3 Initial:	659.5
			Final-4:				#4 Final:	872.9
			Initial-4:				#4 Initial:	860.2
			Final-5:				#5 Final:	
			Initial-5:				#5 Initial:	
			Volume:	<b>76.302</b>			#6 Final:	
							#6 Initial:	
							#7 Final:	
							#7 Initial:	
							#8 Final:	
							#8 Initial:	
						<b>Total wt of impingers:</b>	<b>22.4</b>	

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Run No.: 2  
 Test Date: 05/21/19  
 Times: 15:10 - 17:40

point	Stack Temp (°F)		Velocity Head (in. WC)		dH (in. WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	157	12.5	2.70	1.6432	1.35	88	88
2	152	12.3	2.80	1.6733	1.41	89	89
3	152	12.3	2.70	1.6432	1.36	90	90
4	150	12.2	2.80	1.6733	1.42	91	91
5	151	12.3	3.30	1.8166	1.67	91	91
6	149	12.2	3.30	1.8166	1.68	92	92
7	155	12.4	3.90	1.9748	1.97	92	92
8	149	12.2	4.10	2.0248	2.09	93	93
9	150	12.2	3.90	1.9748	1.99	93	93
10	135	11.6	4.00	2.0000	2.09	93	93
11	116	10.8	3.40	1.8439	1.83	93	93
12	114	10.7	3.00	1.7321	1.62	93	93
B-1	134	11.6	3.40	1.8439	1.76	87	87
2	133	11.5	3.30	1.8166	1.71	88	88
3	129	11.4	3.30	1.8166	1.73	89	89
4	128	11.3	3.20	1.7889	1.68	89	89
5	127	11.3	2.90	1.7029	1.53	90	90
6	125	11.2	3.00	1.7321	1.59	91	91
7	119	10.9	1.60	1.2649	0.86	92	92
8	128	11.3	2.30	1.5166	1.21	91	91
9	117	10.8	1.80	1.3416	0.97	92	92
10	118	10.9	1.40	1.18	0.75	91	91
11	108	10.4	1.20	1.10	0.65	91	91
12	121	11.0	0.94	0.97	0.50	91	91
<b>Average:</b>	<b>133.6</b>		<b>2.7624</b>		<b>1.48</b>		<b>90.8</b>

DGM Reading (cu.ft.):	Final-1:	432.385	Impinger Weight (g):	#1 Final:	762.8
	Initial-1:	349.920		#1 Initial:	763.0
	Final-2:			#2 Final:	768.9
	Initial-2:			#2 Initial:	760.6
	Final-3:			#3 Final:	636.8
	Initial-3:			#3 Initial:	635.7
	Final-4:			#4 Final:	889.4
	Initial-4:			#4 Initial:	874.5
	Final-5:			#5 Final:	
	Initial-5:			#5 Initial:	
	Volume:	<b>82.465</b>		#6 Final:	
				#6 Initial:	
				#7 Final:	
				#7 Initial:	
				#8 Final:	
				#8 Initial:	
			<b>Total wt of impingers:</b>		<b>24.1</b>

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Run No.: 3  
 Test Date: 05/22/19  
 Times: 08:30 - 10:45

point	Stack Temp (°F)		Velocity Head (in. WC)		dH (in. WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	165	12.8	2.50	1.5811	2.21	80	80
2	134	11.6	2.60	1.6125	2.42	82	82
3	171	13.1	2.50	1.5811	2.20	84	84
4	180	13.4	2.60	1.6125	2.27	86	86
5	147	12.1	2.70	1.6432	2.49	87	87
6	131	11.4	3.00	1.7321	2.85	89	89
7	146	12.1	3.10	1.7607	2.87	90	90
8	110	10.5	3.80	1.9494	3.75	91	91
9	110	10.5	3.40	1.8439	3.37	93	93
10	104	10.2	3.00	1.7321	3.00	93	93
11	93	9.6	2.20	1.4832	2.25	93	93
12	126	11.2	2.00	1.4142	1.93	93	93
B-1	119	10.9	3.70	1.9235	3.59	90	90
2	126	11.2	3.50	1.8708	3.36	91	91
3	155	12.4	3.30	1.8166	3.03	92	92
4	164	12.8	3.20	1.7889	2.89	92	92
5	152	12.3	3.00	1.7321	2.77	93	93
6	118	10.9	3.40	1.8439	3.32	93	93
7	124	11.1	2.20	1.4832	2.13	93	93
8	152	12.3	2.30	1.5166	2.12	93	93
9	109	10.4	1.70	1.3038	1.69	94	94
10	119	10.9	1.60	1.26	1.56	94	94
11	124	11.1	1.40	1.18	1.36	94	94
12	114	10.7	1.20	1.10	1.18	94	94
<b>Average:</b>	<b>132.1</b>		<b>2.6094</b>		<b>2.53</b>		<b>90.6</b>

DGM Reading (cu.ft.):	Final-1:	539.086	Impinger Weight (g):	#1 Final:	738.7
	Initial-1:	432.940		#1 Initial:	756.7
	Final-2:			#2 Final:	615.5
	Initial-2:			#2 Initial:	602.5
	Final-3:			#3 Final:	665.5
	Initial-3:			#3 Initial:	661.4
	Final-4:			#4 Final:	886.7
	Initial-4:			#4 Initial:	862.1
	Final-5:			#5 Final:	
	Initial-5:			#5 Initial:	
	Volume:	<b>106.146</b>		#6 Final:	
				#6 Initial:	
				#7 Final:	
				#7 Initial:	
				#8 Final:	
				#8 Initial:	
			<b>Total wt of impingers:</b>		<b>23.7</b>

Location: Inlet 2 (Upstream to Baghouse)

## TEST RESULTS CARB 436 (Multiple Metals)

Facility: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Inlet (Upstream to Baghouse)

Test Data	Units	Source Test Results			Average
Run Number	--	Run 1	Run 2	Run 3	
Test Date	mm/dd/yy	05/21/19	05/21/19	05/22/19	--
Test Time	hh:mm	12:10 - 14:30	15:10 - 17:40	08:30 - 10:40	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	90	84	87	<b>87</b>
Moisture	%	1.4	1.3	1.2	<b>1.3</b>
Sample Volume	dscf	80	85	102	<b>89</b>
Oxygen**	% v/v	20.1	20.1	20.2	<b>20.1</b>
Carbon Dioxide**	% v/v	< 0.3	< 0.3	< 0.3	<b>&lt; 0.3</b>
Gas Velocity	ft/min	5,534	5,695	5,778	<b>5,669</b>
Stack Flow Rate	acfm	39,119	40,259	40,843	<b>40,074</b>
Stack Flow Rate	dscfm	35,723	37,208	37,320	<b>36,750</b>
<b><u>CARB Method 436</u></b>					
<b><u>CONCENTRATION</u></b>					
		<u>Total</u>	<u>Total</u>	<u>Total</u>	
Arsenic	ug/dscm	ND 0.44	ND 0.42	ND 0.34	< <b>0.40</b>
	ug/dscf	ND 0.012	ND 0.012	ND 0.010	< <b>0.011</b>
Cadmium	ug/dscm	0.483	ND 0.416	ND 0.345	<b>0.415</b>
	ug/dscf	0.014	ND 0.012	ND 0.010	<b>0.012</b>
Chromium	ug/dscm	13.4	3.41	20.2	<b>12.3</b>
	ug/dscf	0.379	0.097	0.571	<b>0.349</b>
Nickel	ug/dscm	9.09	4.87	14.7	<b>9.56</b>
	ug/dscf	0.257	0.138	0.417	<b>0.27</b>
<b><u>CARB Method 436</u></b>					
<b><u>MASS EMISSION RATE</u></b>					
		<u>Total</u>	<u>Total</u>	<u>Total</u>	
Arsenic	lb/hr	ND 5.88E-05	ND 5.80E-05	ND 4.82E-05	< <b>5.50E-05</b>
Cadmium	lb/hr	6.47E-05	ND 5.80E-05	ND 4.82E-05	<b>5.69E-05</b>
Chromium	lb/hr	1.79E-03	4.75E-04	2.82E-03	<b>1.70E-03</b>
Nickel	lb/hr	1.22E-03	6.78E-04	2.06E-03	<b>1.32E-03</b>

Notes:

\* Performed during isokinetic sampling (e.g. CARB Method 436).

\*\* Measured via SCAQMD Method 10.1.

ND or "<" - Not detected, reporting limit reported.

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A      Test Date(s): 05/21-22/2019  
 City: ██████████ CA      Operator: CH/NC  
 Source: Baghouse      Entered by: TG  
 Location: Inlet 2      Checked by: CF

<b>Metals Catch, Mi</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	<b>Reagent Blank</b>
Fraction		Results		Results		Results		Results	Results
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.00
Cadmium	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.00
Chromium	ug		32.0		9.7		60.0	2.2	1.50
Nickel	ug		22.0		13.0		44.0	3.1	1.30

<b>Reagent Blank</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	
Fraction		Results		Results		Results		Results	
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Cadmium	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Chromium	ug		1.5		1.5		1.50	1.5	
Nickel	ug		1.3		1.3		1.30	1.3	

<b>Reagent Blank Corrected Values</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	<b>Reporting Limit</b>
Fraction		Results		Results		Results		Results	
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Cadmium	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.0
Chromium	ug		30.5		8.2		58.5	0.7	2.10
Nickel	ug		20.7		11.7		42.7	1.8	5.40

These value should be considered as in the "noise of the sampling method" and will be reported as below the reporting limit  
 Reporting limit is based on three times the FB values.



**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A      Test Date(s): 5/21-22/2019  
 City: ██████████ CA      Operator: MN/NC  
 Source: Baghouse      Entered by: TG  
 Location: Inlet (Upstream to Bagh Checked by: CF

<b>Metals Catch, Mi</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>		<b>Field Blank</b>	<b>Reagent Blank</b>
Fraction		Total		Total		Total		Total	Total
Arsenic	ug	ND	1.0	ND	1.0	ND	1.0	ND	1.00
Cadmium	ug		1.1	ND	1.0	ND	1.0	ND	1.00
Chromium	ug	B	30.5	B	8.2	B	58.5	2.2	1.50
Nickel	ug	B	20.7	B	11.7	B	42.7	3.1	1.30
<b>Metals Molecular Weight, MW</b>		<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>			
Fraction		Total		Total		Total			
Arsenic	g/g-mole	74.92		74.92		74.92			
Cadmium	g/g-mole	112.41		112.41		112.41			
Chromium	g/g-mole	51.995		51.995		51.995			
Nickel	g/g-mole	58.69		58.69		58.69			
<b>Concentration (ug/dscm), Ci = Mi/VmStd *35.315e-3cf/dscm</b>									
Fraction		Total		Total		Total			
Arsenic	ug/dscm	ND	0.44	ND	0.42	ND	0.34		
Cadmium	ug/dscm	0.4832		ND	0.4160	ND	0.3447		
Chromium	ug/dscm	13.398		3.411		20.165			
Nickel	ug/dscm	9.0930		4.8668		14.719			
<b>Metals Mass Emission Rate (ug/hr), Ei,m Ei,m = Ci*Qsdm*60</b>									
Fraction		Total		Total		Total			
Arsenic	ug/hr	ND	2.67E+04	ND	2.63E+04	ND	2.19E+04		
Cadmium	ug/hr	2.93E+04		ND	2.63E+04	ND	2.19E+04		
Chromium	ug/hr	8.13E+05		2.16E+05		1.28E+06			
Nickel	ug/hr	5.52E+05		3.08E+05		9.33E+05			
<b>Metals Mass Emission Rate (lb/hr), Ei Ei = Ci*Qsdm*60/453600/1000</b>									
Fraction		Total		Total		Total			
Arsenic	lb/hr	ND	5.88E-05	ND	5.80E-05	ND	4.82E-05		
Cadmium	lb/hr	6.47E-05		ND	5.80E-05	ND	4.82E-05		
Chromium	lb/hr	1.79E-03		4.75E-04		2.82E-03			
Nickel	lb/hr	1.22E-03		6.78E-04		2.06E-03			

Flags  
 ND or "<" - Not detected, reporting limit reported.  
 B - Reagent blank corrected value.  
 NDb - Reagent blank corrected result is less than RL. RL is substituted.

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Inlet (Upstream to Baghouse)

Test Date(s): 5/21-22/2019  
 Operator: MN/NC  
 Entered by: TG  
 Checked by: CF

DATA ENTRY	Symbol	units	05/21/19	05/21/19	05/22/19
			DATA	DATA	DATA
Run Number			Run 1	Run 2	Run 3
Stack Dimensions: Round Stack Diameter	Ds	in.	36.0	36.0	36.0
Rectangular Stack, Length	L	in.			
Width	W	in.			
Nozzle Diameter	Dn	in.	0.155	0.155	0.173
Standard Temperature	Tstd	°F	68	68	68
Universal (molar) Gas Constant	Renglish	in. Hg-cu.ft/ °R-lbmole	21.85	21.85	21.85
Average Stack Temperature (measured)	Fs	°F	90.2	84.3	86.7
Average Meter Temperature (measured)	Fm	°F	90.3	88.3	80.4
Standard Pressure	Pstd	in.Hg	29.92	29.92	29.92
Barometric Pressure	Pbar	in.Hg	29.83	29.83	29.62
Stack Static Pressure	Pg	in.WC	-13.0	-13.0	-13.0
Average Meter Orifice Head (Delta-H)	dH	in.WC	1.59	1.61	2.53
Average RMS Velocity Head (Delta-P)	dP	in.WC	2.48	2.66	2.71
Pitot Coefficient	Cp	—	0.84	0.84	0.84
Net Volume of Gas Metered	Vm	cu.ft.	80.532	84.726	101.253
Dry Gas Meter Calibration Factor (gamma, Y)	Y	—	1.0395	1.0395	1.0395
NET Sampling Time	min	min.	120	120	120
Stack Gas: Oxygen Content *	O2,m	%	20.1	20.1	20.2
Carbon Dioxide Content *	CO2,m	%	< 0.3	< 0.3	< 0.3
Total Impinger Gain	Ww	g	24.1	23.1	27.4
<b>CALCULATED DATA</b>					
Nozzle Area: $An = \pi/4 * dn^2$	An	sq.in.	0.0189	0.0189	0.0235
Stack Area (round): $As = \pi/576 * ds^2$	As	sq.ft.	7.07	7.07	7.07
(rectangular): $As = L * W / 144$					
Absolute Stack Temperature: $Ts = Fs + 460$	Ts	°R	550.2	544.3	546.7
Absolute Meter Temperature: $Tm = Fm + 460$	Tm	°R	550.3	548.3	540.4
Standard Temperature: $Tstdr = Tstd + 460$	Tstdr	°R	528.0	528.0	528.0
Gas Sample Volume at Standard Conditions: $Vm(std) = Y * (Vm/Tm) * (Pbar + dH/13.6 \text{ in H}_2\text{O/in Hg}) * (Tstdr/Pstd)$	VmStd	cu.ft.	80.394	84.899	102.451
Vol. of Water Vapor, $Vw(std) = Ww/453.59 * Renglish/18 * Tstdr / Pstd$	VwStd	cu.ft.	1.138	1.091	1.294
Moisture Fraction: $Bws = VwStd / (VmStd + VwStd)$	Bws	—	0.014	0.013	0.012
Stack Gas MW, Dry Basis: $Md = 0.32 * O_{2,m} + 0.44 * CO_{2,m} + 0.28 * (100 - O_{2,m} - CO_{2,m})$	Md	g/mole	28.85	28.85	28.86
Stack Gas MW, Wet Basis: $Mw = Md * (1 - Bws) + 18 * Bws$	Mw	g/mole	28.70	28.71	28.72
Stack Pressure: $Ps = Pbar + Pg / 13.6$	Ps	in.Hg	28.87	28.87	28.66
Stack Gas Velocity, measured $vs = 85.49 * Cp * \sqrt{(dP * Ts / Ps / Mw)}$ $vm = 0.3048 \text{ m/ft} * vs$	vs	ft/s	92.24	94.92	96.30
	vsm	m/s	28.11	28.93	29.35
Stack Gas Volumetric Flow Rate: $Q = 60 * vs * As$	Q	acfm	39,119	40,259	40,843
Stack Gas Volumetric Flow Rate, corrected: $Qsd = Q * (1 - Bws) * (Ps / Ts) * (Tstdr / Pstd)$ $Qsdm = Qsd / 35.315$	Qsd	dscfm	35,723	37,208	37,320
	Qsdm	dscmm	1,011.6	1,053.6	1,056.8
Isokinetic Sampling Rate: $I = 144 * 100 * Ts * Vmstd * Pstd / [60 * Tstdr * vs * \min(An * Ps * (1 - Bws))]$	I	%	101.2	102.6	99.1

\* O2/CO2 is based on SCAQMD Method 10.1 analysis.

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet (Upstream to Baghouse)

Run No.: 1  
 Test Date: 05/21/19  
 Times: 12:10 - 14:30

point	Stack Temp (°F)		Velocity Head (in. WC)		dH (in. WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-12	92	9.6	2.10	1.4491	1.25		85
11	91	9.5	2.60	1.6125	1.55		87
10	91	9.5	3.20	1.7889	1.90		88
9	93	9.6	2.90	1.7029	1.75		89
8	90	9.5	2.70	1.6432	1.60		90
7	91	9.5	2.65	1.6279	1.60		91
6	90	9.5	2.60	1.6125	1.55		91
5	91	9.5	2.10	1.4491	1.25		92
4	92	9.6	1.95	1.3964	1.15		92
3	88	9.4	1.60	1.2649	0.95		92
2	87	9.3	2.40	1.5492	1.45		92
1	81	9.0	2.80	1.6733	1.65		92
B-12	89	9.4	2.40	1.5492	1.45		89
11	91	9.5	2.90	1.7029	1.75		89
10	90	9.5	3.10	1.7607	1.85		90
9	91	9.5	3.40	1.8439	2.00		91
8	91	9.5	2.80	1.6733	1.65		91
7	91	9.5	2.60	1.6125	1.55		91
6	91	9.5	2.80	1.6733	1.65		91
5	88	9.4	2.05	1.4318	2.05		91
4	89	9.4	2.00	1.4142	2.00		90
3	93	9.6	1.50	1.22	1.50		91
2	92	9.6	2.35	1.53	1.40		91
1	92	9.6	2.70	1.64	1.60		91
<b>Average:</b>	<b>90.2</b>		<b>2.4849</b>		<b>1.59</b>		<b>90.3</b>

DGM Reading (cu.ft.):	Final-1:	990.560	Impinger Weight (g):	#1 Final:	724.3
	Initial-1:	910.028		#1 Initial:	733.4
	Final-2:			#2 Final:	755.3
	Initial-2:			#2 Initial:	742.0
	Final-3:			#3 Final:	537.4
	Initial-3:			#3 Initial:	534.0
	Final-4:			#4 Final:	891.8
	Initial-4:			#4 Initial:	875.3
	Final-5:			#5 Final:	
	Initial-5:			#5 Initial:	
	Volume:	<b>80.532</b>		#6 Final:	
				#6 Initial:	
				#7 Final:	
				#7 Initial:	
				#8 Final:	
				#8 Initial:	
			<b>Total wt of impingers:</b>		<b>24.1</b>

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet (Upstream to Baghouse)

Run No.: 2  
 Test Date: 05/21/19  
 Times: 15:10 - 17:40

point	Stack Temp (°F)		Velocity Head (in. WC)		dH (in. WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-12	86	9.3	2.20	1.4832	1.30		85
11	86	9.3	2.40	1.5492	1.45		86
10	87	9.3	3.10	1.7607	1.85		87
9	87	9.3	3.00	1.7321	1.80		88
8	87	9.3	2.75	1.6583	1.65		89
7	87	9.3	3.10	1.7607	1.85		89
6	87	9.3	3.10	1.7607	1.85		90
5	86	9.3	2.60	1.6125	1.55		90
4	86	9.3	2.40	1.5492	1.45		91
3	86	9.3	2.80	1.6733	1.65		91
2	86	9.3	2.70	1.6432	1.60		91
1	84	9.2	2.30	1.5166	1.35		91
B-12	82	9.1	2.80	1.6733	1.65		86
11	82	9.1	2.70	1.6432	1.60		86
10	83	9.1	2.90	1.7029	1.75		87
9	82	9.1	2.90	1.7029	1.75		87
8	83	9.1	2.40	1.5492	1.45		88
7	83	9.1	3.00	1.7321	1.80		88
6	83	9.1	2.70	1.6432	1.60		88
5	83	9.1	2.40	1.5492	1.45		88
4	82	9.1	2.55	1.5969	1.50		88
3	82	9.1	2.30	1.52	1.35		88
2	82	9.1	2.65	1.63	1.60		88
1	82	9.1	2.30	1.52	1.70		88
<b>Average:</b>	<b>84.3</b>		<b>2.6614</b>		<b>1.61</b>		<b>88.3</b>

DGM Reading (cu.ft.):	Final-1:	1075.670	Impinger Weight (g):	#1 Final:	630.4
	Initial-1:	990.944		#1 Initial:	626.1
	Final-2:			#2 Final:	757.0
	Initial-2:			#2 Initial:	751.9
	Final-3:			#3 Final:	629.5
	Initial-3:			#3 Initial:	628.4
	Final-4:			#4 Final:	915.6
	Initial-4:			#4 Initial:	903.0
	Final-5:			#5 Final:	
	Initial-5:			#5 Initial:	
	Volume:	<b>84.726</b>		#6 Final:	
				#6 Initial:	
				#7 Final:	
				#7 Initial:	
				#8 Final:	
				#8 Initial:	
			<b>Total wt of impingers:</b>		<b>23.1</b>

**CARB METHOD 436 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet (Upstream to Baghouse)

Run No.: 3  
 Test Date: 05/22/19  
 Times: 08:30 - 10:40

point	Stack Temp (°F)		Velocity Head (in. WC)		dH (in. WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	83	9.1	2.90	1.7029	2.70		71
2	84	9.2	3.50	1.8708	3.25		73
3	87	9.3	3.40	1.8439	3.15		74
4	88	9.4	3.50	1.8708	3.25		76
5	86	9.3	2.90	1.7029	2.70		77
6	85	9.2	2.70	1.6432	2.50		77
7	84	9.2	2.65	1.6279	2.45		79
8	86	9.3	2.45	1.5652	2.25		80
9	87	9.3	2.00	1.4142	1.85		80
10	82	9.1	2.00	1.4142	1.85		80
11	83	9.1	2.30	1.5166	2.15		81
12	83	9.1	2.20	1.4832	2.05		81
B-1	85	9.2	2.60	1.6125	2.40		79
2	87	9.3	3.40	1.8439	3.15		81
3	89	9.4	3.30	1.8166	3.05		81
4	89	9.4	3.60	1.8974	3.35		83
5	88	9.4	3.00	1.7321	2.75		83
6	87	9.3	2.90	1.7029	2.70		83
7	91	9.5	2.70	1.6432	2.50		84
8	92	9.6	2.20	1.4832	2.05		84
9	91	9.5	1.70	1.3038	1.50		85
10	90	9.5	1.80	1.34	1.65		85
11	87	9.3	2.80	1.67	2.60		86
12	87	9.3	3.20	1.79	2.95		86
<b>Average:</b>	<b>86.7</b>		<b>2.7081</b>		<b>2.53</b>		<b>80.4</b>

DGM Reading (cu.ft.):	Final-1:	177.210	Impinger Weight (g):	#1 Final:	714.4
	Initial-1:	75.957		#1 Initial:	735.9
	Final-2:			#2 Final:	764.6
	Initial-2:			#2 Initial:	744.4
	Final-3:			#3 Final:	541.1
	Initial-3:			#3 Initial:	535.7
	Final-4:			#4 Final:	905.4
	Initial-4:			#4 Initial:	882.1
	Final-5:			#5 Final:	
	Initial-5:			#5 Initial:	
	Volume:	<b>101.253</b>		#6 Final:	
				#6 Initial:	
				#7 Final:	
				#7 Initial:	
				#8 Final:	
				#8 Initial:	
			<b>Total wt of impingers:</b>		<b>27.4</b>

**APPENDIX C2**  
**MULTIPLE METAL EMISSIONS – FIELD DATA**


Location: Baghouse Outlet

Sampling Access

The exhaust test location was accessed via a man lift for one side of the exhaust.

For the others side, the facility installed a platform with guardrails that extends from the roof to the exhaust stack.

146 inches divided by 4, and then by 2  
 36.50 Div 4  
 18.25 Div 2  
 54.75 Sum  
 60 minutes at 5 minutes a point



9 Points Roof Side

12 Points Lot Side



Run #:	R1A	Pilot ID:	47	Impinger #	Initial	Final	Net	Pilot Leak Check	
Date:	5-21-19	Pilot Coeff.:	.89	1	776.8	778.1		Initial:	
Client:	Facility A	Meter Box #:	A-6	2	625.0	632.5		Final:	
Unit:	Outlet	Meter @ Dh:	1.789	3	627.7	629.2		Meter Box Leak Check	
Operator:	CH	Meter Y:	1.0376	4	911.3	922.0		Rate	7HG
Stack Dia:	Area Source	TC #:	47	5				Initial:	22"
Amb. Press:	29.83	Start Time:	1210	Nozzle Dia:	H2O Gain =			Final:	
Static Press:	NA	Stop Time:	1433	Filter:					

Transverse Points	Time (Minute)	Delta P (HG)	Stack Temp. (F)	Set delta H (HG)	Meter Volume (scf)	Air Inlet Temp. (F)	Air Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (HG)
0	0	0.0245	-	-	642.123	-	-	247	246	-	-	NA	
1	5	0.0245	72	2.01	645.962	80	80	250	249	52	5		
2	10	0.0245	80	1.98	649.780	80	80	251	250	52	5		
3	15	0.0245	92	1.94	653.562	80	80	247	250	52	5		
4	20	0.0245	84	1.97	657.368	81	81	247	252	53	5		
5	25	0.0245	81	1.98	661.204	82	82	250	253	53	5		
6	30	0.0245	81	1.95	665.012	83	83	247	251	54	5		
7	35	0.0245	100	1.92	668.776	83	83	250	252	54	5		
8	40	0.0245	90	1.96	672.592	84	84	251	250	54	5		
9	45	0.0245	84	1.98	676.428	84	84	250	253	55	5		
10	50	0.0245	82	1.99	680.277	85	85	251	252	55	5		
11	55	0.0245	84	1.98	684.118	85	85	249	251	55	5		
12	60	0.0245	86	1.98	687.957	86	86	250	247	55	5		
					688.334								
1	7	0.0245	78	1.98	693.691	79	79	251	246	55	5		
2	14	0.0245	82	1.97	699.012	79	79	250	247	55	5		
3	21	0.0245	87	1.95	704.318	80	80	251	249	55	5		
4	28	0.0245	85	1.97	709.653	81	81	250	252	55	5		
5	35	0.0245	83	1.98	715.002	82	82	247	250	55	5		
6	42	0.0245	86	1.97	720.344	82	82	249	253	55	5		
7	49	0.0245	90	1.95	725.668	83	83	251	250	55	5		
8	56	0.0245	84	1.98	731.032	84	84	247	252	55	5		
9	63	0.0245	86	1.97	736.394	84	84	249	250	55	5		
10													
11													
12													

1310  
 CH  
 0.0245  
 22"

CH  
12

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: 80

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: 2%

Estimated O2: 20.5

Estimated CO2: 0.05

**Equipment Evaluation, OK? Y or N**

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pitot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pitot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Run #	2	Pilot ID:	47	Impinger #	Initial	Final	Net	Pilot Leak Check	
Date	5-21-2019	Pilot Coeff.:	.84	1	736.2	730.5		Initial:	NA
Client	Facility A	Meter Box #:	A-6	2	747.5	756.7		Final:	NA
Unit	Outlet	Meter @ Dh:	1.759	3	625.9	628.3		Meter Box Leak Check	
Operator	CH	Meter Y:	1.0376	4	852.2	871.4		Rate	THG
Stack Dia:	5-2	TC #:	47	5				Initial:	0.00
Amb. Press:	29.83	Start Time:	1510	Nozzle Dia:	H2O Gain =			Final:	0.00
Static Press:	NA	Stop Time:	1740	Filter:					29"

Reverse Points	Time (Minute)	Delta P (HG)	Stack Temp. (F)	Set delta H (HG)	Meter Volume (scf)	Mt. Inlet Temp. (F)	Mt. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (HG)
0	0	-	-	-	736.990	-	-	-	-	-	-	NA	
1	7	0.0245	91	1.93	742.241	76	76	250	246	54	5		
2	14	0.0245	87	1.95	747.532	78	78	247	251	54	5		
3	21	0.0245	84	1.96	752.841	78	78	250	247	54	5		
4	28	0.0245	89	1.94	758.127	79	79	253	249	54	5		
5	35	0.0245	86	1.96	763.493	80	80	252	251	54	5		
6	42	0.0245	83	1.97	768.782	80	80	250	248	54	5		
7	49	0.0245	87	1.96	774.097	81	81	251	249	55	5		
8	56	0.0245	89	1.95	779.423	82	82	250	247	55	5		
9	63	0.0245	85	1.97	784.771	82	82	251	249	55	5		
					785.282								
1	5	0.0245	87	1.94	789.052	76	76	250	246	55	5		
2	10	0.0245	89	1.93	792.808	76	76	248	249	55	5		
3	15	0.0245	85	1.95	796.592	77	77	250	255	55	5		
4	20	0.0245	82	1.97	800.391	78	78	252	253	55	5		
5	25	0.0245	87	1.95	804.168	78	78	250	252	56	5		
6	30	0.0245	88	1.95	807.952	79	79	251	249	56	5		
7	35	0.0245	85	1.96	811.751	80	80	252	250	56	5		
8	40	0.0245	82	1.97	815.563	80	80	253	247	56	5		
9	45	0.0245	87	1.95	819.361	80	80	251	249	56	5		
10	50	0.0245	86	1.96	823.169	81	81	254	252	56	5		
11	55	0.0245	82	1.98	826.987	81	81	253	249	56	5		
12	60	0.0245	89	1.95	830.772	82	82	250	251	56	5		

Hold meter Leak Check @ 1640  
 @ 1640  
 @ 1640

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: 2.2

Estimated O2: 20.5

Estimated CO2: 0.5

**Equipment Evaluation, OK? Y or N**

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Run #:	3	Pilot ID:	47	Impinger #:	Initial	Final	Net	Pilot Leak Check	
Date:	5-23-19	Pilot Coeff.:	.54	1	776.0	746.0		Initial:	
Client:	Facility A	Meter Box #:	A-6	2	625.2	639.9		Final:	
Unit:	Outlet	Meter @ Dh:	1.789	3	628.8	634.1		Meter Box Leak Check	
Operator:	CH	Meter Y:	10376	4	880.0	402.0		Rate:	"HG
Stack Dia:	Area Source	TC #:	47	5				Initial:	22"
Amb. Press:	29.62	Start Time:	0830	Nozzle Dia:	H2O Gain =			Final:	18"
Static Press:	NA	Stop Time:	1048	Filter:					

Traverse Points	Time (Min/Sec)	Delta P (H2O)	Stack Temp. (F)	Set delta H (H2O)	Meter Volume (scf)	Mtr. Inlet Temp. (F)	Mtr. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
0	0	-	-	-	831.607	-	-	-	-	-	-	NA	-
1	5	.0256	76	1.81	838.211	64	64	246	249	54	5		
2	10	.0256	84	1.79	838.792	65	65	249	252	54	5		
3	15	.0256	87	1.78	842.371	66	66	250	251	54	5		
4	20	.0256	89	1.78	845.953	67	67	247	248	54	5		
5	25	.0256	90	1.78	849.542	69	69	250	253	54	5		
6	30	.0256	86	1.80	853.160	71	71	252	251	54	5		
7	35	.0256	92	1.79	856.763	72	72	253	250	54	5		
8	40	.0256	87	1.81	860.402	74	74	254	252	54	5		
9	45	.0256	84	1.82	864.049	75	75	251	250	54	5		
10	50	.0256	89	1.81	867.692	76	76	252	249	54	5		
11	55	.0256	85	1.83	871.351	77	77	250	251	55	5		
12	60	.0256	84	1.83	875.022	77	77	247	250	55	5		
					875.534								
1	7	.0256	86	1.80	880.621	73	73	246	251	55	5		
2	14	.0256	91	1.79	885.692	74	74	249	252	55	5		
3	21	.0256	88	1.80	890.781	75	75	250	251	55	5		
4	28	.0256	93	1.79	895.862	76	76	251	247	55	5		
5	35	.0256	87	1.81	900.941	77	77	253	250	55	5		
6	42	.0256	84	1.82	906.120	78	78	251	247	55	5		
7	49	.0256	88	1.81	911.253	79	79	253	251	55	5		
8	56	.0256	85	1.82	916.401	79	79	251	249	55	5		
9	63	.0256	85	1.82	921.550	79	79	250	251	55	5		

Reserve @ 0945  
 Add name  
 Leak Check  
 21-100 Rev

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: 2%

Estimated O2: 20.9

Estimated CO2: .05

**Equipment Evaluation, OK? Y or N**

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Location: Inlet 1 (Inside)

**SAMPLING AND VELOCITY TRAVERSE POINT DETERMINATION  
SCAQMD METHOD 1.2**

CLIENT: AQMD Facility A  
 PLANT NAME: Metal Melting Facility  
 CITY, STATE: ██████████ CA  
 SAMPLING LOCATION: Inlet Furnace  
 TYPE OF TESTING: Metals & Particulate

NO. OF PORTS AVAILABLE: 2  
 NO. OF PORTS TO BE USED: 2  
 PORT INSIDE DIAMETER: 3 inches

DISTANCE FROM FAR WALL TO OUTSIDE OF PORT: 13.50 inches  
 NIPPLE LENGTH AND/OR WALL THICKNESS: 3.50 inches  
 DEPTH OF STACK OR DUCT, D: 10.00 inches  
 STACK OR DUCT WIDTH (IF RECTANGULAR), W: #N/A inches


**EQUIVALENT DIAMETER**

$D_e = 2 * (DEPTH) * (WIDTH) / (DEPTH + WIDTH) =$  10.00 inches  
 MAKE SURE TO USE METHOD A  
 STACK/DUCT AREA = 0.55 sq. feet 78.5 sq. inches

	<b>DISTANCE OF TEST PORT LOCATION:</b>	<b>DOWNSTREAM FROM FLOW DISTURBANCE</b>	<b>UPSTREAM FROM FLOW DISTURBANCE</b>
		B	A
# OF INCHES		25.00	16.50
# OF DIAMETERS		2.50	1.65

MINIMUM NUMBER OF TRAVERSE POINTS: 24

POINT NO.	% OF DUCT DEPTH	DISTANCE FROM INSIDE WALL (in.)	DISTANCE FROM OUTSIDE OF PORT (in.)
1	2.1	0.50	4
2	6.7	0.67	4 1/8
3	11.8	1.18	4 5/8
4	17.7	1.77	5 1/4
5	25.0	2.50	6
6	35.6	3.56	7
7	64.4	6.44	10
8	75.0	7.50	11
9	82.3	8.23	11 3/4
10	88.2	8.82	12 3/8
11	93.3	9.33	12 7/8
12	97.9	9.50	13



DRAWING NOT TO SCALE

Run #:	1	Pilot ID:	28	Impinger #:	Initial	Final	Net	Pilot Leak Check	
Date:	05/21/2015	Pilot Coeff.:	.84	0-1111021	757.2	872.9	760.0	Initial:	<input checked="" type="checkbox"/>
Client:	[REDACTED]	Meter Box #:	A-7	2	598.7	604.8		Final:	<input checked="" type="checkbox"/>
Unit:	Inlet 1 F&B 990	Meter @ Dh:	1.736	3	699.5	660.3		Meter Box Leak Check	
Operator:	T.TA	Meter Y:	1.0214	4	860.2	812.9		Rate	"HG
Stack Dia:	10.0"	TC #:	28	5				Initial:	0.008 27.0
Amb. Press:	29.83	Start Time:	1210	6				Final:	0.005 21.0
Static Press:	-14.1	Stop Time:	1430	8					
				Nozzle Dia:	H2O Gain =				
				Filter:					

Top

Side

Traverse Points	Time (Minute)	Delta P (H2O)	Stack Temp. (F)	Set delta H (H2O)	Meter Volume T-T (acf)	Mtr. Inlet Temp. (F)	Mtr. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
0	0				278.50								Jumper
A-1	5	2.50	107	1.36	273.113 276.43	89	89	242	239	56	6.0	243	
2	10	2.70	109	1.46	279.81	89	89	242	241	50	6.0	243	
3	15	2.70	100	1.49	283.28	90	90	241	240	47	6.0	242	
4	20	2.60	100	1.44	286.60	90	90	241	236	49	6.0	243	
5	25	3.0	128	1.58	290.20	92	92	241	240	52	6.50	243	
6	30	3.20	144	1.65	293.60	93	93	240	240	52	7.0	243	
7	35	3.50	149	1.79	297.35	93	93	241	240	53	7.0	242	
8	40	3.80	134	1.99	301.36	94	94	240	236	51	7.0	243	
9	45	3.10	113	1.69	305.08	95	95	240	235	52	7.0	243	
10	50	3.50	126	1.87	308.97	96	96	239	235	54	7.0	244	
11	55	3.60	134	1.89	312.83	96	96	241	235	54	7.0	243	stop @ 1310
12	60	3.10	108	1.65	316.48	97	97	240	236	55	7.0	243	
B-1	65	3.30	145	1.70	320.19	93	93	241	237	58	7.0	243	start @ 1330
2	70	3.40	128	1.80	323.95	94	94	241	235	55	7.0	242	
3	75	3.40	120	1.83	327.80	95	95	240	238	54	7.0	242	
4	80	2.70	146	1.39	331.16	95	95	239	239	55	6.50	243	
5	85	3.10	127	1.65	334.83	96	96	240	237	54	7.0	243	
6	90	2.90	133	1.53	338.31	97	97	240	236	53	7.0	243	
7	95	1.80	128	1.03	341.20	97	97	239	236	52	6.0	243	
8	100	1.10	135	.62	343.45	97	97	240	239	54	5.0	243	
9	105	.43	105	.26	347.94	97	97	239	240	54	4.50	243	
10	110	.39	118	.23	346.30	97	97	240	240	53	4.50	243	
11	115	.45	108	.27	347.77	96	96	240	338	54	4.50	243	
12	120	.52	107	.31	349.415	95	95	240					
In to out 12													

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: 95  
 Estimated Stack Temp: 89  
 Estimated Delta P: 3.48  
 Estimated Moisture Content: 2.0  
 Estimated O2: 20.5  
 Estimated CO2: .5

**Equipment Evaluation, OK? Y or N**

Ambient Temp.:  
 TC Check:  
 Pilot Check:  
 Teflon Bag:  
 Pilot Exp Date:  
 TC Exp Date:

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Inlet:						
Vacuum:						
Leak Rate:						
DGM Final:						

Run #:	2	Pilot ID:	28	Impinger #	Initial	Final	Net	Pilot Leak Check		
Date:	5/21/19	Pilot Coeff.:	.84	1	763.0	762.8		Initial:	<input checked="" type="checkbox"/>	
Client:	Facility A	Meter Box #:	A-7	2	760.6	768.9		Final:	<input checked="" type="checkbox"/>	
Unit:	Inlet 1 (Inside)	Meter @ Dh:	1.736	3	635.7	636.8		Meter Box Leak Check		
Operator:	T-TH	Meter Y:	1.0274	4	874.5	889.4		Rate	THG	
Stack Dia:	10	TC #:	28	5				Initial:	0.006	20.0
Amb. Press:	29.83	Start Time:	1510	Nozzle Dia:	120	Gain =		Final:	0.008	21.0
Static Press:	-14.10	Stop Time:	1740	Filter:						

Transverse Points	Time (Minute)	Delta P (H2O)	Stack Temp. (F)	Sec delta H (H2O)	Meter Volume (scf)	Mt. Inlet Temp. (F)	Mt. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
0	0				349.920								gumbo
A-1	5	2.70	157	1.35	353.24	88	88	240	235	57	5.0	238	
2	10	2.80	152	1.41	356.55	89	89	241	239	51	5.0	239	
3	15	2.70	152	1.36	359.87	90	90	241	237	50	5.0	239	
4	20	2.80	150	1.42	363.24	91	91	241	238	51	5.0	241	
5	25	3.30	151	1.67	366.89	91	91	241	240	52	5.50	243	
6	30	3.30	149	1.68	370.51	92	92	240	240	52	5.50	243	
7	35	3.90	155	1.97	374.53	92	92	240	238	51	6.0	243	
8	40	4.10	149	2.09	378.65	93	93	241	235	52	6.0	243	
9	45	3.90	150	1.99	382.64	93	93	241	234	53	6.0	242	
10	50	4.0	135	2.09	386.74	93	93	240	236	53	6.0	241	
11	55	3.40	116	1.83	390.85	93	93	240	237	52	6.0	241	
12	60	3.0	114	1.62	394.21	93	93	240	237	52	5.50	241	stop 160
B-1	65	3.40	134	1.76	397.92	87	87	238	239	56	5.50	240	start 1640
2	70	3.30	133	1.71	401.64	88	88	240	238	52	5.50	242	
3	75	3.30	129	1.73	405.30	89	89	240	241	52	5.50	242	
4	80	3.20	128	1.68	408.94	89	89	241	240	53	5.50	243	
5	85	2.90	127	1.53	412.47	90	90	241	239	53	5.0	243	
6	90	3.0	125	1.59	416.08	91	91	241	236	54	5.0	243	
7	95	1.60	119	.86	419.69	92	92	240	237	54	4.50	243	
8	100	2.30	128	1.21	423.82	91	91	240	240	53	5.0	243	
9	105	1.80	117	.97	425.60	92	92	241	237	53	4.50	243	
10	110	1.40	118	.75	428.04	91	91	241	236	54	4.50	242	
11	115	1.20	108	.65	430.35	91	91	241	237	54	4.0	242	
12	120	.94	121	.50	432.385	91	91	241	239	54	4.0	242	
In to out 12													

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: \_\_\_\_\_

Estimated O2: \_\_\_\_\_

Estimated CO2: \_\_\_\_\_

**Equipment Evaluation, OK? Y or N**

Ambient Temp: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Run #:	3	Pilot ID:	28	Impinger #:	Initial	Final	Net	Pilot Leak Check		
Date:	05/22/19	Pilot Coeff.:	.84	2	356.7	738.1		Initial:	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Client:	Facility A	Meter Box #:	A-7	3	602.5	615.5		Final:	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Unit:	Inlet 11 (Inside)	Meter @ Dh:	1.736	4	661.4	665.5		Meter Box Leak Check		
Operator:	T. TA	Meter Y:	1.0274	5	862.1	886.7		Rate:		THC:
Stack Dia:	10	TC #:	28	H2O Gain =			Initial:	0.004	20.04	
Amb. Press:	29.62	Start Time:	0830	Nozzle Dia:	1.80	Filter:	Final:	0.10	22.0	
Static Press:	-14.30	Stop Time:	1045							

TOP

Traverse Points	Time (Minute)	Delta P (H2O)	Stack Temp. (F)	Set delta H (H2O)	Meter Volume (cc)	Mt. Inlet Temp. (F)	Mt. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
0	0				432.940								number
A-1	5	2.50	165	2.21	437.11	80	80	242	237	54	8.50	242	
2	10	2.60	134	2.42	441.49	82	82	241	239	46	9.50	243	
3	15	2.50	171	2.20	445.64	84	84	242	238	50	9.50	242	
4	20	2.60	180	2.27	449.83	86	86	242	238	54	10.0	243	
5	25	2.70	147	2.49	454.26	87	87	241	237	58	10.50	243	
6	30	3.0	131	2.85	458.98	89	89	242	240	57	13.50	242	
7	35	3.1	146	2.87	463.77	90	90	241	238	58	14.0	242	
8	40	3.8	110	3.75	469.21	91	91	240	239	58	16.0	243	
9	45	3.4	110	3.37	474.35	93	93	241	239	57	17.0	243	
10	50	3.0	104	3.0	479.25	93	93	241	236	57	16.0	243	
11	55	2.20	93	2.25	482.45	93	93	241	235	55	13.0	243	
12	60	2.0	126	1.93	487.19	93	93	241	239	53	12.50	243	stop @ 0930
B-1	65	3.7	119	3.59	492.48	90	90	241	243	50	16.0	243	start @ 945
2	70	3.50	126	3.36	497.60	91	91	240	236	49	17.0	242	
3	75	3.90	155	3.03	502.47	92	92	240	235	54	18.0	242	
4	80	3.20	164	2.89	507.28	92	92	240	239	55	18.0	243	
5	85	3.0	152	2.77	511.94	93	93	241	237	54	18.50	243	
6	90	3.40	118	3.32	517.05	93	93	241	239	54	20.0	243	
7	95	2.2	124	2.13	521.20	93	93	241	238	51	16.0	242	
8	100	2.3	152	2.12	525.31	93	93	241	236	50	16.50	242	
9	105	1.70	109	1.69	529.08	94	94	241	237	51	13.50	243	
10	110	1.60	119	1.56	532.62	94	94	241	239	52	13.0	243	
11	115	1.40	124	1.36	535.94	94	94	240	236	51	13.0	243	
12	120	1.20	114	1.18	539.086	94	94	241	239	54	11.50	243	

In to out 12

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: 95

Estimated Stack Temp: 140

Estimated Delta P: 2.73

Estimated Moisture Content: 2

Estimated O2: 20.5

Estimated CO2: .50

**Equipment Evaluation, OK? Y or N**

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pitot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pitot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						





Location: Inlet 1 (Upstream of the Baghouse)

**SAMPLING AND VELOCITY TRAVERSE POINT DETERMINATION  
SCAQMD METHOD 1.1**

CLIENT: AQMD Facility A  
 PLANT NAME: Metal Melting Facility  
 CITY, STATE: ██████████, CA  
 SAMPLING LOCATION: Inlet (Upstream of Baghouse)  
 TYPE OF TESTING: Metals/Particulate

NO. OF PORTS AVAILABLE: 1  
 NO. OF PORTS TO BE USED: 1  
 PORT INSIDE DIAMETER: 2.5 inches

DISTANCE FROM FAR WALL TO OUTSIDE OF PORT: 38.00 inches  
 NIPPLE LENGTH AND/OR WALL THICKNESS: 2.00 inches  
 DEPTH OF STACK OR DUCT, D: 36.00 inches  
 STACK OR DUCT WIDTH (IF RECTANGULAR), W: #N/A inches


EQUIVALENT DIAMETER  
 $De = 2 * (DEPTH) * (WIDTH) / (DEPTH + WIDTH) =$  36.00 inches

STACK/DUCT AREA = 7.07 sq. feet 1017.9 sq.inches

DISTANCE OF TEST PORT LOCATION:	<b>DOWNSTREAM</b>	<b>UPSTREAM</b>
	<b>FROM FLOW</b>	<b>FROM FLOW</b>
	<b><u>DISTURBANCE</u></b>	<b><u>DISTURBANCE</u></b>
	<b>B</b>	<b>A</b>
# OF INCHES	87.00	48.50
# OF DIAMETERS	2.42	1.35

MINIMUM NUMBER OF TRAVERSE POINTS: 24

POINT NO.	% OF DUCT DEPTH	DISTANCE FROM INSIDE WALL (in.)	DISTANCE FROM OUTSIDE OF PORT (in.)
1	2.1	0.76	2 3/4
2	6.7	2.41	4 3/8
3	11.8	4.25	6 1/4
4	17.7	6.37	8 3/8
5	25.0	9.00	11
6	35.6	12.82	14 7/8
7	64.4	23.18	25 1/8
8	75.0	27.00	29
9	82.3	29.63	31 5/8
10	88.2	31.75	33 3/4
11	93.3	33.59	35 5/8
12	97.9	35.24	37 1/4



DRAWING NOT TO SCALE

Run #:	1	Pilot ID:	34	Impinger #:	Initial	Final	Net	Pilot Leak Check		
Date:	5/21/19	Pilot Coeff.:	0.84	1	733.4	724.3		Initial:	x	x
Client:	Facility A	Meter Box #:	A-8	2	742.0	735.3		Final:	x	x
Unit:	Inlet 2 outside	Meter @ Dh:	1.834	3	534.0	537.4		Meter Box Leak Check		
Operator:	MN	Meter Y:	1.0395	4	875.3	891.8		Rate:		THG
Stack Dia:	86.0	TC #:	34	5				Initial:	0.000	10
Amb. Press:	29.83	Start Time:	1210	Nozzle Dia:	H2O Gain =			Final:	0.000	12
Static Press:	-1.8	Stop Time:	1430	Filter:	0.155					

Traverse Points	Time (Minute)	Delta P (H2O)	Stack Temp. (F)	Set delta H (H2O)	Meter Volume (scf)	Mr. Inlet Temp. (F)	Mr. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vol. (H2O)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
12	0	2.10	93	2.25	910.028	85	NA	249	252	47	9.0	NA	<10
11	5.00	2.50	91	1.55	913.24	87		252	251	44	11.0	NA	<10
10	10.0	3.2	91	1.90	916.89	88		253	253	47	11.0	NA	
9	15.0	2.90	98	1.75	920.63	89		252	252	49	10.0		
8	20.0	2.70	90	1.60	924.30	90		252	252	51	10.0		
7	25.0	2.65	91	1.6	927.85	91		251	252	51	10.0		
6	30.0	2.60	90	1.55	931.37	91		252	257	53	10.0		
5	35.0	2.10	91	1.25	935.02	92		252	252	53	10.0		
4	40.0	1.95	92	1.15	938.06	92		251	252	54	10.0		
3	45.0	1.60	88	0.95	941.05	92		252	251	54	10.0		
2	50.0	2.40	87	1.45	943.69	92		252	251	54	10.0		
1	55.0	2.80	81	1.65	947.01	92		251	251	54	10.0		
12	60.0	2.40	89	1.45	950.58	89	NA	252	252	52	10.0		<10
11	65.0	2.90	91	1.75	953.83	89		252	253	51	10.0		
10	70.0	3.20	90	1.85	957.46	90		251	257	51	11.0	NA	
9	75.0	3.40	91	2.00	961.25	91		253	252	52	11.0		
8	80.0	3.80	91	1.65	965.21	91		252	252	53	11.0		
7	85.0	2.60	91	1.55	968.88	91		252	253	53	11.0		
6	90.0	2.80	91	1.65	972.34	91		252	252	55	11.0		
5	95.0	2.05	88	2.05	975.89	91		252	253	56	11.0		
4	100.0	2.00	89	2.00	979.00	90		251	252	57	11.0		
3	105.0	2.50	93	1.50	982.02	91		252	252	56	11.0		
2	110.0	2.35	92	1.4	984.68	91		252	251	56	11.0		
1	115.0	2.70	92	1.6	987.00	91		252	252	56	11.0		
0	120.0				990.56								

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: \_\_\_\_\_

Estimated O2: \_\_\_\_\_

Estimated CO2: \_\_\_\_\_

Equipment Evaluation, OK? Y or N

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

Dry Gas Meter Leak Checks

DGM Initial:	1	2	3	4	5	6
Vacuum:						
Leak Rate:						
DGM Final:						

Run #:	2	Pilot ID:	39	Impinger #:	Initial	Final	Net	Pilot Leak Check		
Date:	5/21/19	Pilot Coeff.:	0.84	1	626.1	630.4		Initial:	X	X
Client:	Facility A	Meter Box #:	A-8	2	751.9	757.0		Final:	X	X
Unit:	Inlet 2 (Outside)	Meter @ Dh:	1.834	3	629.4	629.5		Meter Box Leak Check		
Operator:	MN	Meter Y:	1.0395	4	903.0	915.6		Rate:		"HG
Stack Dia:	36.0	TC #:	54	5				Initial:	0.000	10
Amb. Press:	29.83	Start Time:	1510	Nozzle Dia:	H2O Gain =			Final:	0.000	13
Static Press:	-13	Stop Time:	1740	0.155	Filter:					

1510

Traverse Points	Time (Minute)	Delta P ("H2O)	Stack Temp. (F)	Set delta H ("H2O)	Meter Volume (acf)	Mt. Inlet Temp. (F)	Mt. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. ("HG)	TE Cooler Temp. (F)	Cyclonic Flow ("H2O)
12	0	2.20	86	1.30	990.944	85	85	255	254	57	8.0	NA	<16
11	5.0	2.40	86	1.45	994.110	86		253	251	48	8.0	NA	<10
10	10.0	2.10	87	1.85	997.22	87		255	252	47	8.0		<10
9	15.0	2.00	87	1.80	1001.22	88		251	252	46	9.0		
8	20.0	2.75	87	1.65	1005.00	89		251	253	46	9.0		
7	25.0	2.80	87	1.85	1008.52	89		252	252	45	9.0		
6	30.0	2.50	87	1.85	1012.96	90		253	252	45	9.0		
5	35.0	2.60	86	1.55	1016.17	90		251	252	46	9.0		
4	40.0	2.40	86	1.45	1019.64	91		252	252	47	9.0		
3	45.0	2.80	86	1.65	1023.00	91		251	251	47	9.0		
2	50.0	2.70	86	1.60	1026.51	91		253	254	47	9.0		
1	55.0	2.30	84	1.35	1030.23	91	NA	252	253	48	9.0		
0	60.0	2.80	82	1.65	1033.52	91		251	252	52	9.0		
12	65.0	2.70	82	1.60	1037.08	86		253	251	48	9.0	NA	
11	70.0	2.90	83	1.75	1040.58	87		252	252	48	9.0	NA	<10
10	75.0	2.90	82	1.75	1044.16	87		251	253	48	9.0		
9	80.0	2.40	83	1.45	1048.00	88		252	251	48	9.0		
8	85.0	3.0	83	1.80	1051.35	88		253	253	49	9.0		
7	90.0	2.7	83	1.60	1055.18	88		251	254	49	9.0		
6	95.0	2.4	83	1.45	1058.75	88		253	252	49	9.0		
5	100.0	2.55	82	1.50	1062.11	88		253	252	49	9.0		
4	105.0	2.3	82	1.35	1065.53	88		251	251	49	9.0		
3	110.0	2.65	82	1.60	1068.79	88		252	251	49	9.0		
2	115.0	2.3	82	1.7	1071.35	88		254	254	50	9.0		
1	120.0				1075.67								

640

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: 40

Estimated Stack Temp: 85

Estimated Delta P: 2.83

Estimated Moisture Content: 2.0%

Estimated O2: 20.5%

Estimated CO2: 0.5%

**Equipment Evaluation, OK? Y or N**

Ambient Temp.: X

TC Check: X

Pilot Check: X

Tedlar Bag: N/A

Pilot Exp Date:

TC Exp Date:

**Dry Gas Meter Leak Checks**

DGM Initial:	1	2	3	4	5	6
Vacuum:						
Leak Rate:						
DGM Final:						

Run #:	3	Pilot ID:	834	Impinger #:	Initial	Final	Net	Pilot Leak Check	
Date:	5/22/19	Pilot Coeff.:	0.84		135.9	114.4		Initial:	NA
Client:	Facility A	Meter Box #:	A-8		744.4	704.6		Final:	NA
Unit:	Inlet 2 (outside)	Meter @ Dh:	1.834		535.7	541.1		Meter Box Leak Check	
Operator:	MN	Meter Y:	1.0375		822.1	905.4		Rate:	14
Stack Dia:	36.0	TC #:	34					Final:	0.000 23
Amb. Press:	29.62	Start Time:	8:30	Nozzle Dia:	0.173		H2O Gain =		
Static Press:	-13	Stop Time:	18:10	Filter:	0.195				

Traverse Points	Time (Minutes)	Delta P (H2O)	Stack Temp. (F)	Std delta H (H2O)	Meter Volume (scf)	Mt. Inlet Temp. (F)	Mt. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vol. (H2O)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
12	0	2.90	83	2.7	35.957	72	NA	254	251	43	12.0	NA	210
11	5.0	3.50	84	3.25	80.210	73	///	253	252	45	13.0	///	///
10	6.0	3.40	87	3.15	85.02	74	///	252	253	53	13.0	///	///
9	15.0	3.50	88	3.25	89.66	76	///	252	253	56	13.0	///	///
8	20.0	2.90	86	2.70	94.410	77	///	253	254	59	12.0	///	///
7	25.0	2.70	85	2.50	98.720	77	///	252	253	59	12.0	///	///
6	30.0	2.65	84	2.45	102.95	79	///	251	253	58	12.0	///	///
5	35.0	2.45	86	2.25	107.02	80	///	253	252	56	10.0	///	///
4	40.0	2.00	87	1.85	111.03	80	///	252	253	55	10.0	///	///
3	45.0	2.00	82	1.85	114.82	80	///	253	253	55	10.0	///	///
2	50.0	2.30	83	2.15	118.45	81	///	251	251	53	11.0	///	///
1	55.0	2.20	83	2.05	122.35	81	///	254	252	54	10.0	///	///
0	60.0	2.60	85	2.4	126.21	79	NA	253	252	52	10.0	NA	210
12	65.0	2.40	87	3.15	130.35	81	///	251	253	52	13.0	///	///
11	70.0	3.30	89	3.05	135.12	81	///	254	253	54	13.0	///	///
10	75.0	3.60	89	3.35	139.79	83	///	251	251	56	14.0	///	///
9	80.0	3.00	88	2.75	144.72	83	///	253	252	52	13.0	///	///
8	85.0	2.90	87	2.70	149.13	83	///	254	252	50	13.0	///	///
7	90.0	2.70	89	2.50	153.46	84	///	253	253	49	13.0	///	///
6	95.0	2.2	92	2.05	157.69	84	///	252	262	49	11.0	///	///
5	100.0	1.7	91	1.80	161.54	85	///	253	252	48	10.0	///	///
4	105.0	1.8	90	1.65	164.85	85	///	251	251	48	10.0	///	///
3	110.0	2.8	87	2.6	168.34	86	///	252	251	49	12.0	///	///
2	115.0	3.2	87	2.95	172.63	86	///	253	263	49	13.0	///	///
1	120.0				177.21		///					///	///

Restart 7:45

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: \_\_\_\_\_

Estimated O2: \_\_\_\_\_

Estimated CO2: \_\_\_\_\_

Equipment Evaluation, OK? Y or N

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pitot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pitot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

**APPENDIX C3**

**MULTIPLE METAL EMISSIONS – LABORATORY DATA**

Mehod 436 Lab Data Summary								
				Inlet 1 (Inside)	Inlet 2 (Outside)	Outlet	RB	FB
				1	Upstream of Baghouse			
Run 1	Arsenic	As	ug	<1	<1	<1	<1	<1
	Cadmium	Cd	ug	<1	1.1	<1	<1	<1
	Chromium	Cr	ug	220	32	41	1.5	<b>2.2</b>
	<b>RB Corrected</b>	<b>Cr</b>	<b>ug</b>	<b>218.5</b>	<b>30.5</b>	<b>39.5</b>		
	Nickel	Ni	ug	59	22	7.4	1.3	3.1
	<b>RB Corrected</b>	<b>Ni</b>	<b>ug</b>	<b>57.7</b>	<b>20.7</b>	<b>6.1</b>		
Run 2	Arsenic	As	ug	<1	<1	<1		
	Cadmium	Cd	ug	<1	<1	<1		
	Chromium	Cr	ug	41	9.7	2.5		
	<b>RB Corrected</b>	<b>Cr</b>	<b>ug</b>	<b>39.5</b>	<b>8.2</b>	<b>1.0</b>		
	Nickel	Ni	ug	7.3	13	1.8		
	<b>RB Corrected</b>	<b>Ni</b>	<b>ug</b>	<b>6</b>	<b>11.7</b>	<b>0.50</b>		
Run 3	Arsenic	As	ug	2.9	<1	<1		
	Cadmium	Cd	ug	1	<1	<1		
	Chromium	Cr	ug	690	60	2.1		
	<b>RB Corrected</b>	<b>Cr</b>	<b>ug</b>	<b>688.5</b>	<b>58.5</b>	<b>0.6</b>		
	Nickel	Ni	ug	130	44	1.9		
	<b>RB Corrected</b>	<b>Ni</b>	<b>ug</b>	<b>128.7</b>	<b>42.7</b>	<b>0.6</b>		



Work Orders: 9E30032

Report Date: 6/20/2019

Project: 10562/IN(I)/In(O)/Out

Received Date: 5/29/2019

Turnaround Time: Normal

Phones: (714) 889-4000

Fax: (714) 889-7030

P.O. #: 10562

Attn: Almaga Environmental & Technical Services

Billing Code:

Client: Almaga Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630


EPA-UCMR #CA00211 • HW-DOH # • ISO 17025 #L2457.01 • LACSD #10143 • NELAP-CA #04229CA • NELAP-OR #4047 •  
NJ-DEP #CA015 • NV-DEP #NAC 445A • SCAQMD #93LA1006

*This is a complete final report. The information in this report applies to the samples analyzed in accordance with the chain-of-custody document. Weck Laboratories certifies that the test results meet all requirements of TNI unless noted by qualifiers or written in the Case Narrative. This analytical report must be reproduced in its entirety.*

Dear Almaga Environmental & Technical Services,


Enclosed are the results of analyses for samples received 5/29/19 with the Chain-of-Custody document. The samples were received in good condition, at 4.7 °C. All analyses met the method criteria except as noted in the case narrative or in the report with data qualifiers.

Reviewed by:



Brandon Gee  
Operations Manager/Senior PM





WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL


**Project Number:** 10562/IN(I)/In(O)/Out

**Reported:**  
06/20/2019 07:57

**Project Manager:** Almega Environmental & Technical Services

## Sample Summary

Sample Name	Sampled By	Lab ID	Matrix	Sampled	Qualifiers
105462 - M436 - C1 - In(O) - FB	Client	9E30032-01	Filter	05/21/19 09:00	
105462 - M436 - C1 - In(I) - R1	Client	9E30032-04	Filter	05/21/19 12:10	
105462 - M436 - C1 - In(O) - R1	Client	9E30032-07	Filter	05/21/19 12:10	
105462 - M436 - C1 - Out - R1	Client	9E30032-10	Filter	05/21/19 12:10	
105462 - M436 - C1 - In(I) - R2	Client	9E30032-13	Filter	05/21/19 15:10	
105462 - M436 - C1 - In(O) - R2	Client	9E30032-16	Filter	05/21/19 15:10	
105462 - M436 - C1 - Out - R2	Client	9E30032-19	Filter	05/21/19 15:10	
105462 - M436 - C1 - In(I) - R3	Client	9E30032-22	Filter	05/22/19 08:30	
105462 - M436 - C1 - In(O) - R3	Client	9E30032-25	Filter	05/22/19 08:30	
105462 - M436 - C1 - Out - R3	Client	9E30032-28	Filter	05/22/19 08:30	
105462-M436-RB-Filter	Client	9E30032-31	Filter	05/22/19 09:30	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL

Project Number: 10562/IN(I)/In(O)/Out

Reported: 06/20/2019 07:57

Project Manager: Almega Environmental & Technical Services

## Sample Results

Sample: 105462 - M436 - C1 - In(O) - FB  
9E30032-01 (Filter) Sampled: 05/21/19 9:00 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 14:16	
Cadmium, Total	ND	1.0	ug/filter	5	06/17/19 14:16	
Chromium, Total	2.2	0.20	ug/filter	1	06/17/19 13:28	
Nickel, Total	3.1	0.20	ug/filter	1	06/17/19 13:28	

Sample: 105462 - M436 - C1 - In(I) - R1  
9E30032-04 (Filter) Sampled: 05/21/19 12:10 by Client


Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 14:20	
Cadmium, Total	ND	1.0	ug/filter	5	06/17/19 14:20	
Chromium, Total	220	1.0	ug/filter	5	06/17/19 14:20	
Nickel, Total	59	1.0	ug/filter	5	06/17/19 14:20	

Sample: 105462 - M436 - C1 - In(O) - R1  
9E30032-07 (Filter) Sampled: 05/21/19 12:10 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 14:22	
Cadmium, Total	1.1	1.0	ug/filter	5	06/17/19 14:22	
Chromium, Total	32	0.20	ug/filter	1	06/17/19 13:35	
Nickel, Total	22	0.20	ug/filter	1	06/17/19 13:35	

Sample: 105462 - M436 - C1 - Out - R1  
9E30032-10 (Filter) Sampled: 05/21/19 12:10 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 14:24	
Cadmium, Total	ND	1.0	ug/filter	5	06/17/19 14:24	
Chromium, Total	41	0.20	ug/filter	1	06/17/19 13:37	
Nickel, Total	7.4	0.20	ug/filter	1	06/17/19 13:37	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

**Almega** REPORT  
ENVIRONMENTAL

**Project Number:** 10562/IN(I)/In(O)/Out

**Reported:**

06/20/2019 07:57

**Project Manager:** Almega Environmental & Technical Services

## Sample Results

(Continued)

Sample: 105462 - M436 - C1 - In(I) - R2  
9E30032-13 (Filter)

Sampled: 05/21/19 15:10 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 14:26	
Cadmium, Total	ND	1.0	ug/filter	5	06/17/19 14:26	
Chromium, Total	41	0.20	ug/filter	1	06/17/19 13:39	
Nickel, Total	7.3	0.20	ug/filter	1	06/17/19 13:39	

Sample: 105462 - M436 - C1 - In(O) - R2  
9E30032-16 (Filter)

Sampled: 05/21/19 15:10 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 14:29	
Cadmium, Total	ND	1.0	ug/filter	5	06/17/19 14:29	
Chromium, Total	9.7	0.20	ug/filter	1	06/17/19 13:42	
Nickel, Total	13	0.20	ug/filter	1	06/17/19 13:42	

Sample: 105462 - M436 - C1 - Out - R2  
9E30032-19 (Filter)


Sampled: 05/21/19 15:10 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 14:31	
Cadmium, Total	ND	1.0	ug/filter	5	06/17/19 14:31	
Chromium, Total	2.5	0.20	ug/filter	1	06/17/19 13:44	
Nickel, Total	1.8	0.20	ug/filter	1	06/17/19 13:44	

Sample: 105462 - M436 - C1 - In(I) - R3  
9E30032-22 (Filter)

Sampled: 05/22/19 8:30 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	2.9	1.0	ug/filter	5	06/17/19 14:33	
Cadmium, Total	1.0	1.0	ug/filter	5	06/17/19 14:33	
Chromium, Total	690	1.0	ug/filter	5	06/17/19 14:33	
Nickel, Total	130	1.0	ug/filter	5	06/17/19 14:33	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL

**Project Number:** 10562/IN(I)/In(O)/Out

**Reported:**  
06/20/2019 07:57

**Project Manager:** Almega Environmental & Technical Services

## Sample Results

(Continued)

Sample: 105462 - M436 - C1 - In(O) - R3  
9E30032-25 (Filter) Sampled: 05/22/19 8:30 by Client


Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 15:03	
Cadmium, Total	ND	1.0	ug/filter	5	06/17/19 15:03	
Chromium, Total	60	0.20	ug/filter	1	06/17/19 13:48	
Nickel, Total	44	0.20	ug/filter	1	06/17/19 13:48	

Sample: 105462 - M436 - C1 - Out - R3  
9E30032-28 (Filter) Sampled: 05/22/19 8:30 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 15:05	
Cadmium, Total	ND	1.0	ug/filter	5	06/17/19 15:05	
Chromium, Total	2.1	0.20	ug/filter	1	06/17/19 14:02	
Nickel, Total	1.9	0.20	ug/filter	1	06/17/19 14:02	

Sample: 105462-M436-RB-Filter  
9E30032-31 (Filter) Sampled: 05/22/19 9:30 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
<b>Method:</b> EPA 6020	<b>Batch ID:</b> W9F0681	<b>Instr:</b> ICPMS03	<b>Prepared:</b> 06/12/19 16:26	<b>Analyst:</b> ALN		
Arsenic, Total	ND	1.0	ug/filter	5	06/17/19 14:18	
Cadmium, Total	ND	1.0	ug/filter	5	06/17/19 14:18	
Chromium, Total	1.5	0.20	ug/filter	1	06/17/19 13:31	
Nickel, Total	1.3	0.20	ug/filter	1	06/17/19 13:31	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL

Project Number: 10562/IN(I)/In(O)/Out

Reported:


06/20/2019 07:57

Project Manager: Almega Environmental & Technical Services

## Quality Control Results

Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Analyte	Result	MRL	Units	Spike Level	Source Result	%REC	Limits	RPD	RPD Limit	Qualifier
<b>Batch: W9F0681 - EPA 6020</b>										
<b>Blank (W9F0681-BLK1)</b>										
<b>Prepared: 06/12/19 Analyzed: 06/17/19</b>										
Arsenic, Total	ND	0.20	ug/filter							
Cadmium, Total	ND	0.20	ug/filter							
Chromium, Total	ND	0.20	ug/filter							
Nickel, Total	ND	0.20	ug/filter							
<b>LCS (W9F0681-BS1)</b>										
<b>Prepared: 06/12/19 Analyzed: 06/17/19</b>										
Arsenic, Total	5.11	1.0	ug/filter	5.00		102	80-120			
Cadmium, Total	4.96	1.0	ug/filter	5.00		99	80-120			
Chromium, Total	5.14	0.20	ug/filter	5.00		103	80-120			
Nickel, Total	5.02	0.20	ug/filter	5.00		100	80-120			
<b>LCS Dup (W9F0681-BSD1)</b>										
<b>Prepared: 06/12/19 Analyzed: 06/17/19</b>										
Arsenic, Total	5.10	1.0	ug/filter	5.00		102	80-120	0.2	20	
Cadmium, Total	5.05	1.0	ug/filter	5.00		101	80-120	2	20	
Chromium, Total	5.09	0.20	ug/filter	5.00		102	80-120	0.8	20	
Nickel, Total	4.90	0.20	ug/filter	5.00		98	80-120	2	20	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

Project Number: 10562/IN(I)/In(O)/Out

Project Manager: Almega Environmental & Technical Services

Reported:  
06/20/2019 07:57

## Notes and Definitions

Item	Definition
% Rec	Percent Recovery
Dil	Dilution
dry	Sample results reported on a dry weight basis
MDA	Minimum Detectable Activity
MDL	Method Detection Limit
MRL	The minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence. The MRL is also known as Limit of Quantitation (LOQ) and Detection Limit for Reporting (DLR)
ND	NOT DETECTED at or above the Method Reporting Limit (MRL). If Method Detection Limit (MDL) is reported, then ND means not detected at or above the MDL.
NR	Not Reportable
RPD	Relative Percent Difference
Source	Sample that was matrix spiked or duplicated.
TIC	Tentatively Identified Compound (TIC) using mass spectrometry. The reported concentration is relative concentration based on the nearest internal standard. If the library search produces no matches at, or above 85%, the compound is reported as unknown.

Any remaining sample(s) will be disposed of one month from the final report date unless other arrangements are made in advance.

An Absence of Total Coliform meets the drinking water standards as established by the California State Water Resources Control Board (SWRCB)

All results are expressed on wet weight basis unless otherwise specified.

All samples collected by Weck Laboratories have been sampled in accordance to laboratory SOP Number MIS002.

Signature: 1065  
 01E20032



**INVOICE:**  
**CLIENT:** AQMD Facility A  
**JOB #:** 10662  
**ATTN:**

**REPORT TO:**  
 ALMEGA Environmental & Technical Services  
 10902 Walker St.  
 Cypress, CA 90630  
 (714) 889-6000 Fax (714) 889-7030  
 info@almegaenv.com  
 Contact: Neal Conroy

**Turnaround Time**  
 Standard: X  
 Other: \_\_\_\_\_  
 Route: \_\_\_\_\_  
 Depends on # of Samples  
 5 - 10 days  
 3 - 7 days

Unit 1: In (I)	Unit 2: In (C)	Unit 3: Out	Project Manager: Sample Date	Sample Time	Sample Identification	Description	Type of Sample		ANALYSIS REQUESTED		Return or Dispose	REMARKS
							Liquid	Solid	By	Y		
5/21/2019	09:00		Neal Conroy		10662 - M436 - C1 - In (C) - FI	Fiber	X	1	X			
					10662 - M436 - C2 - In (C) - FI	Proteinaceous Res	X	1	X			
					10662 - M436 - C3 - In (C) - FI	Imp. 1, 2, 3	X	1	X			
5/21/2019	12:19-14:30				10662 - M436 - C1 - In (C) - R1	Fiber	X	1	X			
					10662 - M436 - C2 - In (C) - R1	Proteinaceous Res	X	1	X			
					10662 - M436 - C3 - In (C) - R1	Imp. 1, 2, 3	X	1	X			
5/21/2019	12-10-14:30				10662 - M436 - C1 - In (C) - R1	Fiber	X	1	X			
					10662 - M436 - C2 - In (C) - R1	Proteinaceous Res	X	1	X			
					10662 - M436 - C3 - In (C) - R1	Imp. 1, 2, 3	X	1	X			

Received by: SLB Date: 5/21/19 Time: 7:15 PM  
 Requisitioned by: Neal Conroy  
 Received by: SLB Date: 5/28/19 Time: 9:30  
 Requisitioned by: Neal Conroy  
 Received by: SLB Date: 6/18/19 Time: 11:15  
 Requisitioned by: Neal Conroy







Q/E 30032

INVOICE:		REPORT TO:		Page-Off:		Turnaround Time	
CLIENT:	ALMENA Environmental & Technical Services	PO #	10567	Standard	X	Other	
JOB #:	10992 Walker St Cypress, CA 90630 (714) 889-4000 Fax (714) 889-7000 info@almegaenv.com	Contact:	Neal Conroy	Remarks:	Rush: Depends on # of Samples 5 - 10 days 3 - 7 days		
A/TTN:	10992			Return of Disposal			
		Unit 2: In(C)    Unit 3: Out		ANALYSIS REQUESTED			
Sample Date	Sample Time	Sample Identification	Description	Type Of Sample	Filter	Analysis Requested	Remarks
5/21/2019	15:10-17:40	10562 - M436 - C1 - In(C) - R2	Filter	X	1	X	
		10562 - M436 - C2 - In(C) - R2	Protocols/Rinses	X	1	X	
		10562 - M436 - C3 - In(C) - R2	Imp 1, 2, 3	X	1	X	
5/21/2019	15:10-17:40	10562 - M436 - C1 - In(C) - R2	Filter	X	1	X	
		10562 - M436 - C2 - In(C) - R2	Protocols/Rinses	X	1	X	
		10562 - M436 - C3 - In(C) - R2	Imp 1, 2, 3	X	1	X	
5/21/2019	15:10-17:40	10562 - M436 - C1 - Out - R2	Filter	X	1	X	
		10562 - M436 - C2 - Out - R2	Protocols/Rinses	X	1	X	
		10562 - M436 - C3 - Out - R2	Imp 1, 2, 3	X	1	X	
Received by: <i>W Camp</i> Date: 5/21/19    Time: 9:15 PM		Received by: <i>[Signature]</i> Date: 5/22/19    Time: 12:00		Received by: <i>[Signature]</i> Date: 6/18/19    Time: 11:15		4.7% TOTO	

Page 1 of 2  
4 of 5



9E30032



INVOICE:		REPORT TO:		ALPHA		ANALYSIS REQUESTED		TURNAROUND TIME			
CLIENT:	ACMD Facility A	ALMEGA Environmental & Technical Services	PO #	10567	Standard	X	Other				
JOB #:	10502	10602 Walker St Cypress, CA 90030 (714) 889-4569 Fax (714) 889-7030 Info@almegaenv.com Contact: Noel Conroy			Depends on # of Samples		5-10 days				
ATTN:					3-7 days						
Unit 1:	Unit 2:	Unit 3:	Unit 4:	Unit 5:	Unit 6:	Unit 7:	Unit 8:	Unit 9:	Unit 10:		
Sample Date	Sample Time	Sample Identification	Description	Type of Sample	Number of Samples	Number of Analytes	Number of Containers	Number of Containers	Number of Containers		
5/22/2019	8:30-10:45	10562 - M436 - C1 - In(1) - R3	Filter	X	1	X					
		10562 - M436 - C2 - In(1) - R3	Preoxidized Filter	X	1	X					
		10562 - M436 - C3 - In(1) - R3	Imp 1, 2, 3	X	1	X					
		10562 - M436 - C1 - In(1) - R3	Filter	X	1	X					
		10562 - M436 - C2 - In(1) - R3	Preoxidized Filter	X	1	X					
		10562 - M436 - C3 - In(1) - R3	Imp 1, 2, 3	X	1	X					
		10562 - M436 - C1 - Out - R3	Filter	X	1	X					
		10562 - M436 - C2 - Out - R3	Preoxidized Filter	X	1	X					
		10562 - M436 - C3 - Out - R3	Imp 1, 2, 3	X	1	X					
Collected by: N Conroy		Received by: [Signature]		Date: 5/22/19		Time: 10:15		Date: 5/28/19		Time: 10:20	
Requisitioned by: [Signature]		Received by: [Signature]		Date: 5/22/19		Time: 9:45		Date: 5/28/19		Time: 10:20	
Requisitioned by: [Signature]		Received by: [Signature]		Date: 5/22/19		Time: 9:45		Date: 5/28/19		Time: 10:20	
Requisitioned by: [Signature]		Received by: [Signature]		Date: 5/22/19		Time: 9:45		Date: 5/28/19		Time: 10:20	
Requisitioned by: [Signature]		Received by: [Signature]		Date: 5/22/19		Time: 9:45		Date: 5/28/19		Time: 10:20	

9E30032



**INVOICE:**  
**CLIENT:** AQMD Facility A  
**JOB #:** 10562  
**ATTN:**

**REPORT TO:**  
 ALMEGA Environmental & Technical Services  
 10602 Wilbur St.  
 Cypress, CA 90630  
 (714) 869-4000 Fax (714) 869-7030  
 info@almegaenv.com  
 Contact: Neal Conroy

**PO #** 10562

**Turnaround Time**  
 Standard: X  
 Other:  
 Rush:  
 Depends on # of Samples  
 5 - 10 days  
 3 - 7 days

Unit 1: In( )	Unit 2: In( )	Unit 3: Out	Project Manager: Sample Date	Sample Time	Sample Identification	Description	Type of Sample		ANALYSIS REQUESTED		Return or Disposal REMARKS	Turnaround Time
							Location	Container	CA 408	CA 409		
5/22/09 00:30			Neal Conroy		10562-M436-FB-Fiber	Fiber	X	1	X			
					10562-M436-FB-18M33	18M33	X	1	X			
					56502-M436-FB-18M33-CO	18M33-CO	X	1	X			

**Received by:** N Conroy  
 Date: 5/22/09 Time: 18:15

**Refined by:** J Sandstrom  
 Date: 5/28/09 Time: 10:30

**Received by:** J Sandstrom  
 Date: 5/28/09 Time: 18:15

**Refined by:** J Sandstrom  
 Date: 5/28/09 Time: 18:15

**Received by:** J Sandstrom  
 Date: 6/18/09 Time: 06:15

**Received by:** J Sandstrom  
 Date: 6/18/09 Time: 18:15

**APPENDIX C4**  
**O<sub>2</sub>/CO<sub>2</sub> RESULTS – FIELD & LABORATORY DATA**

**LABORATORY REPORT**  
Carbon Dioxide & Oxygen by TCD  
by Modified SCAQMD Method 25.3 (TCA/FID)

Client: AQMD  
Project No.: c10562  
Unit Tested: Facility A  
Sampling Date: 21-May-19  
Analyzed Date: 22-May-19  
Lab No.: A 053

Client Sample ID	Lab ID	Almega Sample ID	CO <sub>2</sub> % v/v by TCD	O <sub>2</sub> % v/v by TCD
		Tank		
<b>Facility A</b>				
Tnk11 - Inlet (I) - R1	A 053 - 01	11	ND	20.0
Tnk50 - Inlet (O) - R1	A 053 - 02	50	ND	20.1
Tnk30 - Outlet - R1	A 053 - 03	30	ND	16.4
Detection Limit			0.3	0.3

Suspected leak outlet-R1 not used, default ambient O<sub>2</sub>/CO<sub>2</sub> used.

\* NOTE - the BIAS FACTOR (of 1.086) is NOT applied in these results.

ND=Not Detected

TGMNEO concentration values are reported in ppm (v/v) as Methane (carbon#1).

The sample cylinder is analyzed for NMNEO, CO, CH<sub>4</sub>, CO<sub>2</sub> and C<sub>2</sub>H<sub>6</sub>. It is then directed to a separation column where all heavy organics (C<sub>3</sub>+) separate from the light organics (CO, CO<sub>2</sub>, CH<sub>4</sub> and C<sub>2</sub>H<sub>6</sub>). The light organics are then passed through a reduction catalyst to convert CO and CO<sub>2</sub> to CH<sub>4</sub>, and are then directed to a FID for detection and quantification. The heavy organics are backflushed off the holding column, passed through an oxidation catalyst, which convert all organics to CO<sub>2</sub>, then through a reduction catalyst to convert CO<sub>2</sub> to CH<sub>4</sub> and then to a FID for detection and quantification.

Reviewed by: DW

## CALCULATIONS



**Client:** AQMD  
**Project No.:** c10562  
**Unit Tested:** Facility A  
**Sampling Date:** 21-May-19  
**Date tested:** 22-May-19

Lab No.: A 053

Parameter	Symbol	Units	Run #1	Run #2
Sample ID			Tnk11 - Inlet (I) - R1	Tnk50 - Inlet (O) - R1
Lab ID			A 053 - 01	A 053 - 02
<u>Sample Tank</u>				
Tank No			11	50
Sample Tank Volume	$V_T$	L	12.095	12.050
Barometric Pressure	$P_b$	mm Hg	763	763
Pre-test Pressure	$P_{T1}$	mm Hg (abs)	2.00	2.00
Pre-test Temperature	$t_{T1}$	°C	21	21
Abs. Pre-test Temperature	$T_{T1}$	°K	294	294
Post-test Pressure	$P_{TS}$	mm Hg (abs)	476	580
Post-test Temperature	$t_{TS}$	°C	21	21
Abs. Post-test Temperature	$c$	°K	294	294
Final Pressure	$P_{TF}$	mm Hg (abs)	912	914
Abs. Final Temperature	$T_{TF}$	°K	293	293
Dilution Factor	$DF_T$		1.93	1.59
Sample Volume	$V_s$	L	7.408	9.000

**Calculations**

$$V_s = k_1 * V_T * (P_{TS}/T_{TS} - P_{T1}/T_{T1})$$

$$k_1 = (273 + 15.56) / 760 = 0.3799$$

$$C_{SAT} = DF * C_{SA}$$

$$C_{COF} = DF * C_{CO}$$

$$DF = (P_{TF}/T_{TF}) / (P_{TS}/T_{TS} - P_{T1}/T_{T1})$$

### CALCULATIONS

Client:	AQMD	Lab No.:
Project No.:	c10562	A 053
Unit Tested:	Facility A	
Sampling Date:	21-May-19	
Date tested:	22-May-19	

Parameter	Symbol	Units	Run #3
Sample ID			Tnk30 - Outlet - R1
Lab ID			A 053 - 03
<u>Sample Tank</u>			
Tank No			30
Sample Tank Volume	$V_T$	L	12.000
Barometric Pressure	$P_b$	mm Hg	763
Pre-test Pressure	$P_{T1}$	mm Hg (abs)	2.00
Pre-test Temperature	$t_{T1}$	°C	21
Abs. Pre-test Temperature	$T_{T1}$	°K	294
Post-test Pressure	$P_{TS}$	mm Hg (abs)	72
Post-test Temperature	$t_{TS}$	°C	21
Abs. Post-test Temperature	$T_{TS}$	°K	294
Final Pressure	$P_{TF}$	mm Hg (abs)	920
Abs. Final Temperature	$T_{TF}$	°K	293
Dilution Factor	$DF_T$		13.19

Sample Volume	$V_s$	L	1.085
---------------	-------	---	-------

#### Calculations

$$V_s = k_i \cdot V_T \cdot (P_{TS}/T_{TS} - P_{T1}/T_{T1})$$

$$k_i = (273 + 15.56) / 760 = 0.3799$$

$$C_{SAT} = DF \cdot C_{SA}$$

$$C_{COT} = DF \cdot C_{CO}$$

$$DF = (P_{TF} \cdot T_{TF}) / (P_{TS} \cdot T_{TS} + P_{T1} \cdot T_{T1})$$



QA/QC SUMMARY  
(Repeat Analysis)



Client Project No.: c10562  
 Sampling Date: 21-May-19  
 Run #1

Lab No.: A 053  
 Analyzed Date: 22-May-19

Analyte	Sample ID	Area Count #1	Area Count #2	Area % diff (±20%)	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
<b>Tank Analysis</b>								
CO2*	A 053 - 01	ND	ND	ND	ND	ND	ND	ND
O2*	A 053 - 01	1959779	1985721	-1.32	10.3	10.4	10.3	-1.32

Run #2

Analyte	Sample ID	Area Count #1	Area Count #2	Area Count #3	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
<b>Tank Analysis</b>								
CO2*	A 053 - 02	ND	ND	ND	ND	ND	ND	ND
O2 *	A 053 - 02	2420149	2398562	0.89	12.7	12.6	12.6	0.90

\* - by GC/TCD

$$\text{Conc}_{\text{CO}} \text{ in tank} = \text{MeanConc}_{\text{CO}} * \text{DF}$$

$$\text{Conc}_{\text{CO}_2} \text{ in tank} = \text{MeanConc}_{\text{CO}_2} * \text{DF}$$

$$\text{Conc}_{\text{O}_2} \text{ in tank} = \text{MeanConc}_{\text{O}_2} * \text{DF}$$

Li# A053

Page \_\_\_ of \_\_\_



### CHAIN OF CUSTODY

### RECORDS

INVOICE TO:		REPORT TO:		PO #		Turnaround Time	
ALMEGA Environmental & Technical Services		ALMEGA Environmental & Technical Services		Standard: <input checked="" type="checkbox"/> Other: _____		Rush: _____	
10802 Walker St.		10802 Walker St.		Depends on # of Samples		5 - 10 days _____	
Cypress, CA 90630		Cypress, CA 90630		3 - 7 days _____		Return or Dispose	
(714) 889-4000 Fax (714) 889-7030		(714) 889-4000 Fax (714) 889-7030		lab@almegaenv.com		REMARKS	
ATTN:		Contact:		[Redacted]			
Client: AgMD Facility A		Location:		ANALYSIS REQUESTED			
Unit Information:		Lab Sample #		Type Of Sample		No of Containers	
		AG13		LIQUID GAS SOLID		1	
Sample Identification		-01					
Tank 11 - Inlet (E) - R1		-02					
Tank 50 - Inlet (O) - R1		-03					
Tank 30 - Outlet - R1							
Sample Date		Sample Time		Received by:		Time	
5/21/19		12:16		Date: 5/21/19		Time: 19:15	
13:16		13:15		Received by:		Time	
12:15		13:15		Date: 5/22/19		Time: 5:02	
13:15				Received by:		Time	
Relinquished by: N Conroy		Relinquished by:		Date:		Time:	
Date: 5/21/19		Date:		Date:		Date:	
Time: 19:15		Time:		Time:		Time:	
Relinquished by:		Relinquished by:		Relinquished by:		Relinquished by:	
Date:		Date:		Date:		Date:	
Time:		Time:		Time:		Time:	

Standard Receipt  
Sample LOG in Checklist

Project No: C10562  
~~616470~~

Method: 010.1

Lab ID: A053

Sampling Date: 5/21, 5/22, 5/23

Location: AQMD - A Int: \_\_\_\_\_

Date & Time Rc'd: 5/22/9 9:02  
5/23/9 8:42 5/24/9 8:15

Location: LAB Int: DW

Arrived By: (circle) FedEx UPS Drop Off (Int) DW Other \_\_\_\_\_

Condition of Package(s): (comment): OK // Package Type: Box Cooler Other: /

Number of Sample Container(s): 3, 3, 3, 9 Correct Containers (per Method): (Y) N //

Preservation: (circle) ICE DryICE ICEPacks (None) //

Sample Conditions:

Sample Temp (C): 21 //

Ambient Temp (C): 21 //

Sample Temp (C): \_\_\_\_\_

Filter Condition: OK

PH: \_\_\_\_\_

Components Sealed: (Y) N //

Sample Recovery Completed On: (date & time) \_\_\_\_\_

Recovered In: (circle) (Field) Lab Other //

Silica Gel Condition: \_\_\_\_\_

Tedlar Bags -

Condensation: Y N

Comments:

Container(s) Requested: Glass \_\_\_\_\_ Plastic \_\_\_\_\_

Additional Comments:

**CHROMATOGRAM  
TEST SAMPLES**

13.793

15.66

A053

-01

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 135

FILE METHOD 0 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.93	8185348			35.5692	
2	13.793	1959779			8.5162	
3	15.66	12867348	V		55.9147	
TOTAL		23012474			100	

3.926

13.807

15.678

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 136

FILE METHOD 0 41


PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.926	8169617			35.2455	
2	13.807	1985721			8.5668	
3	15.678	13023824	V		56.1876	
TOTAL		23179160			100	

A053  
-01  
JP

047

223-C

Almaga ENVIRONMENTAL




A053  
-02

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 137

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.943	8179695			35.2608	
2	13.811	2420149			10.4327	
3	15.7	12597873	Y		54.3065	
TOTAL		23197716			100	



A053  
-02  
dmp

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 138

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.936	8163036			35.3284	
2	13.778	2398562			10.3806	
3	15.663	12544587	Y		54.291	
TOTAL		23106184			100	



3.94  
**Almega**  
 ENVIRONMENTAL  
 15.508


A053  
 03

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
 CHANNEL NO 1  
 SAMPLE NO 0  
 REPORT NO 139

FILE 0  
 METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.94	7938802			35.2892	
2	13.746	237054			1.0537	
3	15.508	14320518	V		63.657	
TOTAL		22496374			100	



A053  
 -03  
 040

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
 CHANNEL NO 1  
 SAMPLE NO 0  
 REPORT NO 140

FILE 0  
 METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.938	8032626			35.5329	
2	13.784	237504			1.0506	
3	15.552	14336059	V		63.4165	
TOTAL		22606188			100	

043  
 223-02037-01  
 170615  
 Shimadzu

QAQC




*Handwritten signature*

044

223-02037-01

170615

Skimmed




CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
 CHANNEL NO 1  
 SAMPLE NO 0  
 REPORT NO 128

FILE 0  
 METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.93	8306954			35.2162	
2	13.884	3879877			16.4448	
3	15.891	11402443	V		48.339	
TOTAL		23588472			100	




CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
 CHANNEL NO 1  
 SAMPLE NO 0  
 REPORT NO 129

FILE 0  
 METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.741	8290768			35.221	
2	6.433	7086			0.0301	
3	13.681	3887198			16.5137	
4	15.677	11354206	V		48.2352	
TOTAL		23539256			100	



CHROMATOGRAM 1 MEMORIZED


C-R5A CHROMATOPAC  
CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 130

FILE 0  
METHOD 41

*18/9*  
*9/9*

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.903	6775490			33.5948	
2	6.012	986494			4.8913	
3	13.809	1654429			8.2031	
4	15.83	10751828	V		53.3107	

TOTAL 20168240 100



CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 131

FILE 0  
METHOD 41

*18/9*

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.893	6801136			33.4508	
2	6.001	992409			4.8811	
3	13.792	1668812			8.2079	
4	15.858	10869372	V		53.4601	


TOTAL 20331728 100

045

223-02037-01

170615

Skinnadzu



*18/9*

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1

SAMPLE NO 0

REPORT NO 141

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.886	6798158			33.6424	
2	5.99	993430			4.9162	
3	13.777	1655096			8.1987	
4	15.787	10760414	✓		53.2507	
TOTAL		20207096			100	

## TANK PREPARATION

**TANK PREPARATIONS**

Client: AQMD Lab No.: A 053  
 Project No.: c10562  
 Unit Tested: Facility A  
 Sampling Date: 21-May-19  
 Date pressurized: 22-May-19

Tank ID	Sample ID	Pre-test pressure mm Hg		Post-test pressure mm Hg	Final Pressure	Comments
		1	2			
11	A 053 - 01	-758	-758	-284	152	Run #1
50	A 053 - 02	-758	-758	-180 *	154	Run #2
30	A 053 - 03	-758	-758	-688	160	Run #3

\* - Post -test Pressure is less then 200 mm Hg.





VOC FIELD DATA SHEET - SCAQMD METHOD 10.1

Date: 5/21/19 Test No.: \_\_\_\_\_  
 Client: Facility 4 Barometric Pressure (in. Hg): 29.83  
 Unit: Inlet Outside Pretest Leak Check: \_\_\_\_\_  
 Operator Name: MN A: x B: \_\_\_\_\_  
 Fuel: stack gas Post-test Leak check: \_\_\_\_\_  
 Location: Inlet Outside A: y B: \_\_\_\_\_

SAMPLE A

SAMPLE B

		Tank # <u>50</u>	Trap # <u>1643</u>
		Control ID: <u>  </u>	
Time 24 Hours	Start Time	Flow ml/min.	Vacuum inch Hg
0	1210	3.5	29
10			25
20			21
30			17
40			<del>18</del>
50		End Time	
60	1310		8

		Tank # _____	Trap # _____
		Control ID: _____	
Flow ml/min.	Vacuum inch Hg		

**APPENDIX C5**

**SCAQMD METHODS 1.1-4.1 – INLET 3 FLOWS**



### FLOWS DATA AND CALCULATIONS

Plant: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Inlet 3 Flows

Test Date(s): 05/21-23/2019  
 Operator: NC  
 Entered by: TG  
 Checked by: CF

DATA ENTRY	Symbol	units	05/21/19	05/22/19	05/23/19
			DATA	DATA	DATA
Run Number			Run 1	Run 2	Run 3
Stack Dimensions: Round Stack Diameter	Ds	in.			
Rectangular Stack, Length	L	in.	21	21	21
Width	W	in.	25	25	25
Standard Temperature	Tstd	°F	68	68	68
Average Stack Temperature (measured)	Fs	°F	100.4	72.1	92.7
Standard Pressure	Pstd	in.Hg	29.92	29.92	29.92
Barometric Pressure	Pbar	in.Hg	29.83	29.83	29.62
Stack Static Pressure	Pg	in.WC	5.7	-13.0	-13.0
Average RMS Velocity Head (Delta-P)	dP	in.WC	0.857	0.841	0.912
Pitot Coefficient	Cp	—	0.84	0.84	0.84
Stack Gas: Oxygen Content *	O2,m	%	20.9	20.9	20.9
Carbon Dioxide Content *	CO2,m	%	0.04	0.04	0.04
<b>CALCULATED DATA</b>					
Stack Area (round): $As = \pi/576 \cdot ds^2$ (rectangular): $As = L \cdot W/144$	As	sq.ft.	3.65	3.65	3.65
Absolute Stack Temperature: $Ts = Fs + 460$	Ts	°R	560.4	532.1	552.7
Standard Temperature: $Tstdr = Tstd + 460$	Tstdr	°R	528.0	528.0	528.0
Moisture Fraction: $Bws = VwStd / (VmStd + VwStd)$	Bws	—	0.020	0.020	0.020
Stack Gas MW, Dry Basis: $Md = 0.32 \cdot O_{2,m} + 0.44 \cdot CO_{2,m} + 0.28 \cdot (100 - O_{2,m} - CO_{2,m})$	Md	g/mole	28.84	28.84	28.84
Stack Gas MW, Wet Basis: $Mw = Md \cdot (1 - Bws) + 18 \cdot Bws$	Mw	g/mole	28.63	28.63	28.63
Stack Pressure: $Ps = Pbar + Pg/13.6$	Ps	in.Hg	30.25	28.87	28.66
Stack Gas Velocity, measured $vs = 85.49 \cdot Cp \cdot \sqrt{(dP \cdot Ts / Ps / Mw)}$ $vm = 0.3048 \text{ m/ft} \cdot vs$	vs vsm	ft/s m/s	53.49 16.30	52.84 16.10	56.27 17.15
Stack Gas Volumetric Flow Rate: $Q = 60 \cdot vs \cdot As$	Q	acfm	11,701	11,558	12,310
Stack Gas Volumetric Flow Rate, corrected: $Qsd = Q \cdot (1 - Bws) \cdot (Ps / Ts) \cdot (Tstdr / Pstd)$ $Qsdm = Qsd / 35.315$	Qsd Qsdm	dscfm dscmm	10,923 309.3	10,846 307.1	11,041 312.7

\* Ambient level O2/CO2 was used for gas density calculations.

### FLOWS DATA AND CALCULATIONS

Plant: AQMD Facility A                      Run No.: 1  
 City: ██████████ CA                      Test Date: 05/21/19  
 Source: Baghouse  
 Location: Inlet 3 Flows

point	Stack Temp (°F)		Velocity Head (in.WC)	
	Fs	sqrt (Fs)	dP	sqrt (dP)
A-8	100.0	10.0	2.44	1.56
7	99.8	10.0	2.63	1.62
6	99.8	10.0	2.46	1.57
5	99.4	10.0	2.39	1.55
4	99.4	10.0	2.33	1.53
3	99.4	10.0	2.45	1.57
2	99.7	10.0	2.35	1.53
1	100.7	10.0	2.41	1.55
B-8	100.6	10.0	0.63	0.79
7	101.1	10.1	1.02	1.01
6	101.2	10.1	0.97	0.98
5	101.3	10.1	1.12	1.06
4	100.9	10.0	1.11	1.05
3	101.3	10.1	1.01	1.00
2	101.3	10.1	1.07	1.03
1	101.2	10.1	0.860	0.93
C-8	100.3	10.0	0.070	0.26
7	100.5	10.0	0.140	0.37
6	100.3	10.0	0.100	0.32
5	100.2	10.0	0.020	0.14
4	100.4	10.0	0.020	0.14
3	100.5	10.0	0.020	0.14
2	100.6	10.0	0.040	0.20
1	100.4	10.0	0.090	0.30
<b>Average:</b>	<b>100.4</b>		<b>0.8573</b>	<b>0.926</b>

### FLOWS DATA AND CALCULATIONS

Plant: AQMD Facility A                      Run No.: 2  
 City: ██████████ CA                      Test Date: 05/22/19  
 Source: Baghouse  
 Location: Inlet 3 Flows

point	Stack Temp (°F)		Velocity Head (in.WC)	
	Fs	sqrt (Fs)	dP	sqrt (dP)
A-1	72.4	8.5	1.97	1.40
2	72.3	8.5	2.40	1.55
3	72.3	8.5	2.26	1.50
4	71.7	8.5	2.22	1.49
5	76.1	8.7	2.24	1.50
6	69.9	8.4	2.29	1.51
7	69.2	8.3	2.30	1.52
8	68.5	8.3	2.35	1.53
B-1	71.9	8.5	0.74	0.86
2	72.3	8.5	0.97	0.98
3	72.3	8.5	0.95	0.97
4	72.4	8.5	0.94	0.97
5	72.9	8.5	1.21	1.10
6	72.6	8.5	1.20	1.10
7	72.4	8.5	1.12	1.06
8	72.3	8.5	0.84	0.92
C-1	72.9	8.5	0.09	0.30
2	72.6	8.5	0.03	0.17
3	72.5	8.5	0.025	0.16
4	73.3	8.6	0.03	0.17
5	72.3	8.5	0.03	0.17
6	72.1	8.5	0.08	0.28
7	72.1	8.5	0.19	0.44
8	72.2	8.5	0.12	0.35
<b>Average:</b>	<b>72.1</b>		<b>0.8409</b>	

### FLOWS DATA AND CALCULATIONS

Plant: AQMD Facility A                      Run No.: 3  
 City: ██████████ CA                      Test Date: 05/23/19  
 Source: Baghouse  
 Location: Inlet 3 Flows

point	Stack Temp (°F)		Velocity Head (in.WC)	
	Fs	sqrt (Fs)	dP	sqrt (dP)
A-1	93.4	9.7	2.05	1.43
2	93.8	9.7	2.09	1.45
3	93.7	9.7	2.82	1.68
4	94.2	9.7	2.63	1.62
5	95.1	9.8	2.60	1.61
6	94.9	9.7	2.34	1.53
7	94.9	9.7	2.42	1.56
8	94.4	9.7	2.40	1.55
B-1	94.4	9.7	1.01	1.00
2	94.5	9.7	1.26	1.12
3	93.3	9.7	1.17	1.08
4	92.7	9.6	1.20	1.10
5	92.6	9.6	1.19	1.09
6	92.3	9.6	1.11	1.05
7	92.0	9.6	1.15	1.07
8	91.8	9.6	0.88	0.94
C-1	90.7	9.5	0.16	0.40
2	91.0	9.5	0.11	0.33
3	91.0	9.5	0.05	0.22
4	90.9	9.5	0.04	0.20
5	90.7	9.5	0.03	0.17
6	90.6	9.5	0.03	0.17
7	90.7	9.5	0.08	0.28
8	90.6	9.5	0.06	0.24
<b>Average:</b>	<b>92.7</b>		<b>0.912</b>	


### Method 1 Rectangular Stack

Width	Length	"A" Distance	"B" Distance	# of Ports	# of Points	# of Points/Port
25.0	21.0	>12.0	>46.0	3	24	8

Equivalent Diameter =	22.8
"A" Equivalent:	0.53
"B" Equivalent:	2.02

Port Distance
0

Port Corrected	
1	1.31
2	3.94
3	6.56
4	9.19
5	11.81
6	14.44
7	17.06
8	19.69
9	
10	



Traverse Points:	3	4	5	6	8	10
1	1.31	1.31	1.31	1.31	1.31	1.31
2	3.94	3.94	3.94	3.94	3.94	3.94
3	6.56	6.56	6.56	6.56	6.56	6.56
4		9.19	9.19	9.19	9.19	9.19
5			11.81	11.81	11.81	11.81
6				14.44	14.44	14.44
7					17.06	17.06
8					19.69	19.69
9						22.31
10						24.94

↳ TRANSFERRED FROM RAW DATA SHEET

df

SCAQMD METHODS 2-4

Run #:	1	Pitot ID:		Impinger:	Initial	Final	Net	Pitot Leak Check	
Date:	5/22/19	Pitot Coeff.:		Water 1:				Initial:	
Client:		Meter Box #:		Water 2:				Final:	
Unit:	EULET 3	Meter @ Dh:		Blank:				Meter Box Leak Check	
Operator:		Meter Y:		Sl. Gel:				Rate	"HG
Stack Dia:		TC #:		H2O Gain =			Initial:		
Amb. Press:		Start Time:		Pressure Type/Range			Final:		
Static Press:	5.7	Stop Time:							

Time (Minute)	Meter Volume (scf)	Pump Vac (inch Hg)	Meter Temperatures		Set Delta H (Inch H2O)	Impinger Temp. (F)	Sample Point #	Port 1:		Port 2: Delta P (H2O)	Port 2: Stack Temp. (F)	Port 2: Delta P (H2O)	Port 2: Stack Temp. (F)	Port 2: Delta P (H2O)	Port 2: Stack Temp. (F)	Port 2: Delta P (H2O)	Port 2: Stack Temp. (F)	Port 2: Delta P (H2O)	Port 2: Stack Temp. (F)	
			Inlet (F)	Outlet (F)				Delta P (H2O)	Stack Temp. (F)											
							1	2.44	100.0				6							
							2	2.63	99.8				6							
							3	2.46	99.8				7							
							4	2.39	99.4				4							
							5	2.33	99.4				3							
							6	2.45	99.4				2							
							7	2.35	99.7				4							
							8	2.41	100.7				3							
							1	0.63	100.6				-2							
							2	1.02	101.1				-1							
							3	0.97	101.2				-2							
							4	1.17	101.3				-4							
							5	1.11	100.9				-2							
							6	1.01	101.3				-1							
							7	1.07	101.3				1							
							8	0.86	101.2				0							
							1	.07	100.3				-10							
							2	.14	100.5				-8							
							3	.10	100.3				10							
							4	.07	100.2				6							
							5	.07	100.4				6							
							6	.07	100.5				6							
							7	.04	100.6				0							
							8	.09	100.4				0							

STAT: 5.7

**NOZZLE CALIBRATION FORM**

NOZZLE ID #:

CLIENT:

CALIPER ID:

DATE:

CALIBRATOR:

LOCATION:

SIGNATURE:

A	8	2.63	99.8	6
	7	2.46	99.8	7
	6	2.39	99.4	4
	5	2.38	99.4	3
	4	2.45	99.4	2
	3	2.35	99.7	4
	2	2.41	100.7	3
	1			


Measured Diameter A: \_\_\_\_\_ inch

Measured Diameter B: \_\_\_\_\_ inch

Measured Diameter C: \_\_\_\_\_ inch

Average: \_\_\_\_\_ inch

B	8	0.63	100.6	-2
	7	1.02	101.1	-1
	6	0.97	101.2	-2
	5	1.12	101.3	-4
	4	1.11	100.9	-2
	3	1.01	101.3	-1
	2	1.07	101.3	1
	1	0.86	101.2	0
C	8	0.07	100.3	-10
	7	0.14	100.5	-8
	6	0.10	100.3	10
	5	0.02	100.2	0
	4	0.02	100.4	0
	3	0.02	100.5	0
	2	0.04	100.6	0
	1	0.04	100.4	0



Inside Diameter

Is the Nozzle Free from Nicks, Dents, or Corrosion?

Yes \_\_\_\_\_

No \_\_\_\_\_

If "No", please describe deviations below:

Nozzle Deviations (if any):

SCAQMD METHODS 2-4

Run #: <u>Raw</u>	Pilot ID:	Impinger	Initial	Final	Net	Pilot Leak Check	
Date: <u>5/22/19</u>	Pilot Coeff.:	Water 1:				Initial:	
Client:	Meter Box #:	Water 2:				Final:	
Unit: <u>Inlet 3</u>	Meter @ Dh:	Blank:				Meter Box Leak Check	
Operator:	Meter Y:	Sil. Gel:	H2O Gain =			Rate	"HG
Stack Dia:	TC #:		Pressure Type/Range			Initial:	
Amb. Press:	Start Time:					Final:	
Static Press: <u>5.7</u>	Stop Time:						

Time (Minute)	Meter Volume (scf)	Pump Vac (Inch Hg)	Meter Temperatures		Set Delta H (Inch H2O)	Impinger Temp. (F)	Sample Point #	Port 1:		Port 2:		Pilot ID:	
			Inlet (F)	Outlet (F)				Delta P (H2O)	Stack Temp. (F)	Delta P (H2O)	Stack Temp. (F)	Cyclonic Flow (H2O)	TE Cooler Temp. (F)
							1	1.97	72.4				
							2	2.40	72.3				
							3	2.26	72.3				
							4	2.22	72.7				
							5	2.24	72.1				
							6	2.29	69.9				
							7	2.3	69.2				
							8	2.35	68.5				
							1	.74	71.9				
							2	.97	72.3				
							3	.95	72.3				
							4	.14	72.4				
							5	1.21	72.9				
							6	1.2	72.6				
							7	1.12	72.4				
							8	.84	72.3				
							1	.09	72.9				
							2	.03	72.6				
							3	.025	72.5				
							4	.03	73.3				
							5	.03	72.3				
							6	.08	72.1				
							7	.19	72.1				
							8	.12	72.2				



SCAQMD METHODS 2-4

Run #: <u>3</u>	Pilot ID: _____	Impinger	Initial	Final	Net	Pilot Leak Check	
Date: <u>5/22/19</u>	Pilot Coeff.: _____	Water 1:				Initial:	
Client: _____	Meter Box #: _____	Water 2:				Final:	
Unit: <u>Exhaust 3</u>	Meter @ Dh: _____	Blank:				Meter Box Leak Check	
Operator: _____	Meter Y: _____	Sil. Gel:				Rate	"HG
Stack Dia: _____	TC #: _____	H2O Gain = _____			Initial:		
Amb. Press: _____	Start Time: _____	Pressure Type/Range _____			Final:		
Static Press: <u>5.7</u>	Stop Time: _____						

Time (Minute)	Meter Volume (scf)	Pump Vac (Inch Hg)	Meter Temperature		Set Delta H (Inch H2O)	Impinger Temp (F)	Sample Point #	Port 1:		Port 2:		Pilot ID:	
			Inlet (F)	Outlet (F)				Delta P (H2O)	Stack Temp (F)	Delta P (H2O)	Stack Temp (F)	Cyclonic Flow (H2O)	TE Cooler Temp (F)
							1	2.65	93.9				
							2	2.94	93.8				
							3	2.82	93.7				
							4	2.63	94.2				
							5	2.60	95.1				
							6	2.34	94.9				
							7	2.42	94.9				
							8	2.40	94.4				
							1	1.01	94.4				
							2	1.26	94.5				
							3	1.17	93.7				
							4	1.20	92.7				
							5	1.19	92.6				
							6	1.11	92.3				
							7	1.15	92				
							8	.89	91.8				
							1	.16	90.7				
							2	.11	91				
							3	.05	91				
							4	.04	90.9				
							5	.03	90.7				
							6	.03	90.6				
							7	.08	90.7				
							8	.06	90.6				

**APPENDIX C5**

**PRE-FLOWS FOR**  
**EXHAUST FLOW ISOKINETIC CALCULATIONS**

**RUN 1**

# Baghouse Outlet Differential Pressure Calculation

5/21/2019

## Calculation on Inlet Baghouse Velocity

Inlet 1 (Upstream of Baghouse)

Inlet 2

Inlet - HEPA Baghouse

Area - HEPA Baghouse \*

Velocity - HEPA Baghouse

Symbol	Unit	Value	Formula
In 1	acfm	40,682	--
In 2	acfm	11,665	--
In <sub>Bag</sub>	acfm	52,347	--
A <sub>Bag</sub>	in <sup>2</sup>	14,168	$\ln_{Bag} = \ln 1 + \ln 2$
Vel <sub>Bag</sub>	ft/sec	8.867	$Vel_{Bag} = \text{Inlet}_{Bag} \text{ (acfm)} * (144 \text{ in}^2/\text{ft}^2) * (\text{min}/60 \text{ sec}) * (1/A_{Bag} \text{ in}^2)$

## Calculation of Wet Stack Gas Molecular Weight

Dry Stack Gas Molecular Weight

where, O<sub>2</sub> = 20.5%; CO<sub>2</sub> = 0.05%; CO = 0 ppm; N<sub>2</sub> = 79.05 %

Moisture

Dry Mole Fraction

Wet Stack Gas Molecular Weight

MW <sub>dry</sub>	lb/lb-mole	28.72	$MW_{dry} = 0.44 * CO_2\% + 0.32 * O_2\% + 0.28 * CO_{ppm} + 0.28 * N_2\%$
Moist	% H <sub>2</sub> O	2	Assumed Saturated Moisture
Mole <sub>Fract</sub>	decimal	0.98	$Mole_{Fract} = (1 - \{\text{Moist}/100\})$
MW <sub>wet</sub>	lb/lb-mole	28.506	$MW_{wet} = MW_{dry} * Mole_{Fract} + (18 * \{\text{Moist}/100\})$

## Calculation on Inlet Baghouse Pressure

Velocity - HEPA Baghouse

Stack Temperature

Absolute Stack Pressure

Wet Stack Gas Molecular Weight

Pitot Correlation Coefficient

Conversion Factor

Vel <sub>Bag</sub>	ft/sec	8.867	see above
T <sub>stk</sub>	°F	72	--
P <sub>Abs</sub>	in Hg	29.83	--
MW <sub>wet</sub>	lb/lb-mole	28.506	see above
C <sub>p</sub>	--	0.84	--
C <sub>fact</sub>	--	85.49	--
<b>P<sub>Delta</sub></b>	<b>in H<sub>2</sub>O</b>	<b>0.0245</b>	$P_{Delta} = [Vel_{Bag} * 1/C_p * 1/C_{fact} * 1/((T_{stk} + 460)) / (P_{Abs} * MW_{wet})]^{0.5}^2$

\* See next page.

**STACK GAS MOISTURE AND FLOW RATE CALCULATIONS**

Test Date: 6/21/89  
 Facility: [REDACTED]  
 Location: [REDACTED] CA

Source: Inlet 1 (Upstream of Baghouse)

DATA ENTRY	Symbols	Units	RUN 1		
Stack Diameter	D	in.	36		
Length	L	in.			
Width	W	in.			
Barometric Pressure	Pbar	in. Hg.	29.83		
Static Pressure	Ps	in. H2O	-10.00		
Pitot Coefficient	Cp	none	0.84		
Meter Cal. Factor	Y	none	1.0000		
Standard Temperature	Tstd	deg. F	60		
Moisture Factor	K1	cu.ft./mL	.0464		
PT Factor	K2	R/in.Hg	17.38		
Velocity Head (dP)	(dP)	(in. H2O)	2.769		
Velocity Head (Sqrt dP)	Sqrt (dP)	Sqrt(in. H2O)	1.650		
Average Delta H	dH	in. H2O			
Gas Volume Collected	Vm	cf			
Stack Gas Temperature	Ts	deg. F	85.3		
Meter Temperature	Tm	deg. F			
%O2 in Stack Gas	%O2	%	20.50		
%CO2 in Stack Gas	%CO2	%	0.05		
Total Impinger Water	Ww	g			
CALCULATIONS					
	Symbols	Units	RUN 1	RUN 0	RUN 0
Stack Area	As	sq. ft.	7.07		
Stack Gas Temperature	Ts,r	deg. R	545		
Meter Temperature	Tm,r	deg. R	460		
Abs Stk Pressure	Pabs	in. Hg.	29.09		
Gas Vol. @ STD	Vmstd	dscf			
Vol. of Water Vapor	Vwstd	dscf			
Dry Mol. Wt.	Md	lb/lb-mol.	28.83		
Wet Mol. Wt.	Ms	lb/lb-mol.	28.61		
Average Velocity	Vs	ft/s	95.92		
Moisture Content	Bws	%	2.00		
Actual Stack Gas Flow Rate	Qa	acfm	40,682		
Dry Stack Gas Flow Rate	Qds	dscfm	36,970		
Wet Stack Gas Flow Rate	Qws	wscfm	37,724		
CALCULATIONS					
Abs Stk Pressure	Pabs	$Pabs = Pbar + (Ps/13.6)$			
Gas Vol. @ STD	Vmstd	$Vmstd = 17.64 Vm Y [Pbar + dH/13.6] / Tm$			
Vol. of Water Vapor	Vwstd	$Vwstd = 0.04707 Vh2o$			
Dry Mol. Wt.	Md	$Md = .44(\%CO2) + .32(\%O2) + .28[100 - (\%CO2 + \%O2)]$			
Wet Mol. Wt.	Ms	$Ms = Md [1 - (Bws/100)] + .18(Bws/100)$			



SCAQMD METHODS 2-4

Run #: <b>Flow</b>	Pitot ID: <b>3.4</b>	Impinger	Initial	Final	Net	Pilot Leak Check Initial: <table border="1"><tr><td></td><td></td></tr></table> Final: <table border="1"><tr><td></td><td></td></tr></table>				
Date: <b>5/20/19</b>	Pilot Coeff.: <b>0.84</b>	Water 1:								
Client: <b>ScagmD A</b>	Meter Box #: <b>HBA-B</b>	Water 2:				Meter Box Leak Check Rate: <table border="1"><tr><td></td><td></td></tr></table> *HG: <table border="1"><tr><td></td><td></td></tr></table>				
Unit: <b>Inlet outlet</b>	Meter @ Dh:	Blank:								
Operator: <b>MN</b>	Meter Y:	Sil. Gel:								
Stack Dia:	TC #:	H2O Gain =								
Amb. Press: <b>29.8</b>	Start Time:	Pressure Type/Range				Initial: <table border="1"><tr><td></td><td></td></tr></table>				
Static Press: <b>-0</b>	Stop Time:					Final: <table border="1"><tr><td></td><td></td></tr></table>				

Time (Minute)	Meter Volume (acf)	Pump Vac (Inch Hg)	Meter Temperature Inlet (F)	Meter Temperature Outlet (F)	Set Delta H (Inch H2O)	Impinger Temp. (F)	Sample Point #	Port 1: Delta P (H2O)	Stack Temp. (F)	Port 2: Delta P (H2O)	Stack Temp. (F)	Pitot ID: Cyclonic Flow (H2O)	TE Cooler Temp. (F)
A 12							12	2.4	90			-5	
							11	3.2	91			-6	
							10	3.5	92			-7	
							9	3.6	90			-6	
							8	3.3	90			-5	
							7	2.9	90			0	
							6	2.4	90			-7	
							5	2.8	90			+4	
							4	2.6	89			-6	
							3	1.8	87			-3	
							2	1.9	88			-5	
							1	1.9	88			+4	
5/20/19													
5/21/19													
							12	2.6	81				
							11	3.3	81				
							10	3.7	81				
							9	3.5	81				
							8	3.35	81				
							7	2.9	81				
							6	3.1	81				
							5	2.4	81				
							4	2.1	81				
							3	2.1	81				
							2	3.1	81				
							1	2.5	81				

STACK GAS MOISTURE AND FLOW RATE CALCULATIONS

Test Date: 4/23/09  
 Facility: [REDACTED]  
 Location: [REDACTED] CA

Source: Inlet 2

DATA ENTRY	Symbols	Units	RUN1
Stack Diameter	D	in.	
Length	L	in.	21
Width	W	in.	25
Barometric Pressure	Pbar	in. Hg.	29.83
Static Pressure	P <sub>s</sub>	in. H <sub>2</sub> O	5.70
Pitot Coefficient	C <sub>p</sub>	none	0.84
Meter Cal. Factor	Y	none	1.0000
Standard Temperature	Tstd	deg. F	60
Moisture Factor	K1	cu. ft./mL	.0464
PT Factor	K2	R/in.Hg	17.38
Velocity Head (dP)	(dP)	(in. H <sub>2</sub> O)	1.156
Velocity Head (Sqrt dP)	Sqrt(dP)	Sqrt(in. H <sub>2</sub> O)	0.926
Average Delta H	dH	in. H <sub>2</sub> O	
Gas Volume Collected	Vm	cf	
Stack Gas Temperature	Ts	deg. F	96.7
Meter Temperature	Tm	deg. F	
%O <sub>2</sub> in Stack Gas	%O <sub>2</sub>	%	20.50
%CO <sub>2</sub> in Stack Gas	%CO <sub>2</sub>	%	0.05
Total Impinger Water	W/w	g	0.0
<b>CALCULATIONS</b>			
Stack Area	As	sq. ft.	3.65
Stack Gas Temperature	T <sub>s,r</sub>	deg. R	557
Meter Temperature	T <sub>m,r</sub>	deg. R	460
Abs Sdk Pressure	Pabs	in. Hg.	30.25
Gas Vol. @ STD	Vmstd	scf	
Vol. of Water Vapor	Vwstd	scf	
Dry Mol. Wt.	Md	lb/lb-mol.	28.83
Wet Mol. Wt.	Ms	lb/lb-mol.	28.61
Average Velocity	Vs	ft/s	53.33
Moisture Content	Bws	%	2.00
Actual Stack Gas Flow Rate	Qa	scfm	11,865
Dry Stack Gas Flow Rate	Qds	scfm	10,830
Wet Stack Gas Flow Rate	Qws	wscfm	11,051
<b>CALCULATIONS</b>			
Abs Sdk Pressure	Pabs	Pabs=Pbar+(Ps/13.6)	
Gas Vol. @ STD	Vmstd	Vmstd=17.64VmY[(Pbar+dH/13.6)/Pm]	
Vol. of Water Vapor	Vwstd	Vwstd=0.04707 Vmstd	
Dry Mol. Wt.	Md	Md=44(%CO <sub>2</sub> )+32(%O <sub>2</sub> )+28(100-(%CO <sub>2</sub> +%O <sub>2</sub> ))	
Wet Mol. Wt.	Ms	Ms=Md[1-(Bws/100)]+18(Bws/100)	





**APPENDIX C5**

**PRE-FLOWS FOR**  
**EXHAUST FLOW ISOKINETIC CALCULATIONS**

**RUN 2**

# Baghouse Outlet Differential Pressure Calculation

5/22/2019

## Calculation on Inlet Baghouse Velocity

Inlet 1 (Upstream of Baghouse)

Inlet 2

Inlet - HEPA Baghouse

Area - HEPA Baghouse \*

Velocity - HEPA Baghouse

Symbol	Unit	Value	Formula
In 1	acfm	42,141	--
In 2	acfm	11,301	--
In <sub>Bag</sub>	acfm	53,442	In <sub>Bag</sub> = In 1 + In 2
A <sub>Bag</sub>	in <sup>2</sup>	14168	
Vel <sub>Bag</sub>	ft/sec	9.053	Vel <sub>Bag</sub> = Inlet <sub>Bag</sub> (acfm) * (144 in <sup>2</sup> /ft <sup>2</sup> ) * (min/60 sec) * (1/A <sub>Bag</sub> in <sup>2</sup> )

## Calculation of Wet Stack Gas Molecular Weight

Dry Stack Gas Molecular Weight

where, O2 = 20.5%; CO2 = 0.05%; CO = 0 ppm; N2 = 79.05 %

Moisture

Dry Mole Fraction

Wet Stack Gas Molecular Weight

MW <sub>dry</sub>	lb/lb-mole	28.72	MW <sub>dry</sub> = 0.44*CO <sub>2</sub> %+0.32*O <sub>2</sub> %+0.28*COppm+0.28*N <sub>2</sub> %
Moist	% H <sub>2</sub> O	2	Assumed Saturated Moisture
Mole <sub>Fract</sub>	decimal	0.98	Mole <sub>Fract</sub> = (1-{Moist/100})
MW <sub>wet</sub>	lb/lb-mole	28.506	MW <sub>wet</sub> = MW <sub>dry</sub> * Mole <sub>Fract</sub> + (18 * {Moist/100})

## Calculation on Inlet Baghouse Pressure

Velocity - HEPA Baghouse

Stack Temperature

Absolute Stack Pressure

Wet Stack Gas Molecular Weight

Pitot Correlation Coefficient

Conversion Factor

Differential Pressure

Vel <sub>Bag</sub>	ft/sec	9.053	see above
T <sub>stk</sub>	°F	75	--
P <sub>Abs</sub>	in Hg	29.8	--
MW <sub>wet</sub>	lb/lb-mole	28.506	see above
C <sub>p</sub>	--	0.84	--
C <sub>fact</sub>	--	85.49	--
P <sub>Delta</sub>	In H <sub>2</sub> O	0.0256	P <sub>Delta</sub> = [Vel <sub>Bag</sub> * 1/C <sub>p</sub> * 1/C <sub>fact</sub> * 1/((T <sub>stk</sub> +460)/(P <sub>Abs</sub> * MW <sub>wet</sub> ))] <sup>0.5</sup> ^2

\* See next page.

**STACK GAS MOISTURE AND FLOW RATE CALCULATIONS**

Test Date: 5/22/09

Facility: [REDACTED]

Location: [REDACTED] CA

Source: Inlet 1 (Upstream of Baghouse)

DATA ENTRY	Symbols	Units	RUN 1		
Stack Diameter	D	in.	36		
Length	L	in.			
Width	W	in.			
Barometric Pressure	Pbar	in. Hg.	29.80		
Static Pressure	Ps	in. H2O	-15.00		
Pitot Coefficient	Cp	none	0.84		
Meter Cal. Factor	Y	none	1.0000		
Standard Temperature	Tstd	deg. F	60		
Moisture Factor	K1	cu.ft./mL	.0464		
PT Factor	K2	R/in.Hg	17.38		
Velocity Head (dP)	(dP)	(in. H2O)	2.958		
Velocity Head (Sqrt dP)	Sqrt (dP)	Sqrt(in. H2O)	1.706		
Average Delta H	dH	in. H2O			
Gas Volume Collected	Vm	cf			
Stack Gas Temperature	Ts	deg. F	80.3		
Meter Temperature	Tm	deg. F			
%O2 in Stack Gas	%O2	%	20.50		
%CO2 in Stack Gas	%CO2	%	0.05		
Total Impinger Water	Ww	g			
<b>CALCULATIONS</b>					
	Symbols	Units	RUN 1	RUN 0	RUN 0
Stack Area	As	sq. ft.	7.07		
Stack Gas Temperature	Ts,r	deg. R	540		
Meter Temperature	Tm,r	deg. R	460		
Abs Stk Pressure	Pabs	in. Hg.	28.70		
Gas Vol. @ STD	Vmstd	dsf			
Vol. of Water Vapor	Vwstd	dsf			
Dry Mol. Wt.	Md	lb/lb-mol.	28.83		
Wet Mol. Wt.	Ms	lb/lb-mol.	28.61		
Average Velocity	Vs	ft/s	99.36		
Moisture Content	Bws	%	2.00		
Actual Stack Gas Flow Rate	Qa	acfm	42,141		
Dry Stack Gas Flow Rate	Qds	dsfcm	38,128		
Wet Stack Gas Flow Rate	Qws	wscfm	38,906		
<b>CALCULATIONS</b>					
Abs Stk Pressure	Pabs	$Pabs = Pbar + (Ps/13.6)$			
Gas Vol. @ STD	Vmstd	$Vmstd = 17.64 Vm Y [Pbar + dH/13.6] / Tm$			
Vol. of Water Vapor	Vwstd	$Vwstd = 0.04707 Vh2o$			
Dry Mol. Wt.	Md	$Md = .44(\%CO2) + .32(\%O2) + .28[100 - (\%CO2 + \%O2)]$			
Wet Mol. Wt.	Ms	$Ms = Md [1 - (Bws/100)] + 18(Bws/100)$			





STACK GAS MOISTURE AND FLOW RATE CALCULATIONS

Test Date: 5/22/19

Facility: [REDACTED]

Location: [REDACTED]

Source: Inlet 2

DATA ENTRY	Symbol	Units	RUN1
Stack Diameter	D	in.	21
Length	L	in.	25
Width	W	in.	29.80
Barometric Pressure	Pbar	in. Hg.	5.70
Static Pressure	Pst	in. H2O	0.84
Pitot Coefficient	Cp	none	1.0000
Meter Cal. Factor	Y	none	60
Standard Temperature	Tstd	deg. F	.0464
Moisture Factor	K1	cu. ft./mil.	17.38
PT Factor	K2	R/in.Hg	1.108
Velocity Head (dP)	(dP)	(in. H2O)	0.917
Velocity Head (Sqrt dP)	Sqrt(dP)	Sqrt(in. H2O)	
Average Delta H	dH	in. H2O	
Gas Volume Collected	Vm	cf	72.1
Stack Gas Temperature	Ts	deg. F	
Meter Temperature	Tm	deg. F	20.50
%CO2 in Stack Gas	%CO2	%	0.05
%CO2 in Stack Gas	%CO2	%	0.05
Total Impinger Water	Ww	g	0.0
<b>CALCULATIONS</b>			
Stack Area	As	sq. ft.	3.65
Stack Gas Temperature	Ta,r	deg. R	532
Meter Temperature	Tm,r	deg. R	460
Abs Stk Pressure	Pabs	in. Hg.	30.22
Gas Vol. @ STD	Vmstd	scfm	
Vol. of Water Vapor	Vwstd	scfm	
Dry Mol. Wt.	Md	lb/lb-mol.	28.83
Wet Mol. Wt.	Mw	lb/lb-mol.	28.61
Average Velocity	Vs	f/s	51.66
Moisture Content	Bws	%	2.00
Actual Stack Gas Flow Rate	Qa	scfm	11,301
Dry Stack Gas Flow Rate	Qds	scfm	10,933
Wet Stack Gas Flow Rate	Qws	scfm	11,156
<b>CALCULATIONS</b>			
Abs Stk Pressure	Pabs	Pbar - Pbar - (Pw/13.6)	
Gas Vol. @ STD	Vmstd	Vmstd = 17.64 Vm Y [(Pbar - dH/13.6)/Tm]	
Vol. of Water Vapor	Vwstd	Vwstd = 0.04707 Vb26	
Dry Mol. Wt.	Md	Md = 44[(%CO2) + .32(%CO2) + .28(100 - (%CO2 + %CO2))]	
Wet Mol. Wt.	Mw	Mw = Md [1 - (Bws/100)] + 18(Bws/100)	



**APPENDIX C5**

**PRE-FLOWS FOR**  
**EXHAUST FLOW ISOKINETIC CALCULATIONS**

**RUN 3**



# Baghouse Outlet Differential Pressure Calculation

5/23/2019

## Calculation on Inlet Baghouse Velocity

Inlet 1 (Upstream of Baghouse)

Inlet 2

Inlet - HEPA Baghouse

Area - HEPA Baghouse \*

Velocity - HEPA Baghouse

Symbol	Unit	Value	Formula
In 1	acfm	40,979	--
In 2	acfm	11,992	--
In <sub>Bag</sub>	acfm	52,971	In <sub>Bag</sub> = In 1 + In 2
A <sub>Bag</sub>	in <sup>2</sup>	14168	
Vel <sub>Bag</sub>	ft/sec	8.973	Vel <sub>Bag</sub> = Inlet <sub>Bag</sub> (acfm) * (144 in <sup>2</sup> /ft <sup>2</sup> ) * (min/60 sec) * (1/A <sub>Bag</sub> in <sup>2</sup> )

## Calculation of Wet Stack Gas Molecular Weight

Dry Stack Gas Molecular Weight

where, O<sub>2</sub> = 20.5%; CO<sub>2</sub> = 0.05%; CO = 0 ppm; N<sub>2</sub> = 79.05 %

Moisture

Dry Mole Fraction

Wet Stack Gas Molecular Weight

MW <sub>dry</sub>	lb/lb-mole	28.72	MW <sub>dry</sub> = 0.44 * CO <sub>2</sub> + 0.32 * O <sub>2</sub> + 0.28 * COppm + 0.28 * N <sub>2</sub> %
Moist	% H <sub>2</sub> O	2	Assumed Saturated Moisture
Mole <sub>Fract</sub>	decimal	0.98	Mole <sub>Fract</sub> = (1 - [Moist/100])
MW <sub>wet</sub>	lb/lb-mole	28.506	MW <sub>wet</sub> = MW <sub>dry</sub> * Mole <sub>Fract</sub> + (18 * [Moist/100])

## Calculation on Inlet Baghouse Pressure

Velocity - HEPA Baghouse

Stack Temperature

Absolute Stack Pressure

Wet Stack Gas Molecular Weight

Pitot Correlation Coefficient

Conversion Factor

Vel <sub>Bag</sub>	ft/sec	8.973	see above
T <sub>stk</sub>	°F	75	--
P <sub>Abs</sub>	in Hg	29.8	--
MW <sub>wet</sub>	lb/lb-mole	28.506	see above
C <sub>p</sub>		0.84	--
C <sub>fact</sub>		85.49	--
<b>P<sub>Delta</sub></b>	<b>in H<sub>2</sub>O</b>	<b>0.0251</b>	$P_{Delta} = [Vel_{Bag} * 1/C_p * 1/C_{fact} * 1/((T_{stk} + 460)/(P_{Abs} * MW_{wet}))^{0.5}]^2$

\* See next page.

**STACK GAS MOISTURE AND FLOW RATE CALCULATIONS**

Test Date: 5/23/19

Facility: [REDACTED]  
Location: [REDACTED]

Source: Inlet 1 (Upstream of Baghouse)

DATA ENTRY	Symbols	Units	RUN 1		
Stack Diameter	D	in.	36		
Length	L	in.			
Width	W	in.			
Barometric Pressure	Pbar	in. Hg.	29.80		
Static Pressure	Ps	in. H2O	-13.00		
Pitot Coefficient	Cp	none	0.84		
Meter Cal. Factor	Y	none	1.0000		
Standard Temperature	Tstd	deg. F	60		
Moisture Factor	K1	cu.ft./mL	.0464		
PT Factor	K2	R/in.Hg	17.38		
Velocity Head (dP)	(dP)	(in. H2O)	2.800		
Velocity Head (Sqrt dP)	Sqrt (dP)	Sqrt(in. H2O)	1.661		
Average Delta H	dH	in. H2O			
Gas Volume Collected	Vm	cf			
Stack Gas Temperature	Ta	deg. F	81.4		
Meter Temperature	Tm	deg. F			
%O2 in Stack Gas	%O2	%	20.50		
%CO2 in Stack Gas	%CO2	%	0.05		
Total Impinger Water	Ww	g			
<b>CALCULATIONS</b>					
Stack Area	As	sq. ft.	7.07		
Stack Gas Temperature	Ts,r	deg. R	541		
Meter Temperature	Tm,r	deg. R	460		
Abs Stk Pressure	Pabs	in. Hg.	28.84		
Gas Vol. @ STD	Vmstd	dscf			
Vol. of Water Vapor	Vwstd	dscf			
Dry Mol. Wt.	Md	lb/lb-mol.	28.83		
Wet Mol. Wt.	Ms	lb/lb-mol.	28.61		
Average Velocity	Vs	ft/s	96.62		
Moisture Content	Bws	%	2.00		
Actual Stack Gas Flow Rate	Qa	acfm	40,979		
Dry Stack Gas Flow Rate	Qds	dscfm	37,187		
Wet Stack Gas Flow Rate	Qws	wscfm	37,945		
<b>CALCULATIONS</b>					
Abs Stk Pressure	Pabs	$Pabs = Pbar + (Ps/13.6)$			
Gas Vol. @ STD	Vmstd	$Vmstd = 17.64 Vm Y [(Pbar + dH/13.6)] / Tm$			
Vol. of Water Vapor	Vwstd	$Vwstd = 0.04707 Vh2o$			
Dry Mol. Wt.	Md	$Md = .44(\%CO2) + .32(\%O2) + .28[100 - (\%CO2 + \%O2)]$			
Wet Mol. Wt.	Ms	$Ms = Md [1 - (Bws/100)] + 18(Bws/100)$			





STACK GAS MOISTURE AND FLOW RATE CALCULATIONS

Test Date: [REDACTED]  
 Facility: [REDACTED]  
 Location: [REDACTED]

Source: Inlet 2

DATA ENTRY	Symbols	Units	RUN1
Stack Diameter	D	in.	21
Length	L	in.	25
Width	W	in.	29.80
Barometric Pressure	Pbar	in. Hg.	5.70
Static Pressure	Ps	in. H2O	0.84
Pitot Coefficient	Cp	none	1.00000
Meter Cal. Factor	Y	none	60
Standard Temperature	Tstd	deg. F	.0464
Moisture Factor	K1	cu.ft./ml.	17.38
PT Factor	K2	R/in.Hg	1.204
Velocity Head (dP)	Sqrt (dP)	(in. H2O)	0.955
Velocity Head (dP)	dH	Sqrt(in. H2O)	
Average Delta H	Vm	in. H2O	
Gas Volume Collected	Ts	cf	92.7
Stack Gas Temperature	Tm	deg. F	20.50
Meier Temperature	%O2	deg. F	0.05
%O2 in Stack Gas	%CO2	%	0.0
%CO2 in Stack Gas	Ww	%	
Total Impinger Water		g	
<b>CALCULATIONS</b>			
	Symbols	Units	RUN1
Stack Area	As	sq. ft.	3.65
Stack Gas Temperature	Ts,r	deg. R	553
Meier Temperature	Tm,r	deg. R	460
Abs Sik Pressure	Pabs	in. Hg.	30.22
Gas Vol. @ STD	Vmsid	dsf	
Vol. of Water Vapor	Vwsid	dsf	
Dry Mol. Wt.	Md	lb/lb-mol.	28.83
Wet Mol. Wt.	Mw	lb/lb-mol.	28.61
Average Velocity	Va	ft/s	54.82
Moisture Content	Bws	%	2.00
Actual Stack Gas Flow Rate	Qa	scfm	11,992
Dry Stack Gas Flow Rate	Qds	dsfm	11,160
Wet Stack Gas Flow Rate	Qws	wscfm	11,388
<b>CALCULATIONS</b>			
Abs Sik Pressure	Pabs	Pabs=Pbar+(Ps/13.6)	
Gas Vol. @ STD	Vmsid	Vmsid=17.64VmY[Pbar+dH(13.6)]/Tm	
Vol. of Water Vapor	Vwsid	Vwsid=0.04707 Vms2o	
Dry Mol. Wt.	Md	Md=44(%CO2)+32(%O2)+28[100-(%CO2+%O2)]	
Wet Mol. Wt.	Mw	Mw=Md[1-(Bws/100)]+18(Bws/100)	



**APPENDIX D**

**CARB METHOD 425 – CHROMIUM EMISSIONS (HEX/TOTAL)**

**APPENDIX D1**

**CHROMIUM EMISSIONS (HEX/TOTAL) – RESULTS AND CALCULATIONS**



Location: Baghouse Outlet

## TEST RESULTS

### CARB 425 (Hexavalent & Total Chromium)

Facility: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Outlet

TEST DATA	UNITS	TEST RESULTS			AVERAGE
		Run 1	Run 2	Run 3	
Run Number	-				
Test Date	mm/dd/yy	5/22/19	5/22/19	5/23/19	--
Test Time	hh:mm	11:50 - 14:15	14:38 - 16:53	8:25 - 10:45	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	87.2	86.9	86.5	<b>86.9</b>
Moisture	%	1.8	1.7	1.7	<b>1.7</b>
Sample Volume	dscf	91.2	91.2	90.7	<b>91.0</b>
Oxygen**	% v/v	20.9	20.9	20.9	<b>20.9</b>
Carbon Dioxide**	% v/v	0.04	0.04	0.04	<b>0.04</b>
Stack Flow Rate	acfm	-	-	-	-
Stack Flow Rate	dscfm	47,814	48,789	48,995	<b>48,533</b>
<b><u>Total Catch (CARB 425)</u></b>					
Chromium VI	ug	< 0.0460	< 0.0420	< 0.0720	< <b>0.0533</b>
Total Chromium	ug	< 2.000	< 2.000	< 2.000	< <b>2.00</b>
<b><u>Concentration (CARB 425)</u></b>					
Chromium VI	ug/dscm	< 0.0178	< 0.0163	< 0.0280	< <b>0.0207</b>
	ug/dscf	< 0.000504	< 0.000461	< 0.000794	< <b>0.000586</b>
Total Chromium	ug/dscm	< 0.7742	< 0.7748	< 0.7786	< <b>0.776</b>
	ug/dscf	< 0.0219	< 0.0219	< 0.0220	< <b>0.022</b>
<b><u>Mass Emissions (CARB 425)</u></b>					
Chromium VI	ug/hr	< 1446	< 1349	< 2333	< <b>1710</b>
Chromium VI	mg/hr	< 1.45	< 1.35	< 2.33	< <b>1.71</b>
Chromium VI	lb/hr	< 3.2E-06	< 3.0E-06	< 5.1E-06	< <b>3.77E-06</b>
Total Chromium	ug/hr	< 62890	< 64226	< 64816	< <b>63977</b>
Total Chromium	mg/hr	< 62.89	< 64.23	< 64.82	< <b>64.0</b>
Total Chromium	lb/hr	< 1.4E-04	< 1.4E-04	< 1.4E-04	< <b>1.41E-04</b>

Notes:

\* Performed during isokinetic sampling by CARB 425.

\*\* SCAQMD Method 10.1 sample reported error values, ambient O2/CO2 used for gas density calculations.

"<" Indicates an analytical result of non-detect (ND) and the use of laboratory MRL for emission calculations.

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Outlet

Test Date(s): 05/22 to 05/23/19  
 Operator: CH/NC  
 Entered by: TG  
 Checked by: CF

<b>Metals Catch, Mi</b>					
Lab Results	Units	Run 1	Run 2	Run 3	Average
Chromium VI	ug	< 0.046	< 0.042	< 0.072	< 0.053
Total Chromium	μg	< 2.00	< 2.00	< 2.00	< 2.00
Chromium VI, Molecular Weight	g/g-mole	51.995	51.995	51.995	--
Total Chromium, Molecular Weight	g/g-mole	51.995	51.995	51.995	--
<b>Concentration (ug/dscm), Ci = Mi/VmStd *35.315 cf/dscm</b>					
Chromium VI	ug/dscm	< 0.0178	< 0.0163	< 0.0280	< 0.0207
Total Chromium	ug/dscm	< 0.7742	< 0.775	< 0.779	< 0.776
<b>Metals Mass Emission Rate (lb/hr), Ei Ei = Ci*Qsdm*60/453600/1000</b>					
Chromium VI	lb/hr	< 3.19E-06	< 2.97E-06	< 5.14E-06	< 3.77E-06
Total Chromium	lb/hr	< 1.39E-04	< 1.42E-04	< 1.43E-04	< 1.41E-04

MV<sub>1</sub> = 24.05 L/g-mole @68°F, 23.68 L/g-mole @60°F

"<" Indicates an analytical result of non-detect (ND) and the use of laboratory MRL for emission calculations.

### Lab Data - CARB 425

Facility: AQMD Facility A

Source: Baghouse Outlet

Analytical Results - Cr+6									
Run Number:	Run 1		Run 2		Run 3		RB		
Rinse C1, ug	ND	0.011	ND	0.010	ND	0.050	ND, MRL	0.010	Cr+6 C1
Impingers C2, ug		0.035		0.032	ND	0.022	ND, MRL	0.020	C2
<b>Total catch, ug</b>	<	<b>0.046</b>	<	<b>0.042</b>	ND	<b>0.072</b>			

When the DL is used for emissions calculations, it and the resulting calculations are flagged with a "<" symbol.

Analytical Results - Total Chromium									
Run Number:	Run 1		Run 2		Run 3		RB		
Rinse C1, ug	ND	1.00	ND	1.00	ND	1.000	ND, MRL	1.00	Cr C1
Impingers C2, ug	ND	1.00	ND	1.00	ND	1.000	ND, MRL	1.00	C2
<b>Total catch, ug</b>	ND	<b>2.00</b>	ND	<b>2.00</b>	ND	<b>2.00</b>			

When the DL is used for emissions calculations, it and the resulting calculations are flagged with a "<" symbol.

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Outlet

Test Date(s): 05/22 to 05/23/19  
 Operator: CH/NC  
 Entered by: TG  
 Checked by: CF

			05/22/19	05/22/19	05/23/19
<b>DATA ENTRY</b>	<b>symbol</b>	<b>units</b>	<b>DATA</b>	<b>DATA</b>	<b>DATA</b>
Run Number			1	2	3
Stack Dimensions: Round Stack Diameter	Ds	in.			
Rectangular Stack, Length	L	in.			
Width	W	in.			
Nozzle Diameter	Dn	in.	0.513	0.513	0.513
Standard Temperature	Tstd	°F	68	68	68
Universal (molar) Gas Constant	Renglish	in. Hg-cu.ft/ °R-lbmole	21.85	21.85	21.85
Average Stack Temperature (measured)	Fs	°F	87.2	86.9	86.5
Average Meter Temperature (measured)	Fm	°F	83.8	77.5	70.8
Standard Pressure	Pstd	in.Hg	29.92	29.92	29.92
Barometric Pressure	Pbar	in.Hg	29.62	29.62	29.80
Stack Static Pressure	Pg	in.WC	-	-	-
Average Meter Orifice Head (Delta-H)	dH	in.WC	1.83	1.81	1.75
Average RMS Velocity Head (Delta-P)	dP	in.WC	-	-	-
Pitot Coefficient	Cp	—	-	-	-
Net Volume of Gas Metered	Vm	cu.ft.	91.063	89.933	87.853
Dry Gas Meter Calibration Factor (gamma, Y)	Y	—	1.0376	1.0376	1.0376
NET Sampling Time	min	min.	123	123	123
Stack Gas: Oxygen Content*	O2,m	%	20.90	20.90	20.90
Carbon Dioxide Content*	CO2,m	%	0.04	0.04	0.04
Total Impinger Gain	Ww	g	35.4	33.5	32.9
<b>CALCULATED DATA</b>					
Nozzle Area: $An = \pi/4 \cdot dn^2$	An	sq.in.	0.2067	0.2067	0.2067
Stack Area (round): $As = \pi/576 \cdot ds^2$ (rectangular): $As = L \cdot W/144$	As	sq.ft.	-	-	-
Absolute Stack Temperature: $Ts = Fs + 460$	Ts	°R	547.2	546.9	546.5
Absolute Meter Temperature: $Tm = Fm + 460$	Tm	°R	543.8	537.5	530.8
Standard Temperature: $Tstdr = Tstd + 460$	Tstdr	°R	528.0	528.0	528.0
Gas Sample Volume at Standard Conditions: $Vm(std) = Y \cdot (Vm/Tm) \cdot (Pbar + dH/13.6 \text{ in H}_2\text{O/in Hg}) \cdot (Tstdr/Pstd)$	VmStd	cu.ft.	91.233	91.158	90.709
Vol. of Water Vapor, $Vw(std) = Ww/453.59 \cdot Renglish/18 \cdot Tstdr / Pstd$	VwStd	cu.ft.	1.672	1.582	1.554
Moisture Fraction: $Bws = VwStd/(VmStd + VwStd)$	Bws	—	0.0180	0.017	0.0168
Stack Gas MW, Dry Basis: $Md = 0.32 \cdot O_{2,m} + 0.44 \cdot CO_{2,m} + 0.28 \cdot (100 - O_{2,m} - CO_{2,m})$	Md	g/mole	28.84	28.84	28.84
Stack Gas MW, Wet Basis: $Mw = Md \cdot (1 - Bws) + 18 \cdot Bws$	Mw	g/mole	28.65	28.66	28.66
Stack Pressure: $Ps = Pbar + Pg/13.6$	Ps	in.Hg	-	-	-
Stack Gas Velocity, measured $vs = 85.49 \cdot Cp \cdot \sqrt{(dP \cdot Ts/Ps/Mw)}$ $vm = 0.3048 \text{ m/ft} \cdot vs$	vs vsm	ft/s m/s	- -	- -	- -
Stack Gas Volumetric Flow Rate: $Q = 60 \cdot vs \cdot As$	Q	acfm	-	-	-
Stack Gas Volumetric Flow Rate, corrected: $Qsd = Q \cdot (1 - Bws) \cdot (Ps/Ts) \cdot (Tstdr/Pstd)$ $Qsdm = Qsd/35.315$	Qsd** Qsdm	dscfm dscmm	47,814 1,353.9	48,789 1,381.5	48,995 1,387.4
Isokinetic Sampling Rate: $I = 144 \cdot 100 \cdot Ts \cdot Vmstd \cdot Pstd / [60 \cdot Tstdr \cdot vs \cdot \min(An \cdot Ps, (1 - Bws))]$	I	%	-	-	-

\* SCAQMD Method 10.1 sample reported error values, ambient O2/CO2 used for gas density calculations.

\*\* Baghouse outlet flow was assumed to be equal to the inlet. The inlet 1 outside and inlet 2 flows were added utilized the outlet mass emissions calculations.

**CARB METHOD 425 DATA AND CALCULATIONS**

**ISOKINETIC CALCULATION ONLY**

Plant: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Outlet

Test Date(s): 05/22 to 05/23/19  
 Operator: CH/NC  
 Entered by: TG  
 Checked by: CF

			05/22/19	05/22/19	05/23/19
<b>DATA ENTRY</b>	<b>symbol</b>	<b>units</b>	<b>DATA</b>	<b>DATA</b>	<b>DATA</b>
Run Number			1	2	3
Stack Dimensions: Round Stack Diameter	Ds	in.			
Rectangular Stack, Length	L	in.	154	154	154
Width	W	in.	46	46	46
Nozzle Diameter	Dn	in.	0.513	0.513	0.513
Standard Temperature	Tstd	°F	68	68	68
Universal (molar) Gas Constant	Renglish	in. Hg-cu.ft/ °R-lbmole	21.85	21.85	21.85
Average Stack Temperature (measured)	Fs	°F	87.2	86.9	86.5
Average Meter Temperature (measured)	Fm	°F	83.8	77.5	70.8
Standard Pressure	Pstd	in.Hg	29.92	29.92	29.92
Barometric Pressure	Pbar	in.Hg	29.62	29.62	29.80
Stack Static Pressure	Pg	in.WC	N/A	N/A	N/A
Average Meter Orifice Head (Delta-H)	dH	in.WC	1.83	1.81	1.75
Average RMS Velocity Head (Delta-P)	dP	in.WC	0.026	0.026	0.025
Pitot Coefficient	Cp	—	0.84	0.84	0.84
Net Volume of Gas Metered	Vm	cu.ft.	91.063	89.933	87.853
Dry Gas Meter Calibration Factor (gamma, Y)	Y	—	1.0376	1.0376	1.0376
NET Sampling Time	min	min.	123	123	123
Stack Gas: Oxygen Content*	O2,m	%	20.90	20.90	20.90
Carbon Dioxide Content*	CO2,m	%	0.04	0.04	0.04
Total Impinger Gain	Ww	g	35.4	33.5	32.9
<b>CALCULATED DATA</b>					
Nozzle Area: $An = \pi/4*dn^2$	An	sq.in.	0.2067	0.2067	0.2067
Stack Area (round): $As = \pi/576*ds^2$	As	sq.ft.	-	-	-
(rectangular): $As = L*W/144$			98.389	98.389	98.389
Absolute Stack Temperature: $Ts = Fs+460$	Ts	°R	547.2	546.9	546.5
Absolute Meter Temperature: $Tm = Fm+460$	Tm	°R	543.8	537.5	530.8
Standard Temperature: $Tstdr = Tstd+460$	Tstdr	°R	528.0	528.0	528.0
Gas Sample Volume at Standard Conditions: $Vm(std) = Y * (Vm/Tm) * (Pbar + dH/13.6 \text{ in H}_2\text{O/in Hg}) * (Tstdr/Pstd)$	VmStd	cu.ft.	91.233	91.158	90.709
Vol. of Water Vapor, $Vw(std) = Ww/453.59 * Renglish/18 * Tstdr / Pstd$	VwStd	cu.ft.	1.672	1.582	1.554
Moisture Fraction: $Bws = VwStd/(VmStd+VwStd)$	Bws	—	0.0180	0.017	0.0168
Stack Gas MW, Dry Basis: $Md = 0.32*O_{2,m} + 0.44*CO_{2,m} + 0.28*(100-O_{2,m}-CO_{2,m})$	Md	g/mole	28.84	28.84	28.84
Stack Gas MW, Wet Basis: $Mw = Md*(1-Bws) + 18*Bws$	Mw	g/mole	28.65	28.66	28.66
Stack Pressure: $Ps = Pbar + Pg/13.6$	Ps	in.Hg	29.62	29.62	29.80
Stack Gas Velocity, measured $vs = 85.49*Cp*\sqrt{(dP*Ts/Ps/Mw)}$ $vm = 0.3048 \text{ m/ft}*vs$	vs	ft/s	9.23	9.22	9.10
	vsm	m/s	2.81	2.81	2.77
Stack Gas Volumetric Flow Rate: $Q = 60*vs*As$	Q	acfm	54,468	54,447	53,725
Stack Gas Volumetric Flow Rate, corrected: $Qsd = Q*(1-Bws)*(Ps/Ts)*(Tstdr/Pstd)$ $Qsdm = Qsd/35.315$	Qsd**	dscfm	47,814	48,789	48,995
	Qsdm	dscmm	1,353.9	1,381.5	1,387.4
Isokinetic Sampling Rate: $I = 144*100*Ts*Vmstd *Pstd/[60*Tstdr*vs*min*An*Ps*(1-Bws)]$	I	%	99.5	99.3	99.5
			based on estimated dP		

Flow Rate - Estimated (based on preflow calculation and back calculated dP)	51,096	51,146	50,828
Flow Rate based on sum of two inlet flows (as measured during test)	47,814	48,789	48,995
Flow - Percent Difference	107%	105%	104%
Corrected isokinetic sampling rate based on actual flows	106%	104%	103%

### CARB METHOD 425 DATA AND CALCULATIONS

Plant: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Outlet

dP based on inlet pre flows  
 Back-calculated for the  
 this outlet location

Run No.: 1  
 Test Date: 05/22/19  
 Times: 11:50 - 14:15

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	89	9.4	0.0256	0.160	1.81	79	79
2	87	9.3	0.0256	0.160	1.82	80	80
3	91	9.5	0.0256	0.160	1.81	82	82
4	84	9.2	0.0256	0.160	1.84	83	83
5	89	9.4	0.0256	0.160	1.83	84	84
6	87	9.3	0.0256	0.160	1.84	85	85
7	84	9.2	0.0256	0.160	1.85	86	86
8	90	9.5	0.0256	0.160	1.83	86	86
9	88	9.4	0.0256	0.160	1.84	87	87
B-1	90	9.5	0.0256	0.160	1.81	81	81
2	87	9.3	0.0256	0.160	1.83	82	82
3	84	9.2	0.0256	0.160	1.84	82	82
4	89	9.4	0.0256	0.160	1.82	83	83
5	86	9.3	0.0256	0.160	1.83	83	83
6	92	9.6	0.0256	0.160	1.82	84	84
7	88	9.4	0.0256	0.160	1.83	85	85
8	84	9.2	0.0256	0.160	1.85	85	85
9	81	9.0	0.0256	0.160	1.86	85	85
10	85	9.2	0.0256	0.160	1.85	86	86
11	89	9.4	0.0256	0.160	1.83	86	86
12	87	9.3	0.0256	0.160	1.84	86	86
<b>Average:</b>		<b>87.2</b>		<b>0.0256</b>	<b>1.83</b>		<b>83.8</b>

DGM Reading (cu.ft.): Final-1: 971.013 Initial-1: 924.403 Final-2: 1015.763 Initial-2: 971.310 Final-3: Initial-3: Final-4: Initial-4: Final-5: Initial-5: <b>NET Volume: 91.063</b>	Impinger Weight (g): #1 Final: 764.0 #1 Initial: 754.7 #2 Final: 734.7 #2 Initial: 732.3 #3 Final: 677.3 #3 Initial: 673.5 #4 Final: 894.0 #4 Initial: 874.1 #5 Final: #5 Initial: #6 Final: #6 Initial: #7 Final: #7 Initial: #8 Final: #8 Initial: <b>Total wt of impingers: 35.4</b>
--	---

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Outlet

dP based on inlet pre flows Back-calculated for the this outlet location
--

Run No.: 2  
 Test Date: 05/22/19  
 Times: 14:38 - 16:53

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	87	9.3	0.0256	0.160	1.81	78	78
2	90	9.5	0.0256	0.160	1.81	79	79
3	85	9.2	0.0256	0.160	1.82	79	79
4	87	9.3	0.0256	0.160	1.82	80	80
5	89	9.4	0.0256	0.160	1.82	81	81
6	84	9.2	0.0256	0.160	1.83	81	81
7	86	9.3	0.0256	0.160	1.82	80	80
8	88	9.4	0.0256	0.160	1.82	80	80
9	85	9.2	0.0256	0.160	1.83	80	80
10	89	9.4	0.0256	0.160	1.81	79	79
11	87	9.3	0.0256	0.160	1.82	79	79
12	85	9.2	0.0256	0.160	1.82	79	79
B-1	89	9.4	0.0256	0.160	1.79	74	74
2	87	9.3	0.0256	0.160	1.80	73	73
3	84	9.2	0.0256	0.160	1.81	74	74
4	88	9.4	0.0256	0.160	1.80	74	74
5	86	9.3	0.0256	0.160	1.81	75	75
6	89	9.4	0.0256	0.160	1.80	75	75
7	85	9.2	0.0256	0.160	1.81	75	75
8	87	9.3	0.0256	0.160	1.81	76	76
9	89	9.4	0.0256	0.160	1.80	76	76
<b>Average:</b>		<b>86.9</b>		<b>0.0256</b>	<b>1.81</b>		<b>77.5</b>

DGM Reading (cu.ft.):	Final-1: 60.203	Impinger Weight (g):	#1 Final: 763.3
	Initial-1: 16.118		#1 Initial: 753.1
	Final-2: 106.962		#2 Final: 713.9
	Initial-2: 61.114		#2 Initial: 710.4
	Final-3:		#3 Final: 646.0
	Initial-3:		#3 Initial: 643.8
	Final-4:		#4 Final: 925.2
	Initial-4:		#4 Initial: 907.6
	Final-5:		#5 Final:
	Initial-5:		#5 Initial:
NET Volume:	<b>89.933</b>		#6 Final:
			#6 Initial:
			#7 Final:
			#7 Initial:
			#8 Final:
			#8 Initial:
		<b>Total wt of impingers:</b>	<b>33.5</b>



**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Outlet

dP based on inlet pre flows  
 Back-calculated for the  
 this outlet location

Run No.: 3  
 Test Date: 05/23/19  
 Times: 8:25 - 10:45

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	91	9.5	0.0251	0.158	1.72	63	63
2	87	9.3	0.0251	0.158	1.73	64	64
3	84	9.2	0.0251	0.158	1.75	66	66
4	89	9.4	0.0251	0.158	1.73	67	67
5	86	9.3	0.0251	0.158	1.75	68	68
6	83	9.1	0.0251	0.158	1.76	69	69
7	88	9.4	0.0251	0.158	1.75	70	70
8	85	9.2	0.0251	0.158	1.76	70	70
9	89	9.4	0.0251	0.158	1.75	72	72
10	87	9.3	0.0251	0.158	1.76	73	73
11	84	9.2	0.0251	0.158	1.77	73	73
12	86	9.3	0.0251	0.158	1.77	74	74
B-1	79	8.9	0.0251	0.158	1.77	69	69
2	84	9.2	0.0251	0.158	1.76	70	70
3	89	9.4	0.0251	0.158	1.75	71	71
4	87	9.3	0.0251	0.158	1.76	73	73
5	91	9.5	0.0251	0.158	1.75	74	74
6	85	9.2	0.0251	0.158	1.77	75	75
7	89	9.4	0.0251	0.158	1.76	75	75
8	88	9.4	0.0251	0.158	1.76	75	75
9	86	9.3	0.0251	0.158	1.77	75	75
<b>Average:</b>		<b>86.5</b>		<b>0.0251</b>	<b>1.75</b>		<b>70.8</b>

DGM Reading (cu.ft.):	Final-1:	195.671	Impinger Weight (g):	#1 Final:	764.1
	Initial-1:	150.511		#1 Initial:	754.2
	Final-2:	149.942		#2 Final:	738.8
	Initial-2:	107.249		#2 Initial:	735.1
	Final-3:			#3 Final:	676.7
	Initial-3:			#3 Initial:	674.8
	Final-4:			#4 Final:	893.1
	Initial-4:			#4 Initial:	875.7
	Final-5:			#5 Final:	
	Initial-5:			#5 Initial:	
	NET Volume:	<b>87.853</b>		#6 Final:	
				#6 Initial:	
				#7 Final:	
				#7 Initial:	
				#8 Final:	
				#8 Initial:	
			<b>Total wt of impingers:</b>		<b>32.9</b>

Location: Inlet 1 (Inside)

## TEST RESULTS

### CARB 425 (Hexavalent & Total Chromium)

Facility: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

TEST DATA	UNITS	TEST RESULTS			AVERAGE
		Run 1	Run 2	Run 3	
Run Number	-				
Test Date	mm/dd/yy	5/22/19	5/22/19	5/23/19	--
Test Time	hh:mm	11:50 - 14:15	14:38 - 16:53	8:25 - 10:45	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	152.3	138.0	128.4	<b>139.6</b>
Moisture	%	1.2	1.3	1.5	<b>1.4</b>
Sample Volume	dscf	102.7	100.5	105.9	<b>103.0</b>
Oxygen**	% v/v	19.9	19.9	20.2	<b>20.0</b>
Carbon Dioxide**	% v/v	0.30	0.30	0.30	<b>0.30</b>
Gas Velocity	ft/min	6,000.0	5,828.0	5,917.3	<b>5,915</b>
Stack Flow Rate	acfm	3,272	3,179	3,227	<b>3,226</b>
Stack Flow Rate	dscfm	2,661	2,644	2,743	<b>2,683</b>
<b><u>Total Catch (CARB 425)</u></b>					
Chromium VI	ug	58.5	3.8	23.5	<b>28.6</b>
Total Chromium	ug	281	55	346	<b>227</b>
<b><u>Concentration (CARB 425)</u></b>					
Chromium VI	ug/dscm	20.12	1.34	7.84	<b>9.76</b>
	ug/dscf	0.570	0.038	0.222	<b>0.276</b>
Total Chromium	ug/dscm	96.64	19.29	115.44	<b>77.1</b>
	ug/dscf	2.74	0.55	3.27	<b>2.18</b>
<b><u>Mass Emissions (CARB 425)</u></b>					
Chromium VI	ug/hr	90955	6000	36528	<b>44494</b>
Chromium VI	mg/hr	91.0	6.00	36.5	<b>44.5</b>
Chromium VI	lb/hr	2.01E-04	1.32E-05	8.05E-05	<b>9.81E-05</b>
Total Chromium	ug/hr	436895	86678	537974	<b>353849</b>
Total Chromium	mg/hr	437	87	538	<b>354</b>
Total Chromium	lb/hr	9.63E-04	1.91E-04	1.19E-03	<b>7.80E-04</b>

Notes:

\* Performed during isokinetic sampling by CARB 425.

\*\* O2/CO2 was measured via SCAQMD Method 10.1 by GC.

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Test Date(s): 05/22 to 05/23/19  
 Operator: T.Ta/NC  
 Entered by: TG  
 Checked by: CF

Lab Results	Units	Run 1	Run 2	Run 3	Average
Chromium VI	ug	58.5	3.8	23.5	28.60
Total Chromium	μg	281	54.9	346.1	227.3
Chromium VI, Molecular Weight	g/g-mole	51.995	51.995	51.995	--
Total Chromium, Molecular Weight	g/g-mole	51.995	51.995	51.995	--
<b>Concentration (ug/dscm), <math>C_i = M_i/V_mStd * 35.315 \text{ cf/dscm}</math></b>					
Chromium VI	ug/dscm	20.12	1.34	7.84	9.8
Total Chromium	ug/dscm	96.64	19.29	115.44	77
<b>Metals Mass Emissino Rate (lb/hr), <math>E_i = C_i * Q_{sdm} * 60 / 453600 / 1000</math></b>					
Chromium VI	lb/hr	2.01E-04	1.32E-05	8.05E-05	9.81E-05
Total Chromium	lb/hr	9.63E-04	1.91E-04	1.19E-03	7.80E-04

MV<sub>1</sub> = 24.05 L/g-mole @68°F, 23.68 L/g-mole @60°F

### Lab Data - CARB 425

Facility: AQMD Facility A

Source: Baghouse Inlet 1 Furnace (Inside)

Analytical Results - Cr+6					
Run Number:	Run 1	Run 2	Run 3	RB	
Rinse C1, ug	6.5	1.7	2.5	ND, MRL	0.010
Impingers C2, ug	52	2.1	21	ND, MRL	0.020
<b>Total catch, ug</b>	<b>58.5</b>	<b>3.8</b>	<b>23.5</b>		

**Cr+6**

**C1**

**C2**

Analytical Results - Total Chromium					
Run Number:	Run 1	Run 2	Run 3	RB	
Rinse C1, ug	11	3.9	6.1	ND, MRL	1.00
Impingers C2, ug	270	51	340	ND, MRL	1.00
<b>Total catch, ug</b>	<b>281</b>	<b>54.9</b>	<b>346.1</b>		

**Cr**

**C1**

**C2**

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Test Date(s): 05/22 to 05/23/19  
 Operator: T.Ta/NC  
 Entered by: TG  
 Checked by: CF

			05/22/19	05/22/19	05/23/19
<b>DATA ENTRY</b>	<b>symbol</b>	<b>units</b>	<b>DATA</b>	<b>DATA</b>	<b>DATA</b>
Run Number			1	2	3
Stack Dimensions: Round Stack Diameter	Ds	in.	10.00	10.00	10.00
Rectangular Stack, Length	L	in.			
Width	W	in.			
Nozzle Diameter	Dn	in.	0.180	0.180	0.180
Standard Temperature	Tstd	°F	68	68	68
Universal (molar) Gas Constant	Renglish	in. Hg-cu.ft/ °R-lbmole	21.85	21.85	21.85
Average Stack Temperature (measured)	Fs	°F	152.3	138.0	128.4
Average Meter Temperature (measured)	Fm	°F	97.7	93.8	90.0
Standard Pressure	Pstd	in.Hg	29.92	29.92	29.92
Barometric Pressure	Pbar	in.Hg	29.62	29.62	29.81
Stack Static Pressure	Pg	in.WC	-14.30	-14.30	-14.20
Average Meter Orifice Head (Delta-H)	dH	in.WC	2.46	2.41	2.55
Average RMS Velocity Head (Delta-P)	dP	in.WC	2.597	2.508	2.646
Pitot Coefficient	Cp	—	0.84	0.84	0.84
Net Volume of Gas Metered	Vm	cu.ft.	105.990	103.006	107.068
Dry Gas Meter Calibration Factor (gamma, Y)	Y	—	1.0274	1.0274	1.0274
NET Sampling Time	min	min.	120	120	120
Stack Gas: Oxygen Content*	O2,m	%	19.90	19.90	20.20
Carbon Dioxide Content*	CO2,m	%	<0.30	<0.30	<0.30
Total Impinger Gain	Ww	g	27.2	28.6	34.1
<b>CALCULATED DATA</b>					
Nozzle Area: $An = \pi/4 \cdot dn^2$	An	sq.in.	0.0254	0.0254	0.0254
Stack Area (round): $As = \pi/576 \cdot ds^2$ (rectangular): $As = L \cdot W/144$	As	sq.ft.	0.55	0.55	0.55
Absolute Stack Temperature: $Ts = Fs + 460$	Ts	°R	612.3	598.0	588.4
Absolute Meter Temperature: $Tm = Fm + 460$	Tm	°R	557.7	553.8	550.0
Standard Temperature: $Tstdr = Tstd + 460$	Tstdr	°R	528.0	528.0	528.0
Gas Sample Volume at Standard Conditions: $Vm(std) = Y \cdot (Vm/Tm) \cdot (Pbar + dH/13.6 \text{ in H}_2\text{O/in Hg}) \cdot (Tstdr/Pstd)$	VmStd	cu.ft.	102.7	100.5	105.9
Vol. of Water Vapor: $Vw(std) = Ww/453.59 \cdot Renglish/18 \cdot Tstdr / Pstd$	VwStd	cu.ft.	1.285	1.351	1.610
Moisture Fraction: $Bws = VwStd/(VmStd + VwStd)$	Bws	—	0.0124	0.013	0.0150
Stack Gas MW, Dry Basis: $Md = 0.32 \cdot O_{2,m} + 0.44 \cdot CO_{2,m} + 0.28 \cdot (100 - O_{2,m} - CO_{2,m})$	Md	g/mole	28.84	28.84	28.86
Stack Gas MW, Wet Basis: $Mw = Md \cdot (1 - Bws) + 18 \cdot Bws$	Mw	g/mole	28.71	28.70	28.69
Stack Pressure: $Ps = Pbar + Pg/13.6$	Ps	in.Hg	28.57	28.57	28.77
Stack Gas Velocity, measured $vs = 85.49 \cdot Cp \cdot \sqrt{(dP \cdot Ts / Ps \cdot Mw)}$ $vm = 0.3048 \text{ m/ft} \cdot vs$	vs vsm	ft/s m/s	100.00 30.48	97.13 29.61	98.62 30.06
Stack Gas Volumetric Flow Rate: $Q = 60 \cdot vs \cdot As$	Q	acfm	3,272	3,179	3,227
Stack Gas Volumetric Flow Rate, corrected: $Qsd = Q \cdot (1 - Bws) \cdot (Ps / Ts) \cdot (Tstdr / Pstd)$ $Qsdm = Qsd / 35.315$	Qsd Qsdm	dscfm dscmm	2,661 75.4	2,644 74.9	2,743 77.7
Isokinetic Sampling Rate: $I = 144 \cdot 100 \cdot Ts \cdot Vmstd \cdot Pstd / [60 \cdot Tstdr \cdot vs \cdot \min \cdot An \cdot Ps \cdot (1 - Bws)]$	I	%	99.3	97.7	99.3

\* O2/CO2 was measured via SCAQMD Method 10.1 by GC.

### CARB METHOD 425 DATA AND CALCULATIONS

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Run No.: 1  
 Test Date: 05/22/19  
 Times: 11:50 - 14:15

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	117	10.8	2.70	1.64	2.63	90	90
2	126	11.2	3.00	1.73	2.88	91	91
3	144	12.0	2.60	1.61	2.43	92	92
4	140	11.8	2.60	1.61	2.45	94	94
5	128	11.3	2.50	1.58	2.41	95	95
6	166	12.9	2.80	1.67	2.54	96	96
7	193	13.9	3.30	1.82	2.87	96	96
8	139	11.8	3.50	1.87	3.33	98	98
9	164	12.8	3.20	1.79	2.92	98	98
10	173	13.2	2.90	1.70	2.62	99	99
11	190	13.8	2.60	1.61	2.29	100	100
12	142	11.9	2.20	1.48	2.09	100	100
B-1	148	12.2	3.30	1.82	3.08	95	95
2	175	13.2	3.20	1.79	2.86	96	96
3	144	12.0	3.20	1.79	3.02	98	98
4	137	11.7	3.30	1.82	3.16	99	99
5	178	13.3	3.10	1.76	2.78	100	100
6	169	13.0	3.40	1.84	3.10	101	101
7	123	11.1	2.00	1.41	1.97	101	101
8	152	12.3	2.10	1.45	1.97	102	102
9	144	12.0	1.90	1.38	1.80	101	101
10	157	12.5	1.70	1.30	1.58	101	101
11	162	12.7	1.30	1.14	1.20	101	101
12	161	12.7	1.10	1.05	1.01	100	100
<b>Average:</b>		<b>152.3</b>		<b>2.5974</b>	<b>2.46</b>		<b>97.7</b>

DGM Reading (cu.ft.):	Final-1: 645.510	Impinger Weight (g):	#1 Final: 755.6
	Initial-1: 539.520		#1 Initial: 751.1
	Final-2:		#2 Final: 753.2
	Initial-2:		#2 Initial: 749.5
	Final-3:		#3 Final: 653.8
	Initial-3:		#3 Initial: 651.2
	Final-4:		#4 Final: 820.9
	Initial-4:		#4 Initial: 804.5
	Final-5:		#5 Final:
	Initial-5:		#5 Initial:
NET Volume:	<b>105.990</b>		#6 Final:
			#6 Initial:
			#7 Final:
			#7 Initial:
			#8 Final:
			#8 Initial:
		<b>Total wt of impingers:</b>	<b>27.2</b>

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ████████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Run No.: 2  
 Test Date: 05/22/19  
 Times: 14:38 - 16:53

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	186	13.6	2.40	1.55	2.09	92	92
2	168	13.0	2.50	1.58	2.25	94	94
3	143	12.0	2.50	1.58	2.35	94	94
4	124	11.1	2.70	1.64	2.63	96	96
5	117	10.8	2.80	1.67	2.76	96	96
6	115	10.7	2.70	1.64	2.67	97	97
7	130	11.4	3.80	1.95	3.38	98	98
8	138	11.7	3.20	1.79	3.05	98	98
9	145	12.0	3.50	1.87	3.30	98	98
10	123	11.1	2.40	1.55	2.35	99	99
11	150	12.2	2.30	1.52	1.98	99	99
12	147	12.1	1.80	1.34	1.69	98	98
B-1	153	12.4	3.50	1.87	3.21	91	91
2	150	12.2	3.40	1.84	3.14	91	91
3	148	12.2	3.30	1.82	3.06	92	92
4	147	12.1	3.30	1.82	3.07	92	92
5	145	12.0	3.40	1.84	3.17	92	92
6	144	12.0	3.40	1.84	3.17	92	92
7	137	11.7	2.10	1.45	1.98	92	92
8	135	11.6	1.90	1.38	1.80	91	91
9	129	11.4	1.50	1.22	1.43	90	90
10	124	11.1	1.30	1.14	1.25	90	90
11	117	10.8	1.20	1.10	1.17	90	90
12	110	10.5	1.00	1.00	0.98	89	89
<b>Average:</b>		<b>138.0</b>		<b>2.5084</b>	<b>2.41</b>		<b>93.8</b>

DGM Reading (cu.ft.):	Final-1:	749.086	Impinger Weight (g):	#1 Final:	770.8
	Initial-1:	646.080		#1 Initial:	762.6
	Final-2:			#2 Final:	643.5
	Initial-2:			#2 Initial:	640.0
	Final-3:			#3 Final:	656.6
	Initial-3:			#3 Initial:	655.7
	Final-4:			#4 Final:	860.0
	Initial-4:			#4 Initial:	844.0
	Final-5:			#5 Final:	
	Initial-5:			#5 Initial:	
	NET Volume:	<b>103.006</b>		#6 Final:	
				#6 Initial:	
				#7 Final:	
				#7 Initial:	
				#8 Final:	
				#8 Initial:	
			<b>Total wt of impingers:</b>		<b>28.6</b>



### CARB METHOD 425 DATA AND CALCULATIONS

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 1 Furnace (Inside)

Run No.: 3  
 Test Date: 05/23/19  
 Times: 8:25 - 10:45

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-1	184	13.6	2.60	1.61	2.24	84	84
2	185	13.6	2.50	1.58	2.16	86	86
3	145	12.0	2.50	1.58	2.14	87	87
4	140	11.8	2.30	1.52	2.15	89	89
5	131	11.4	2.60	1.61	2.47	90	90
6	110	10.5	2.70	1.64	2.67	91	91
7	128	11.3	3.40	1.84	3.26	92	92
8	117	10.8	3.60	1.90	3.53	93	93
9	113	10.6	3.30	1.82	3.25	93	93
10	114	10.7	2.70	1.64	2.66	94	94
11	135	11.6	2.50	1.58	2.37	93	93
12	126	11.2	1.70	1.30	1.64	93	93
B-1	121	11.0	2.80	1.67	2.69	86	86
2	103	10.1	3.40	1.84	3.38	87	87
3	136	11.7	3.50	1.87	3.29	88	88
4	106	10.3	3.30	1.82	3.27	89	89
5	159	12.6	3.20	1.79	2.91	90	90
6	132	11.5	3.40	1.84	3.23	91	91
7	147	12.1	2.70	1.64	2.50	91	91
8	123	11.1	2.40	1.55	2.32	91	91
9	117	10.8	2.20	1.48	2.15	91	91
10	115	10.7	2.10	1.45	2.06	91	91
11	105	10.2	1.70	1.30	1.69	90	90
12	109	10.4	1.30	1.14	1.28	90	90
<b>Average:</b>		<b>128.4</b>		<b>2.6459</b>	<b>2.55</b>		<b>90.0</b>

DGM Reading (cu.ft.): Final-1:	858.118	Impinger Weight (g): #1 Final:	758.4
Initial-1:	751.050	#1 Initial:	751.6
Final-2:		#2 Final:	737.4
Initial-2:		#2 Initial:	749.9
Final-3:		#3 Final:	672.9
Initial-3:		#3 Initial:	652.9
Final-4:		#4 Final:	853.4
Initial-4:		#4 Initial:	833.6
Final-5:		#5 Final:	
Initial-5:		#5 Initial:	
NET Volume:	<b>107.068</b>	#6 Final:	
		#6 Initial:	
		#7 Final:	
		#7 Initial:	
		#8 Final:	
		#8 Initial:	
		<b>Total wt of impingers:</b>	<b>34.1</b>

Location: Inlet 2 (downstream/outside)

## TEST RESULTS

### CARB 425 (Hexavalent & Total Chromium)

Facility: AQMD Facility A  
 City: █████ CA  
 Source: Baghouse  
 Location: Inlet 2 (Upstream to Baghouse)

TEST DATA	UNITS	TEST RESULTS			AVERAGE
		Run 1	Run 2	Run 3	
Run Number	-				
Test Date	mm/dd/yy	5/22/19	5/22/19	5/23/19	--
Test Time	hh:mm	11:50 - 14:12	14:38 - 16:50	8:25 - 10:42	--
<b><u>Sampling Data*</u></b>					
Stack Temperature	°F	91	85	81	<b>86</b>
Moisture	%	1.4	1.5	1.5	<b>1.5</b>
Sample Volume	dscf	102.2	105.0	105.0	<b>104.1</b>
Oxygen**	% v/v	20.2	20.2	19.9	<b>20.1</b>
Carbon Dioxide**	% v/v	0.30	0.30	0.30	<b>0.30</b>
Gas Velocity	ft/min	5,774.9	5,873.0	5,815.4	<b>5,821</b>
Stack Flow Rate	acfm	40,820	41,514	41,106	<b>41,147</b>
Stack Flow Rate	dscfm	36,968	37,943	37,953	<b>37,621</b>
<b><u>Total Catch (CARB 425)</u></b>					
Chromium VI	ug	4.30	0.52	3.04	<b>2.62</b>
Total Chromium	ug	13.7	5.1	21.7	<b>13.5</b>
<b><u>Concentration (CARB 425)</u></b>					
Chromium VI	ug/dscm	1.49	0.17	1.02	<b>0.89</b>
	ug/dscf	0.042	0.005	0.029	<b>0.025</b>
Total Chromium	ug/dscm	4.73	1.72	7.30	<b>4.58</b>
	ug/dscf	0.13	0.05	0.21	<b>0.13</b>
<b><u>Mass Emissions (CARB 425)</u></b>					
Chromium VI	ug/hr	93299	11274	65907	<b>56827</b>
Chromium VI	mg/hr	93.3	11.3	65.9	<b>56.8</b>
Chromium VI	lb/hr	2.1E-04	2.5E-05	1.5E-04	<b>1.25E-04</b>
Total Chromium	ug/hr	297255	110574	470457	<b>292762</b>
Total Chromium	mg/hr	297.26	110.57	470.46	<b>292.8</b>
Total Chromium	lb/hr	6.6E-04	2.4E-04	1.0E-03	<b>6.45E-04</b>

Notes:

\* Performed during isokinetic sampling by CARB 425.

\*\*O2/CO2 was measured via SCAQMD Method 10.1 by GC.

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 2 (Upstream to Baghouse)

Test Date(s): 05/22 to 05/23/19  
 Operator: MN/NC  
 Entered by: TG  
 Checked by: CF

<b>Metals Catch, Mi</b>					
Lab Results	Units	Run 1	Run 2	Run 3	Average
Chromium VI	ug	4.30	0.52	3.04	2.62
Total Chromium	μg	13.7	5.1	21.7	13.5
Chromium VI, Molecular Weight	g/g-mole	51.995	51.995	51.995	--
Total Chromium, Molecular Weight	g/g-mole	51.995	51.995	51.995	--
<b>Concentration (ug/dscm), Ci = Mi/VmStd *35.315 cf/dscm</b>					
Chromium VI	ug/dscm	1.49	0.17	1.02	0.89
Total Chromium	ug/dscm	4.73	1.72	7.30	4.58
<b>Metals Mass Emissino Rate (lb/hr), Ei Ei = Ci*Qsdm*60/453600/1000</b>					
Chromium VI	lb/hr	2.06E-04	2.49E-05	1.45E-04	1.25E-04
Total Chromium	lb/hr	6.55E-04	2.44E-04	1.04E-03	6.45E-04

MV<sub>1</sub> = 24.05 L/g-mole @68°F, 23.68 L/g-mole @60°F

### Lab Data - CARB 425

Facility: AQMD Facility A

Source: Baghouse Inlet 2 (Upstream to Baghouse)

Analytical Results - Cr+6						
Run Number:	Run 1	Run 2	Run 3	RB		
Rinse C1, ug	1.2	0.21	0.94	ND, MRL	0.010	Cr+6 C1
Impingers C2, ug	3.1	0.31	2.10	ND, MRL	0.020	C2
<b>Total catch, ug</b>	<b>4.3</b>	<b>0.52</b>	<b>3.04</b>			

Analytical Results - Total Chromium						
Run Number:	Run 1	Run 2	Run 3	RB		
Rinse C1, ug	2.70	1.5	2.7	ND, MRL	1.00	Cr C1
Impingers C2, ug	11.0	3.6	19	ND, MRL	1.00	C2
<b>Total catch, ug</b>	<b>13.7</b>	<b>5.1</b>	<b>21.7</b>			

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 2 (Upstream to Baghouse)

Test Date(s): 05/22 to 05/23/19  
 Operator: MN/NC  
 Entered by: TG  
 Checked by: CF

			05/22/19	05/22/19	05/23/19
<b>DATA ENTRY</b>	<b>symbol</b>	<b>units</b>	<b>DATA</b>	<b>DATA</b>	<b>DATA</b>
Run Number			1	2	3
Stack Dimensions: Round Stack Diameter	Ds	in.	36.00	36.00	36.00
Rectangular Stack, Length	L	in.			
Width	W	in.			
Nozzle Diameter	Dn	in.	0.173	0.173	0.173
Standard Temperature	Tstd	°F	68	68	68
Universal (molar) Gas Constant	Renglish	in. Hg-cu.ft/ °R-lbmole	21.85	21.85	21.85
Average Stack Temperature (measured)	Fs	°F	90.8	85.1	81.5
Average Meter Temperature (measured)	Fm	°F	92.8	85.6	76.0
Standard Pressure	Pstd	in.Hg	29.92	29.92	29.92
Barometric Pressure	Pbar	in.Hg	29.62	29.62	29.80
Stack Static Pressure	Pg	in.WC	-13.0	-13.0	-14.0
Average Meter Orifice Head (Delta-H)	dH	in.WC	2.53	2.67	2.61
Average RMS Velocity Head (Delta-P)	dP	in.WC	2.683	2.803	2.776
Pitot Coefficient	Cp	—	0.84	0.84	0.84
Net Volume of Gas Metered	Vm	cu.ft.	103.348	104.747	102.330
Dry Gas Meter Calibration Factor (gamma, Y)	Y	—	1.0395	1.0395	1.0395
NET Sampling Time	min	min.	120	120	120
Stack Gas: Oxygen Content*	O2,m	%	20.20	20.20	19.90
Carbon Dioxide Content*	CO2,m	%	<0.3	<0.3	<0.3
Total Impinger Gain	Ww	g	30.3	34.1	34.5
<b>CALCULATED DATA</b>					
Nozzle Area: $An = \pi/4 \cdot dn^2$	An	sq.in.	0.0235	0.0235	0.0235
Stack Area (round): $As = \pi/576 \cdot ds^2$ (rectangular): $As = L \cdot W/144$	As	sq.ft.	7.07	7.07	7.07
Absolute Stack Temperature: $Ts = Fs + 460$	Ts	°R	550.8	545.1	541.5
Absolute Meter Temperature: $Tm = Fm + 460$	Tm	°R	552.8	545.6	536.0
Standard Temperature: $Tstdr = Tstd + 460$	Tstdr	°R	528.0	528.0	528.0
Gas Sample Volume at Standard Conditions: $Vm(std) = Y \cdot (Vm/Tm) \cdot (Pbar + dH/13.6 \text{ in H}_2\text{O/in Hg}) \cdot (Tstdr/Pstd)$	VmStd	cu.ft.	102.228	105.003	105.037
Vol. of Water Vapor: $Vw(std) = Ww/453.59 \cdot Renglish/18 \cdot Tstdr / Pstd$	VwStd	cu.ft.	1.431	1.610	1.629
Moisture Fraction: $Bws = VwStd/(VmStd + VwStd)$	Bws	—	0.0138	0.015	0.0153
Stack Gas MW, Dry Basis: $Md = 0.32 \cdot O_{2,m} + 0.44 \cdot CO_{2,m} + 0.28 \cdot (100 - O_{2,m} - CO_{2,m})$	Md	g/mole	28.86	28.86	28.84
Stack Gas MW, Wet Basis: $Mw = Md \cdot (1 - Bws) + 18 \cdot Bws$	Mw	g/mole	28.71	28.69	28.68
Stack Pressure: $Ps = Pbar + Pg/13.6$	Ps	in.Hg	28.66	28.66	28.77
Stack Gas Velocity, measured $vs = 85.49 \cdot Cp \cdot \sqrt{(dP \cdot Ts / Ps \cdot Mw)}$ $vm = 0.3048 \text{ m/ft} \cdot vs$	vs vsm	ft/s m/s	96.25 29.34	97.88 29.84	96.92 29.54
Stack Gas Volumetric Flow Rate: $Q = 60 \cdot vs \cdot As$	Q	acfm	40,820	41,514	41,106
Stack Gas Volumetric Flow Rate, corrected: $Qsd = Q \cdot (1 - Bws) \cdot (Ps / Ts) \cdot (Tstdr / Pstd)$ $Qsdm = Qsd / 35.315$	Qsd Qsdm	dscfm dscmm	36,968 1,046.8	37,943 1,074.4	37,953 1,074.7
Isokinetic Sampling Rate: $I = 144 \cdot 100 \cdot Ts \cdot Vmstd \cdot Pstd / [60 \cdot Tstdr \cdot vs \cdot \text{min} \cdot An \cdot Ps \cdot (1 - Bws)]$	I	%	99.8	99.9	99.9

\*O2/CO2 was measured via SCAQMD Method 10.1 by GC.

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 2 (Upstream to Baghouse)

Run No.: 1  
 Test Date: 05/22/19  
 Times: 11:50 - 14:12

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-12	87	9.3	2.80	1.67	2.60		84
11	89	9.4	3.50	1.87	3.25		85
10	89	9.4	2.90	1.70	2.70		87
9	90	9.5	3.40	1.84	3.15		89
8	89	9.4	3.20	1.79	2.95		91
7	93	9.6	2.90	1.70	2.70		93
6	93	9.6	2.70	1.64	2.50		94
5	92	9.6	2.40	1.55	2.25		95
4	94	9.7	1.90	1.38	1.75		96
3	94	9.7	1.80	1.34	1.65		96
2	91	9.5	1.80	1.34	1.65		95
1	85	9.2	2.50	1.58	2.30		95
B-12	90	9.5	2.60	1.61	2.40		90
11	92	9.6	2.90	1.70	2.70		92
10	92	9.6	3.40	1.84	3.15		93
9	92	9.6	3.30	1.82	3.05		94
8	95	9.7	3.10	1.76	2.90		95
7	94	9.7	2.80	1.67	2.60		95
6	93	9.6	2.70	1.64	2.50		95
5	96	9.8	2.30	1.52	2.15		95
4	94	9.7	1.80	1.34	1.70		95
3	92	9.6	1.50	1.22	1.40		94
2	83	9.1	3.10	1.76	2.90		94
1	82	9.1	4.00	2.00	3.70		94
<b>Average:</b>		<b>90.8</b>		<b>2.6834</b>	<b>2.53</b>		<b>92.8</b>

DGM Reading (cu.ft.):	Final-1:	281.562	Impinger Weight (g):	#1 Final:	675.0
	Initial-1:	178.214		#1 Initial:	667.1
	Final-2:			#2 Final:	700.1
	Initial-2:			#2 Initial:	696.5
	Final-3:			#3 Final:	667.0
	Initial-3:			#3 Initial:	666.2
	Final-4:			#4 Final:	936.9
	Initial-4:			#4 Initial:	918.9
	Final-5:			#5 Final:	
	Initial-5:			#5 Initial:	
	NET Volume:	<b>103.348</b>		#6 Final:	
				#6 Initial:	
				#7 Final:	
				#7 Initial:	
				#8 Final:	
				#8 Initial:	
			<b>Total wt of impingers:</b>		<b>30.3</b>

**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 2 (Upstream to Baghouse)

Run No.: 2  
 Test Date: 05/22/19  
 Times: 14:38 - 16:50

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-12	92	9.6	2.60	1.61	2.40		88
11	93	9.6	3.30	1.82	3.05		89
10	92	9.6	3.50	1.87	3.25		90
9	88	9.4	3.20	1.79	2.95		91
8	88	9.4	3.00	1.73	3.75		91
7	88	9.4	2.80	1.67	2.80		90
6	86	9.3	2.70	1.64	2.50		91
5	86	9.3	2.10	1.45	1.95		91
4	88	9.4	1.90	1.38	1.60		90
3	88	9.4	1.80	1.34	1.65		91
2	82	9.1	3.10	1.76	2.90		91
1	82	9.1	3.80	1.95	3.50		90
B-12	82	9.1	2.75	1.66	2.55		82
11	82	9.1	3.40	1.84	3.15		82
10	84	9.2	3.50	1.87	3.25		82
9	84	9.2	3.10	1.76	2.90		81
8	84	9.2	3.10	1.76	2.90		81
7	84	9.2	2.90	1.70	2.70		81
6	84	9.2	2.65	1.63	2.45		81
5	83	9.1	2.00	1.41	1.85		81
4	83	9.1	1.85	1.36	1.70		81
3	80	8.9	1.90	1.38	1.75		80
2	80	8.9	3.20	1.79	2.95		80
1	80	8.9	4.00	2.00	3.70		80
<b>Average:</b>		<b>85.1</b>		<b>2.8033</b>	<b>2.67</b>		<b>85.6</b>

DGM Reading (cu.ft.):	Final-1:	386.610	Impinger Weight (g):	#1 Final:	767.9
	Initial-1:	281.863		#1 Initial:	758.6
	Final-2:			#2 Final:	766.3
	Initial-2:			#2 Initial:	762.6
	Final-3:			#3 Final:	644.0
	Initial-3:			#3 Initial:	641.6
	Final-4:			#4 Final:	791.3
	Initial-4:			#4 Initial:	772.6
	Final-5:			#5 Final:	
	Initial-5:			#5 Initial:	
NET Volume:		<b>104.747</b>		#6 Final:	
				#6 Initial:	
				#7 Final:	
				#7 Initial:	
				#8 Final:	
				#8 Initial:	
			<b>Total wt of impingers:</b>		<b>34.1</b>



**CARB METHOD 425 DATA AND CALCULATIONS**

Plant: AQMD Facility A  
 City: ██████████ CA  
 Source: Baghouse  
 Location: Inlet 2 (Upstream to Baghouse)

Run No.: 3  
 Test Date: 05/23/19  
 Times: 8:25 - 10:42

point	Stack Temp (°F)		Velocity Head (in.WC)		dH (in.WC)	DGM Temperature (°F)	
	Fs	sqrt (Fs)	dP	sqrt (dP)		Fm,in	Fm,out
A-12	86	9.3	2.60	1.61	2.40		67
11	86	9.3	2.60	1.61	2.40		68
10	85	9.2	3.40	1.84	3.15		71
9	86	9.3	3.20	1.79	2.95		72
8	84	9.2	3.10	1.76	2.90		73
7	84	9.2	3.10	1.76	2.90		74
6	84	9.2	2.90	1.70	2.70		75
5	84	9.2	2.40	1.55	2.25		76
4	82	9.1	2.20	1.48	2.05		77
3	82	9.1	1.80	1.34	1.65		77
2	76	8.7	2.20	1.48	2.05		78
1	73	8.5	3.80	1.95	3.50		78
B-12	79	8.9	2.40	1.55	2.25		74
11	79	8.9	3.60	1.90	3.45		76
10	82	9.1	3.30	1.82	3.05		78
9	81	9.0	3.50	1.87	3.25		78
8	81	9.0	3.40	1.84	3.15		79
7	83	9.1	3.20	1.79	3.00		79
6	84	9.2	3.20	1.79	3.00		79
5	82	9.1	2.45	1.57	2.25		79
4	82	9.1	2.10	1.45	1.95		79
3	82	9.1	1.70	1.30	1.60		79
2	79	8.9	2.40	1.55	2.25		79
1	71	8.4	2.80	1.67	2.60		79
<b>Average:</b>		<b>81.5</b>		<b>2.7757</b>	<b>2.61</b>		<b>76.0</b>

DGM Reading (cu.ft.):	Final-1: 489.310	Impinger Weight (g):	#1 Final: 678.6
	Initial-1: 386.980		#1 Initial: 669.4
	Final-2:		#2 Final: 701.2
	Initial-2:		#2 Initial: 696.8
	Final-3:		#3 Final: 668.7
	Initial-3:		#3 Initial: 666.9
	Final-4:		#4 Final: 939.2
	Initial-4:		#4 Initial: 920.1
	Final-5:		#5 Final:
	Initial-5:		#5 Initial:
NET Volume:	<b>102.330</b>		#6 Final:
			#6 Initial:
			#7 Final:
			#7 Initial:
			#8 Final:
			#8 Initial:
		<b>Total wt of impingers:</b>	<b>34.5</b>

**APPENDIX D2**

**CHROMIUM EMISSIONS (HEX/TOTAL) – FIELD DATA**


Location: Baghouse Outlet

Sampling Access

The exhaust test location was accessed via a man lift for one side of the exhaust.

For the others side, the facility installed a platform with guardrails that extends from the roof to the exhaust stack.

146 inches divided by 4, and then by 2  
 36.50 Div 4  
 18.25 Div 2  
 54.75 Sum  
 60 minutes at 5 minutes a point



9 Points Roof Side

12 Points Lot Side

Imp 1 pH 10  
Imp 2 pH 10

Run #	1	Pilot ID	16	Impinger #	Initial	Final	Net	Pilot Leak Check	
Date	5/22/14	Pilot Coeff.	.84	1	754.7	724.0		Initial	
Client	Facility A	Meter Box #	A-6	2	732.3	734.7		Final	
Unit	Outlet	Meter @ Dh	1789	3	673.5	677.3		Meter Box Leak Check	
Operator	CU	Meter Y	10776	4	874.1	824.0		Rate	"HG
Stack Dia		TC #	16	5				Initial	-000
Amb. Press	29.62	Start Time	1150	Nozzle Dia	H2O Gain =			Final	20"
Static Press	NA	Stop Time	1415	1.513	Filter :				

Reverse Points	Time (Minute)	Delta P (HG)	Stack Temp. (F)	Set delta H (HG)	Meter Volume (scf)	Mtr. Inlet Temp. (F)	Mtr. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (HG)
0	0	-	-	-	824.403	-	-	-	-	-	-	NA	-
1	7	.0256	89	1.81	929.531	79	79	NA	NA	54	5		
2	14	.0256	87	1.82	934.682	80	80			54	5		
3	21	.0256	91	1.81	939.829	82	82			54	5		
4	28	.0256	84	1.84	945.022	83	83			54	5		
5	35	.0256	89	1.83	950.198	84	84			55	5		
6	42	.0256	87	1.84	955.371	85	85			56	5		
7	49	.0256	84	1.85	960.610	86	86			56	5		
8	56	.0256	90	1.83	965.802	86	86	↓	↓	56	5	↓	
9	63	.0256	88	1.84	971.013	87	87	NA	NA	56	5	NA	
					971.310								
1	5	.0256	90	1.81	974.981	81	81	NA	NA	56	5	NA	
2	10	.0256	87	1.83	978.672	82	82			56	5		
3	15	.0256	84	1.84	982.371	82	82			56	5		
4	20	.0256	89	1.82	986.062	83	83			56	5		
5	25	.0256	86	1.83	989.760	83	83			56	5		
6	30	.0256	92	1.82	993.452	84	84			56	5		
7	35	.0256	88	1.83	997.160	85	85			56	5		
8	40	.0256	84	1.85	1000.881	85	85			56	5		
9	45	.0256	81	1.86	1004.602	85	85			56	5		
10	50	.0256	85	1.85	1008.332	86	86			56	5		
11	55	.0256	89	1.83	1012.041	86	86	↓	↓	56	5	↓	
12	60	.0256	87	1.84	1015.763	86	86	NA	NA	56	5	NA	

Addition  
 Lean Chain  
 19" A/C  
 1312

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: 27

Estimated O2: 20.7

Estimated CO2: 10.5

**Equipment Evaluation, OK? Y or N**

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Imp 1 pH 10  
Imp 2 pH 10

Run #: 2	Pilot ID: 16	Impinger #: 16	Initial: 753.6	Final: 763.3	Net:	Pilot Leak Check:
Date: 5/22/19	Pilot Coeff.: .89	Sodum bicarb	710.4	713.9		
Client: Facility A	Meter Box #: A-6		643.8	646.0		
Unit: Outlet	Meter @ Dh: 1.282		907.6	925.2		
Operator: CH	Meter Y: 1.0376					
Stack Dia:	TC #: 16					
Amb. Press: 29.62	Start Time: 1438	Nozzle Dia:	H2O Gain =			Meter Box Leak Check
Static Press: NA	Stop Time: 1653	Filter:				Rate: 1000
						THG: 24"
						Final: 1000
						23"

Traverse Points	Time (Minute)	Delta P (H2O)	Stack Temp. (F)	Set delta H (H2O)	Meter Volume (scf)	Mr. Inlet Temp. (F)	Mr. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vol. (mL)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
0	0	-	-	-	016.118	-	-	-	-	-	-	NA	-
1	5	.0256	87	1.81	019.781	78	78	NA	NA	54	5		
2	10	.0256	90	1.81	023.439	79	79			54	5		
3	15	.0256	85	1.82	027.112	79	79			54	5		
4	20	.0256	87	1.82	030.797	80	80			54	5		
5	25	.0256	89	1.82	034.468	81	81			55	5		
6	30	.0256	84	1.83	038.162	81	81			55	5		
7	35	.0256	86	1.82	041.837	80	80			55	5		
8	40	.0256	88	1.82	045.512	80	80			56	5		
9	45	.0256	85	1.83	049.190	80	80			56	5		
10	50	.0256	89	1.81	052.853	79	79			56	5		
11	55	.0256	87	1.82	056.521	79	79	↓	↓	56	5	↓	
12	60	.0256	85	1.82	060.203	77	77	NA	NA	56	5	NA	
					061.114								
1	7	.0256	89	1.79	066.191	74	74	NA	NA	54	5	NA	
2	14	.0256	87	1.80	071.272	73	73			54	5		
3	21	.0256	84	1.81	076.371	74	74			54	5		
4	28	.0256	88	1.80	081.452	74	74			54	5		
5	35	.0256	86	1.81	086.553	75	75			54	5		
6	42	.0256	89	1.80	091.642	75	75			54	5		
7	49	.0256	85	1.81	096.751	75	75			54	5		
8	56	.0256	87	1.81	101.858	76	76	↓	↓	54	5	↓	
9	63	.0256	87	1.80	106.962	76	76	NA	NA	54	5	NA	

1459  
 22" Addition Leak  
 .000 Rate  
 CHG OK

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: 2%

Estimated O2: 20.7

Estimated CO2: .05

**Equipment Evaluation, OK? Y or N**

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Flows Based on the 2 inches combined

Imp 1 pH 10  
Im " 10

Run #	3	Pilot ID	16	Impinger #	Initial	Final	Net	Pilot Leak Check	
Date	5-23-19	Pilot Coeff.	.84	1	754.2	764.1		Initial	NA NA
Client	Facility A	Meter Box #	A-6	2	735.1	738.8		Final	NA NA
Unit	Outlet	Meter @ Dh	1.789	3	674.8	676.7		Meter Box Leak Check	
Operator	CH	Meter Y	1.0726	4	875.7	893.1		Rate	"HG
Stack Dia		TC #	16	5				Initial	.022 21"
Amb. Press	29.30	Start Time	0825	Nozzle Dia	H2O Gain =			Final	.000 23"
Static Press	NA	Stop Time	1045	.513	Filter:				

Traverse Points	Time (Minute)	Delta P (H2O)	Stack Temp. (F)	Set delta H (H2O)	Meter Volume (scf)	Mt. Inlet Temp. (F)	Mt. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
0	0	-	-	-	107.242	-	-	NA	NA	-	-	NA	
1	5	.0251	91	1.72	110.751	63	63			54	5		
2	10	.0251	87	1.73	114.272	64	64			54	5		
3	15	.0251	84	1.75	117.823	66	66			54	5		
4	20	.0251	89	1.73	121.358	67	67			54	5		
5	25	.0251	86	1.75	124.912	68	68			54	5		
6	30	.0251	83	1.76	128.481	69	69			54	5		
7	35	.0251	88	1.75	132.042	70	70			54	5		
8	40	.0251	85	1.76	135.612	70	70			54	5		
9	45	.0251	89	1.75	139.183	72	72			55	5		
10	50	.0251	87	1.76	142.758	73	73			55	5		
11	55	.0251	84	1.77	146.353	73	73	↓	↓	55	5	↓	
12	60	.0251	86	1.77	149.942	74	74	NA	NA	55	5	NA	
					150.511								
1	7	.0251	79	1.77	155.521	69	69	NA	NA	54	5	NA	
2	14	.0251	84	1.76	160.523	70	70			54	5		
3	21	.0251	89	1.75	165.512	71	71			54	5		
4	28	.0251	87	1.76	170.529	73	73			54	5		
5	35	.0251	91	1.75	175.532	74	74			54	5		
6	42	.0251	85	1.77	180.573	75	75			54	5		
7	49	.0251	89	1.76	185.602	75	75			54	5		
8	56	.0251	89	1.76	190.630	75	75	↓	↓	54	5	↓	
9	63	.0251	86	1.77	195.671	75	75	NA	NA	55	5	NA	

Additional Tech  
100 Read Chart  
0942

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: 2%

Estimated O2: 20.9

Estimated CO2: 0.5

**Equipment Evaluation, OK? Y or N**

Ambient Temp: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

**Location: Inlet 1 (Inside)**



**SAMPLING AND VELOCITY TRAVERSE POINT DETERMINATION  
SCAQMD METHOD 1.2**

CLIENT: AQMD Facility A  
 PLANT NAME: Metal Melting Facility  
 CITY, STATE: ██████████ CA  
 SAMPLING LOCATION: Inlet Furnace  
 TYPE OF TESTING: Metals & Particulate

NO. OF PORTS AVAILABLE: 2  
 NO. OF PORTS TO BE USED: 2  
 PORT INSIDE DIAMETER: 3 inches

DISTANCE FROM FAR WALL TO OUTSIDE OF PORT: 13.50 inches  
 NIPPLE LENGTH AND/OR WALL THICKNESS: 3.50 inches  
 DEPTH OF STACK OR DUCT, D: 10.00 inches  
 STACK OR DUCT WIDTH (IF RECTANGULAR), W: #N/A inches


EQUIVALENT DIAMETER  
 $De = 2 * (DEPTH) * (WIDTH) / (DEPTH + WIDTH) =$

STACK/DUCT AREA = 0.55 sq.feet

DISTANCE OF TEST PORT LOCATION:	DOWNSTREAM	UPSTREAM
	FROM FLOW	FROM FLOW
	DISTURBANCE	DISTURBANCE
	B	A
# OF INCHES	25.00	16.50
# OF DIAMETERS	2.50	1.65

MINIMUM NUMBER OF TRAVERSE POINTS: 24

POINT NO.	% OF DUCT DEPTH	DISTANCE FROM INSIDE WALL (in.)	DISTANCE FROM OUTSIDE OF PORT (in.)
1	2.1	0.50	4
2	6.7	0.67	4 1/8
3	11.8	1.18	4 5/8
4	17.7	1.77	5 1/4
5	25.0	2.50	6
6	35.6	3.56	7
7	64.4	6.44	10
8	75.0	7.50	11
9	82.3	8.23	11 3/4
10	88.2	8.82	12 3/8
11	93.3	9.33	12 7/8
12	97.9	9.50	13



DRAWING NOT TO SCALE

Imp 1 pH 10  
Imp 2

Run #	1	85 Pitot ID:	A-7	Impinger #	Initial	Final	Net	Pilot Leak Check	
Date	5/27/19	Pilot Coeff.:	1.84	1T	751.1	755.6		Initial:	<input checked="" type="checkbox"/>
Client	Facility A	Meter Box #:	A-7	NAMES 2	749.5	753.2		Final:	<input checked="" type="checkbox"/>
Unit	Inlet 1 (Inside)	Meter @ Dh:	1.736		651.2	653.8		Meter Box Leak Check	
Operator	T. TA	Meter Y:	1.024		804.5	820.9		Rate	7HG
Stack Dia	10	TC #:	85		805			Initial:	0.008 21.0
Amb. Press:	29.62	Start Time:	1150	Nozzle Dia	H2O Gain =			Final:	0.012 22.0
Static Press:	-14.30	Stop Time:	1412	.180	Filter:				

TOP

Traverse Points	Time (Minute)	Delta P (H2O)	Stack Temp (F)	Stat delta H (H2O)	Meter Volume (scf)	Mtr. Inlet Temp (F)	Mtr. Outlet Temp (F)	Oven Temp (F)	Probe Temp (F)	Impinger Temp (F)	Pump Vac (7HG)	TE Cooler Temp (F)	Cyclonic Flow (H2O)
0	0				539.52								
A-1	5	2.7	117	2.63	544.08	90	90	NA	NA	57	5.50		
	2.10	3.0	126	2.88	548.88	91	91			53	5.50		
	3.15	2.60	144	2.43	553.30	92	92			52	5.50		
	4.20	2.60	140	2.45	557.74	94	94			54	5.50		
	5.25	2.50	128	2.41	562.12	95	95			54	5.50		
	6.30	2.8	166	2.54	566.60	96	96			55	6.0		
	7.40	3.30	193	2.87	571.40	96	96			54	6.0		
	8.45	3.50	139	3.33	576.62	98	98			54	7.0		
	9.50	3.20	154	2.92	581.48	98	98			55	7.0		
	10.55	2.90	173	2.62	586.11	99	99			56	6.50		
	11.55	2.60	190	2.29	590.42	100	100			55	6.0		
	12.60	2.20	142	2.09	594.57	100	100			56	6.0		stop @ 1250
B-1	65	3.30	148	3.08	599.54	95	95			58	7.0		start @ 1312
	2.70	3.20	175	2.86	604.35	96	96			53	7.0		
	3.75	3.20	144	3.02	609.21	98	98			53	7.0		
	4.80	3.30	137	3.16	614.24	99	99			54	7.50		
	5.85	3.10	178	2.78	619.03	100	100			53	7.0		
	6.90	3.40	169	3.10	624.05	101	101			53	7.0		
	7.95	2.0	123	1.97	628.11	101	101			54	6.50		
	8.100	2.10	152	1.97	632.06	102	102			54	6.50		
	9.105	1.90	144	1.80	635.90	101	101			55	6.0		
	10.110	1.70	157	1.58	639.45	101	101			56	6.0		
	11.115	1.30	162	1.20	642.60	101	101			56	5.50		
	12.120	1.10	161	1.01	645.510	100	100			54	5.0		
In to out 12													

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: \_\_\_\_\_

Estimated O2: \_\_\_\_\_

Estimated CO2: \_\_\_\_\_

Equipment Evaluation, OK? Y or N

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pitot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Imp 1 pH 10  
Imp 2 " 10

Run #: 2	Pilot ID: 85	Impinger #: 1	Initial: 762.6	Final: 770.8	Net:	Pilot Leak Check	
Date: 5/22/19	Pilot Coeff.: 1.84	Impinger #: 2	Initial: 640.0	Final: 643.5	Net:	Initial:	<input checked="" type="checkbox"/>
Client: Facility A	Meter Box #: A-7	Impinger #: 3	Initial: 655.7	Final: 656.6	Net:	Final:	<input checked="" type="checkbox"/>
Unit: Inlet 1 (inside)	Meter @ Dh: 1.736	Impinger #: 4	Initial: 844.0	Final: 860.0	Net:	Meter Box Leak Check	
Operator: T-74	Meter Y: 1.0274	Impinger #: 5	H2O Gain =		Initial:	Rate: 3.010	%G: 22.0
Stack Dia: 10.0	TC #: 85	Nozzle Dia: 1.80	Filter:		Final:	3.009	20.0
Amb. Press: 29.62	Start Time: 1438						
Static Press: -14.3	Stop Time: 1650						

TOP

SIDE

Traverse Points	Time (Minute)	Delta P (H2O)	Stack Temp (F)	Set delta H (H2O)	Meter Volume (scf)	Mt. Inlet Temp (F)	Mt. Outlet Temp (F)	Oven Temp (F)	Probe Temp (F)	Impinger Temp (F)	Pump Vac. (HG)	TE Cooler Temp (F)	Cyclonic Flow (H2O)
0	0				646.08								
A-1	5	2.40	186	2.09	650.20	92	92	NA	NA	5.0	55		
2	10	2.50	168	2.25	654.41	94	94			5.0	50		
3	15	2.50	143	2.35	658.74	94	94			5.0	51		
4	20	2.70	124	2.63	663.35	96	96			6.0	52		
5	25	2.80	117	2.76	668.07	96	96			6.0	52		
6	30	2.70	115	2.67	672.74	97	97			6.0	53		
7	35	3.80	130	3.38	677.72	98	98			7.0	52		
8	40	3.20	138	3.05	682.70	98	98			7.0	52		
9	45	3.50	145	3.30	687.80	98	98			8.0	53		
10	50	3.40	123	2.35	692.22	99	99			8.0	53		
11	55	2.30	150	1.98	696.03	99	99			7.0	54		
12	60	1.80	147	1.69	699.74	98	98			6.50	54	stop @ 1538	
B-1	65	3.50	153	3.21	704.80	91	91			7.50	57	start @ 1550	
2	70	3.40	150	3.14	709.74	91	91			7.0	51		
3	75	3.30	148	3.06	714.68	92	92			7.0	52		
4	80	3.30	147	3.07	719.65	92	92			7.0	52		
5	85	3.40	145	3.17	724.63	92	92			7.50	53		
6	90	3.40	144	3.17	729.69	92	92			7.50	53		
7	95	2.10	137	1.98	733.74	92	92			6.0	54		
8	100	1.9	135	1.80	737.50	91	91			6.0	53		
9	105	1.50	129	1.43	740.94	90	90			5.0	52		
10	110	1.30	124	1.25	744.10	90	90			5.0	53		
11	115	1.20	117	1.17	747.21	90	90			5.0	53		
12	120	1.0	110	.98	749.08	89	89				53		

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: \_\_\_\_\_

Estimated O2: \_\_\_\_\_

Estimated CO2: \_\_\_\_\_

Equipment Evaluation, OK? Y or N

Ambient Temp: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Imp 1 pH 10  
Imp 2 10

Run #: 3	Pilot ID: 85	Impinger #	Initial	Final	Net	Pilot Leak Check
Date: 05/23/19	Pilot Coeff.: .84	2	751.6	753.4		Initial: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>
Client: Facility A	Meter Box #: A-7	3	749.9	737.4		Final: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>
Unit: Inlet 1 (Inside)	Meter @ Oh: 1.736	4	652.9	672.9		Meter Box Leak Check
Operator: T. T. T.	Meter Y: 1.027	5	833.6	853.4		Rate
Stack Dia: 10.0	TC #: 25	H2O Gain =				7HG
Amb. Press: 14.29.80	Start Time: 0825	Nozzle Dia	Filter:			Initial: 0.007 19.0
Static Press: -14.20	Stop Time: 1042					Final: 0.012 21.0

T1  
TOP

Travel Points	Time (Minutes)	Delta P (inH2O)	Stack Temp. (F)	Set Delta P (inH2O)	Meter Volume (scf)	Mt. Inlet Temp. (F)	Mt. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (inHg)	TE Cooler Temp. (F)	Cyclonic Flow (inH2O)
A-B 0					751.05								
1	5	2.60	184	2.24	755.25	84	84	NA	NA	58	4.50		
2	10	2.50	185	2.16	759.41	86	86			54	4.50		
3	15	2.50	145	2.14	763.20	87	87			55	5.0		
4	20	2.30	140	2.15	767.48	89	89			55	5.0		
5	25	2.60	131	2.47	771.94	90	90			56	6.50		
6	30	2.70	110	2.67	776.50	91	91			56	8.0		
7	35	3.40	128	3.26	781.62	92	92			56	11.0		
8	40	3.6	117	3.53	786.40	93	93			57	12.0		
9	45	3.30	113	3.25	791.94	93	93			57	10.0		
10	50	2.70	114	2.66	796.56	94	94			58	9.50		
11	55	2.50	135	2.37	800.84	93	93			56	9.0		
12	60	1.70	126	1.64	804.48	93	93			55	7.0		stop @ 0925 start @ 0942
13	65	2.80	121	2.69	809.10	86	86			56	9.50		
14	70	3.40	103	3.38	814.25	87	87			51	10.50		
15	75	3.50	136	3.29	819.30	88	88			48	11.0		
16	80	3.30	106	3.27	824.41	89	89			50	11.0		
17	85	3.20	159	2.91	829.18	90	90			51	11.0		
18	90	3.40	132	3.23	834.30	91	91			53	11.0	T.T	12.0
19	95	2.70	147	2.50	838.74	91	91			53	10.5		
20	100	2.40	123	2.32	843.08	91	91			53	10.0		
21	105	2.20	117	2.15	847.20	91	91			52	10.0		
22	110	2.10	115	2.06	851.17	91	91			52	10.0		
23	115	1.70	105	1.69	854.87	90	90			52	9.0		
24	120	1.30	109	1.28	858.118	90	90			53	8.0		
In to out 12													

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: \_\_\_\_\_

Estimated O2: \_\_\_\_\_

Estimated CO2: \_\_\_\_\_

Equipment Evaluation, OK? Y or N

Ambient Temp: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Teflon Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Location: Inlet 2 (downstream/outside)

**SAMPLING AND VELOCITY TRAVERSE POINT DETERMINATION  
SCAQMD METHOD 1.1**

CLIENT: AQMD Facility A  
 PLANT NAME: Metal Molding Facility  
 CITY, STATE: ██████████, CA  
 SAMPLING LOCATION: Inlet 2 (Upstream of Baghouse)  
 TYPE OF TESTING: Metals/Particulate

NO. OF PORTS AVAILABLE: 1  
 NO. OF PORTS TO BE USED: 1  
 PORT INSIDE DIAMETER: 2.5 inches

DISTANCE FROM FAR WALL TO OUTSIDE OF PORT: 38.00 inches  
 NIPPLE LENGTH AND/OR WALL THICKNESS: 2.00 inches  
 DEPTH OF STACK OR DUCT, D: 36.00 inches  
 STACK OR DUCT WIDTH (IF RECTANGULAR), W: #N/A inches


EQUIVALENT DIAMETER  
 $De = 2*(DEPTH)*(WIDTH)/(DEPTH+WIDTH) = 36.00$  inches

STACK/DUCT AREA = 7.07 sq.feet 1017.9 sq.inches

	<b>DISTANCE OF TEST PORT LOCATION:</b>	<b>DOWNSTREAM</b>	<b>UPSTREAM</b>
		<b>FROM FLOW</b>	<b>FROM FLOW</b>
		<b>DISTURBANCE</b>	<b>DISTURBANCE</b>
		B	A
	# OF INCHES	87.00	48.50
	# OF DIAMETERS	2.42	1.35

MINIMUM NUMBER OF TRAVERSE POINTS: 24

POINT NO.	% OF DUCT DEPTH	DISTANCE FROM INSIDE WALL (in.)	DISTANCE FROM OUTSIDE OF PORT (in.)
1	2.1	0.76	2 3/4
2	6.7	2.41	4 3/8
3	11.8	4.25	6 1/4
4	17.7	6.37	8 3/8
5	25.0	9.00	11
6	35.6	12.82	14 7/8
7	64.4	23.18	25 1/8
8	75.0	27.00	29
9	82.3	29.63	31 5/8
10	88.2	31.75	33 3/4
11	93.3	33.59	35 5/8
12	97.9	35.24	37 1/4



DRAWING NOT TO SCALE

Imp 1 pH 10  
Imp 2

Run #: 1	Pitot ID: 31	Impinger #	Initial	Final	Net	Pitot Leak Check	
Date: 5/22/19	Pitot Coeff.: 0.84	1	667.1	675.0		Initial: X	X
Client: Facility A	Meter Box #: A-2	2	696.5	700.1		Final: X	X
Unit: Inlet 2 (Outside)	Meter @ Dh: 1.834	3	666.2	667.0			
Operator: MN	Meter Y: 1.0395	4	2.18.9	936.9			
Stack Dia: 36.0	TC #: 31	5					
Amb. Press: 29.62	Start Time: 1150	Nozzle Dia	H2O Gain =			Meter Box Leak Check	
Static Press: -13	Stop Time: 1412	0.173	Filter:			Rate	"HG
						Initial: 28.00	22
						Final: 6.00	15

13/2

Traverse Points	Time (Minute)	Delta P ("H2O)	Stack Temp. (F)	Set delta H ("H2O)	Meter Volume (scf)	Mr. Inlet Temp. (F)	Mr. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. ("HG)	TE Cooler Temp. (F)	Cyclonic Flow ("H2O)
12	0	2.83	87	2.6	178.214	84	NA	NA	NA	49	7.0	NA	410
11	5.0	3.50	89	3.23	182.62	85				47	9.0		
10	10.0	2.90	89	2.70	187.49	87				52	7.0		
9	15.0	3.40	90	3.15	191.91	89				52	7.0		
8	20.0	3.20	89	2.95	196.67	89				51	7.0		
7	25.0	2.90	93	2.70	201.38	93				51	7.0		
6	30.0	2.70	93	2.50	205.92	94				50	7.0		
5	35.0	2.40	92	2.25	210.26	95				51	7.0		
4	40.0	2.90	94	1.75	214.33	96				51	7.0		
3	45.0	1.80	94	1.65	218.00	96				51	7.0		
2	50.0	1.80	91	1.65	221.56	95				52	7.0		
1	55.0	2.50	85	2.30	225.00	95				52	7.0		
0	60.0	2.60	90	2.40	229.15	90				53	7.0		
12	65.0	2.90	92	2.70	233.31	92				49	7.0		
11	70.0	3.40	92	3.15	237.72	93				52	7.0		
10	75.0	3.30	92	3.05	242.61	94				52	7.0		
9	80.0	3.10	95	2.90	247.36	95				53	7.0		
8	85.0	2.8	94	2.60	252.08	95				52	7.0		
7	90.0	2.7	93	2.5	256.51	95				52	7.0		
6	95.0	2.3	96	2.15	260.88	95				51	7.0		
5	100.0	1.80	94	1.70	264.82	95				51	7.0		
4	105.0	1.50	92	1.40	268.34	94				51	7.0		
3	110.0	3.1	83	2.9	271.61	94				51	7.0		
2	115.0	4.0	82	3.7	276.23	94				51	7.0		
1	120.0				281.56								

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp: 90

Estimated Stack Temp: 85

Estimated Delta P: 2.97

Estimated Moisture Content: 2.0

Estimated O2: 10.5

Estimated CO2: 0.5

Equipment Evaluation, OK? Y or N

Ambient Temp: X

TC Check: X

Pitot Check: X

Tedlar Bag: X/A

Pitot Exp Date:

TC Exp Date:

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Run #: <u>2</u>	Pilot ID: <u>31</u>	Impinger #: <u>NA</u>	Initial	Final	Net	Pilot Leak Check
Date: <u>5/22/19</u>	Pilot Coeff.: <u>0.84</u>	Meter Box #: <u>A-8</u>	<u>758.6</u>	<u>767.9</u>		Initial:
Client: <u>Facility A</u>	Meter @ Dh: <u>1.834</u>	Meter Y: <u>1.0395</u>	<u>762.6</u>	<u>766.3</u>		Final:
Unit: <u>Inlet (outside)</u>	TC #: <u>31</u>	Start Time: <u>1438</u>	<u>641.6</u>	<u>644.0</u>		Meter Box Leak Check
Operator: <u>MN</u>	Stop Time: <u>1650</u>	Nozzle Dia: <u>.173</u>	<u>712.6</u>	<u>791.3</u>		Rate
Stack Dia: <u>36.0</u>		H2O Gain =				"HG
Amb. Press: <u>29.62</u>		Filter:				Initial:
Static Press: <u>-13</u>						Final:

Time Points	Time (Minute)	Delta P (H2O)	Stack Temp. (F)	Sol delta H (H2O)	Meter Volume (scf)	Mr. Inlet Temp. (F)	Mr. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
12	0	2.60	92	2.40	281.863	88	NA	NA	NA	55	6.0	NA	410
11	5.0	3.30	93	3.05	286.09	89	NA	NA	NA	50	6.0	NA	410
10	10.0	3.50	92	3.25	290.83	90	NA	NA	NA	52	6.0	NA	410
9	15.0	3.20	88	3.28	295.83	91	NA	NA	NA	54	6.0	NA	410
8	20.0	3.00	88	3.75	300.55	91	NA	NA	NA	54	6.0	NA	410
7	25.0	2.80	88	2.8	305.07	90	NA	NA	NA	54	6.0	NA	410
6	30.0	2.70	86	2.5	309.44	91	NA	NA	NA	54	6.0	NA	410
5	35.0	2.10	86	1.95	313.78	91	NA	NA	NA	54	6.0	NA	410
4	40.0	1.90	88	1.60	317.56	90	NA	NA	NA	54	6.0	NA	410
3	45.0	1.80	88	1.65	321.23	91	NA	NA	NA	54	6.0	NA	410
2	50.0	3.10	82	2.90	324.83	91	NA	NA	NA	54	6.0	NA	410
1	55.0	3.80	82	3.50	329.35	90	NA	NA	NA	55	6.0	NA	410
0	60.0	3.75	82	2.55	334.56	82	NA	NA	NA	48	6.0	NA	410
12	65.0	3.40	82	3.15	338.91	82	NA	NA	NA	48	6.0	NA	410
11	70.0	3.50	84	3.25	343.56	82	NA	NA	NA	48	6.0	NA	410
10	75.0	3.10	84	2.90	348.02	81	NA	NA	NA	48	6.0	NA	410
9	80.0	3.10	84	2.90	352.96	81	NA	NA	NA	48	6.0	NA	410
8	85.0	2.90	84	2.70	357.54	81	NA	NA	NA	49	6.0	NA	410
7	90.0	2.65	84	2.45	362.00	81	NA	NA	NA	50	6.0	NA	410
6	95.0	2.00	83	1.95	366.25	81	NA	NA	NA	50	6.0	NA	410
5	100.0	1.85	83	1.70	369.82	81	NA	NA	NA	50	6.0	NA	410
4	105.0	1.90	80	1.75	373.34	80	NA	NA	NA	50	6.0	NA	410
3	110.0	3.2	80	2.95	376.95	80	NA	NA	NA	51	6.0	NA	410
2	115.0	4.0	80	3.70	381.45	80	NA	NA	NA	51	6.0	NA	410
1	120.0				386.61		NA	NA	NA			NA	410

restoration  
1550

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: \_\_\_\_\_

Estimated O2: \_\_\_\_\_

Estimated CO2: \_\_\_\_\_

**Equipment Evaluation, OK? Y or N**

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						



ISOKINETIC DATA FORM, TE COOLER & CYCLONIC FLOW

METH **Almega**  
ENVIRONMENTAL

Imp 1 pit 10  
Iw-2 pit 10

Run #: 2	Pilot ID: 21	Impinger #	Initial	Final	Net	Pilot Leak Check
Date: 5-23-19	Pilot Coeff.: 0.84	1	669.4	678.6		Initial: 20 20
Client: Facility A	Meter Box #: A-8	2	696.8	701.2		Final: 20 20
Unit: Inlet (outside)	Meter @ Dh: 1.834	3	666.9	668.7		
Operator: MN	Meter Y: 1.0395	4	920.1	939.2		
Stack Dia: 36.0	TC #: 21	5				
Amb. Press: 29.8	Start Time: 8:25	Nozzle Dia: H2O Gain =				Meter Box Leak Check
Static Press: -14	Stop Time: 10:42	Filter:				Rate: 0.000 14
						Final: 0.000 18

Traverse Points	Time (Minute)	Delta P (inH2O)	Stack Temp. (F)	Set delta H (inH2O)	Meter Volume (scf)	Mir. Inlet Temp. (F)	Mir. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (inHG)	TE Cooler Temp. (F)	Cyclonic Flow (inH2O)
17	0.0	2.60	86	2.4	386.98	NA	67	NA	NA	48	5.0	NA	<10
11	5.0	2.60	86	2.4	391.06		68			48	5.0		
10	10.0	2.40	85	3.15	395.00		71			49	8.0		
9	15.0	3.20	86	2.95	390.7		72			51	8.0		
8	20.0	3.10	84	2.90	404.25		73			54	7.0		
7	25.0	3.10	84	2.90	408.62		74			55	7.0		
6	30.0	2.90	84	2.70	413.18		75			58	6.0		
5	35.0	2.40	84	2.25	417.46		76			58	6.0		
4	40.0	2.20	82	2.05	421.38		77			58	4.0		
3	45.0	1.80	82	1.65	425.18		77			56	4.0		
2	50.0	2.20	76	2.05	428.64		78			56	4.0		
1	55.0	3.80	73	3.50	432.50	↓	78	↓	↓	56	8.0	↓	↓
0	60.0	2.40	79	2.25	437.61	NA	74	NA	NA	54	5.0	NA	<10
12	65.0	3.60	79	3.45	441.63		76			52	8.0		
11	70.0	3.30	82	3.05	446.44		78			54	6.0		
10	75.0	3.50	81	2.95	451.11		78			54	5.0		
9	80.0	3.40	81	3.15	455.92		79			54	5.0		
8	85.0	3.20	83	3.0	460.60		79			54	5.0		
7	90.0	3.20	84	3.0	465.22		79			54	6.0		
6	95.0	2.45	82	2.25	469.79		79			54	5.0		
5	100.0	2.10	82	1.95	473.89		79			55	5.0		
4	105.0	1.70	82	1.60	477.65		79			55	5.0		
3	110.0	2.4	79	2.25	481.00		79			55	5.0		
2	115.0	2.8	71	2.60	485.00	↓	79	↓	↓	55	5.0	↓	↓
1	120.0				489.31								

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp: 90  
 Estimated Stack Temp: 85  
 Estimated Delta P: 2.8  
 Estimated Moisture Content: 2.07%  
 Estimated O2: 70.7%  
 Estimated CO2: 0.5%

Equipment Evaluation, OK? Y or N

Ambient Temp.: 65  
 TC Check: X  
 Pilot Check: X  
 Tedlar Bag: N/A  
 Pilot Exp Date:  
 TC Exp Date:

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						



**APPENDIX D3**

**CHROMIUM EMISSIONS (HEX/TOTAL) – LABORATORY DATA**

			Hex Chrome			Total Chrome		
			Inlet 1 Inside	Inlet 2 Outside	Outlet	Inlet 1	Inlet 2	Outlet
Run 1	Rinse	C1 ug	6.5	1.2	< 0.011	11	2.7	< 1
	Impingers	C2 ug	52	3.1	0.035	270	11	< 1
	<b>Total</b>	<b>ug</b>	<b>58.5</b>	<b>4.3</b>	<b>&lt; 0.046</b>	<b>281</b>	<b>13.7</b>	<b>&lt; 2</b>
Run 2	Rinse	C1 ug	1.7	0.21	< .010	3.9	1.5	< 1
	Impingers	C2 ug	2.1	0.31	0.032	51	3.6	< 1
	<b>Total</b>	<b>ug</b>	<b>3.8</b>	<b>0.52</b>	<b>&lt; 0.042</b>	<b>54.9</b>	<b>5.1</b>	<b>&lt; 2</b>
Run 3	Rinse	C1 ug	2.5	0.94	< 0.050	6.1	2.7	< 1
	Impingers	C2 ug	21	2.1	< 0.022	340	19	< 1
	<b>Total</b>	<b>ug</b>	<b>23.5</b>	<b>3.04</b>	<b>&lt; 0.072</b>	<b>346.1</b>	<b>21.7</b>	<b>&lt; 2</b>
Run FB	Rinse	C1 ug		< 0.010			< 1	
	Impingers	C2 ug		0.022			< 1	
	<b>Total</b>	<b>ug</b>		<b>&lt; 0.032</b>			<b>&lt; 2</b>	

Work Orders: 9E30014

Report Date: 6/24/2019

Project: In (I)/In (O)/Out

Received Date: 5/29/2019

Turnaround Time: Normal

Phones: (714) 889-4000

Fax: (714) 889-7030

P.O. #: 10562

Billing Code:

Attn: Almaga Environmental & Technical Services

Client: Almaga Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630


ELAP-CA #1132 • EPA-UCMR #CA00211 • Guam-EPA #17-008R • HW-DOH # • ISO 17025 #L2457.01 • LACSD #10143 •  
NELAP-CA #04229CA • NELAP-OR #4047 • NJ-DEP #CA015 • NV-DEP #NAC 445A • SCAQMD #93LA1006

*This is a complete final report. The information in this report applies to the samples analyzed in accordance with the chain-of-custody document. Weck Laboratories certifies that the test results meet all requirements of TNI unless noted by qualifiers or written in the Case Narrative. This analytical report must be reproduced in its entirety.*

Dear Almaga Environmental & Technical Services,


Enclosed are the results of analyses for samples received 5/29/19 with the Chain-of-Custody document. The samples were received in good condition, at 4.7 °C and on ice. All analyses met the method criteria except as noted in the case narrative or in the report with data qualifiers.

Reviewed by:



Brandon Gee  
Operations Manager/Senior PM





WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL

Project Number: In (I)/In (O)/Out

Reported:  
06/24/2019 14:29


Project Manager: Almega Environmental & Technical Services

## Sample Summary

Sample Name	Sampled By	Lab ID	Matrix	Sampled	Qualifiers
10562 - M425 - C1 - In(O) - FB	Client	9E30014-01	Filter	05/22/19 10:30	
10562 - M425 - C2 - In(O) - FB	Client	9E30014-02	Filter	05/22/19 10:30	
10562 - M425 - C1 - In(I) - R1	Client	9E30014-03	Filter	05/22/19 11:50	
10562 - M425 - C2 - In(I) - R1	Client	9E30014-04	Filter	05/22/19 11:50	
10562 - M425 - C1 - In(O) - R1	Client	9E30014-05	Filter	05/22/19 11:50	
10562 - M425 - C2 - In(O) - R1	Client	9E30014-06	Filter	05/22/19 11:50	
10562 - M425 - C1 - Out - R1	Client	9E30014-07	Filter	05/22/19 11:50	
10562 - M425 - C2 - Out - R1	Client	9E30014-08	Filter	05/22/19 11:50	
10562 - M425 - C1 - In(I) - R2	Client	9E30014-09	Filter	05/22/19 14:38	
10562 - M425 - C2 - In(I) - R2	Client	9E30014-10	Filter	05/22/19 14:38	
10562 - M425 - C1 - In(O) - R2	Client	9E30014-11	Filter	05/22/19 14:38	
10562 - M425 - C2 - In(O) - R2	Client	9E30014-12	Filter	05/22/19 14:38	
10562 - M425 - C1 - Out - R2	Client	9E30014-13	Filter	05/22/19 14:38	
10562 - M425 - C2 - Out - R2	Client	9E30014-14	Filter	05/22/19 14:38	
10562 - M425 - C1 - In(I) - R3	Client	9E30014-15	Filter	05/23/19 08:25	
10562 - M425 - C2 - In(I) - R3	Client	9E30014-16	Filter	05/23/19 08:25	
10562 - M425 - C1 - In(O) - R3	Client	9E30014-17	Filter	05/23/19 08:25	
10562 - M425 - C2 - In(O) - R3	Client	9E30014-18	Filter	05/23/19 08:25	
10562 - M425 - C1 - Out - R3	Client	9E30014-19	Filter	05/23/19 08:25	
10562 - M425 - C2 - Out - R3	Client	9E30014-20	Filter	05/23/19 08:25	
AQMD Facility A - M425 - RB	Client	9E30014-21	Filter	05/23/19 11:30	
AQMD Facility A - M425 - RB - Filter	Client	9E30014-22	Filter	05/23/19 11:30	

## Analyses Accreditation Summary

Analyte	CAS #	Not By NELAP	By ANAB
<b>CARB 425 in Filter</b> Chromium 6+	18540-29-9	✓	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

Almega REPORT  
ENVIRONMENTAL

Project Number: In (I)/In (O)/Out

Reported:  
06/24/2019 14:29

Project Manager: Almega Environmental & Technical Services

## Sample Results

Sample: 10562 - M425 - C1 - In(O) - FB  
9E30014-01 (Filter) Sampled: 05/22/19 10:30 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	ND	1.0	ug/filter	5	06/12/19 15:36	M-04

Sample: 10562 - M425 - C1 - In(O) - FB  
9E30014-01RE1 (Filter) Sampled: 05/22/19 10:30 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Hexavalent Chromium by IC</b>						
Method: CARB 425	Batch ID: W9F0369	Instr: LC13	Prepared: 06/06/19 11:40	Analyst: jna		
Chromium 6+	ND	0.010	ug/filter	1	06/06/19 13:49	O-12

Sample: 10562 - M425 - C2 - In(O) - FB  
9E30014-02 (Filter) Sampled: 05/22/19 10:30 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	ND	1.0	ug/filter	5	06/12/19 14:53	M-04


Sample: 10562 - M425 - C2 - In(O) - FB  
9E30014-02RE1 (Filter) Sampled: 05/22/19 10:30 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Hexavalent Chromium by IC</b>						
Method: CARB 425	Batch ID: W9F0369	Instr: LC13	Prepared: 06/06/19 11:40	Analyst: jna		
Chromium 6+	0.022	0.020	ug/filter	1	06/06/19 14:01	O-12

Sample: 10562 - M425 - C1 - In(I) - R1  
9E30014-03 (Filter) Sampled: 05/22/19 11:50 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Hexavalent Chromium by IC</b>						
Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna		
Chromium 6+	6.5	0.047	ug/filter	5	06/04/19 19:45	

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	11	1.1	ug/filter	5	06/12/19 14:55	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

Almega REPORT  
ENVIRONMENTAL

Project Number: In (I)/In (O)/Out

Reported:  
06/24/2019 14:29

Project Manager: Almega Environmental & Technical Services

## Sample Results

(Continued)

Sample: 10562 - M425 - C2 - In(I) - R1  
9E30014-04 (Filter) Sampled: 05/22/19 11:50 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna
Chromium 6+	52	0.10	ug/filter	5 06/04/19 19:57

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN
Chromium, Total	270	1.0	ug/filter	5 06/12/19 14:56

Sample: 10562 - M425 - C1 - In(O) - R1  
9E30014-05 (Filter) Sampled: 05/22/19 11:50 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna
Chromium 6+	1.2	0.053	ug/filter	5 06/04/19 20:08

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN
Chromium, Total	2.7	1.0	ug/filter	5 06/12/19 14:58

Sample: 10562 - M425 - C2 - In(O) - R1  
9E30014-06 (Filter) Sampled: 05/22/19 11:50 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna
Chromium 6+	3.1	0.10	ug/filter	5 06/04/19 20:20

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN
Chromium, Total	11	1.0	ug/filter	5 06/12/19 14:59

Sample: 10562 - M425 - C1 - Out - R1  
9E30014-07 (Filter) Sampled: 05/22/19 11:50 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN	
Chromium, Total	ND	1.0	ug/filter	5 06/12/19 15:01	M-04


Sample: 10562 - M425 - C1 - Out - R1  
9E30014-07RE1 (Filter) Sampled: 05/22/19 11:50 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0369	Instr: LC13	Prepared: 06/06/19 11:40	Analyst: jna	
Chromium 6+	ND	0.011	ug/filter	1 06/06/19 14:13	O-12





WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL

Project Number: In (I)/In (O)/Out

Reported:  
06/24/2019 14:29

Project Manager: Almega Environmental & Technical Services

## Sample Results

(Continued)

Sample: 10562 - M425 - C2 - Out - R1  
9E30014-08 (Filter) Sampled: 05/22/19 11:50 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	ND	1.0	ug/filter	5	06/12/19 15:03	M-04

Sample: 10562 - M425 - C2 - Out - R1  
9E30014-08RE1 (Filter) Sampled: 05/22/19 11:50 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0369	Instr: LC13	Prepared: 06/06/19 11:40	Analyst: jna		
Chromium 6+	0.035	0.020	ug/filter	1	06/06/19 14:25	O-12

Sample: 10562 - M425 - C1 - In(I) - R2  
9E30014-09 (Filter) Sampled: 05/22/19 14:38 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna		
Chromium 6+	1.7	0.052	ug/filter	5	06/04/19 20:56	

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	3.9	1.0	ug/filter	5	06/12/19 15:04	

Sample: 10562 - M425 - C2 - In(I) - R2  
9E30014-10 (Filter) Sampled: 05/22/19 14:38 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna		
Chromium 6+	2.1	0.10	ug/filter	5	06/04/19 21:08	

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	51	1.0	ug/filter	5	06/12/19 15:06	

Sample: 10562 - M425 - C1 - In(O) - R2  
9E30014-11 (Filter) Sampled: 05/22/19 14:38 by Client


Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna		
Chromium 6+	0.21	0.061	ug/filter	5	06/04/19 21:44	

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	1.5	1.0	ug/filter	5	06/12/19 15:12	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

Almega REPORT  
ENVIRONMENTAL

Project Number: In (I)/In (O)/Out

Reported:  
06/24/2019 14:29

Project Manager: Almega Environmental & Technical Services

## Sample Results

(Continued)

Sample: 10562 - M425 - C2 - In(O) - R2  
9E30014-12 (Filter) Sampled: 05/22/19 14:38 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Hexavalent Chromium by IC</b>						
Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna		
Chromium 6+	0.31	0.11	ug/filter	5	06/04/19 21:56	

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	3.6	1.0	ug/filter	5	06/12/19 15:14	

Sample: 10562 - M425 - C1 - Out - R2  
9E30014-13 (Filter) Sampled: 05/22/19 14:38 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	ND	1.0	ug/filter	5	06/12/19 15:16	M-04

Sample: 10562 - M425 - C1 - Out - R2  
9E30014-13RE1 (Filter) Sampled: 05/22/19 14:38 by Client


Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Hexavalent Chromium by IC</b>						
Method: CARB 425	Batch ID: W9F0369	Instr: LC13	Prepared: 06/06/19 11:40	Analyst: jna		
Chromium 6+	ND	0.010	ug/filter	1	06/06/19 14:37	O-12

Sample: 10562 - M425 - C2 - Out - R2  
9E30014-14 (Filter) Sampled: 05/22/19 14:38 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Metals (Non-Aqueous) by EPA 6000/7000 Series Methods</b>						
Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN		
Chromium, Total	ND	1.0	ug/filter	5	06/12/19 15:17	M-04

Sample: 10562 - M425 - C2 - Out - R2  
9E30014-14RE1 (Filter) Sampled: 05/22/19 14:38 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Hexavalent Chromium by IC</b>						
Method: CARB 425	Batch ID: W9F0369	Instr: LC13	Prepared: 06/06/19 11:40	Analyst: jna		
Chromium 6+	0.032	0.021	ug/filter	1	06/06/19 14:48	O-12



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL

Project Number: In (I)/In (O)/Out

Reported:  
06/24/2019 14:29

Project Manager: Almega Environmental & Technical Services

## Sample Results

(Continued)

Sample: 10562 - M425 - C1 - In(I) - R3  
9E30014-15 (Filter) Sampled: 05/23/19 8:25 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna
Chromium 6+	2.5	0.060	ug/filter	5 06/04/19 22:33

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN
Chromium, Total	6.1	1.0	ug/filter	5 06/12/19 15:19

Sample: 10562 - M425 - C2 - In(I) - R3  
9E30014-16 (Filter) Sampled: 05/23/19 8:25 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna
Chromium 6+	21	0.11	ug/filter	5 06/04/19 22:45

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN
Chromium, Total	340	1.0	ug/filter	5 06/12/19 15:20

Sample: 10562 - M425 - C1 - In(O) - R3  
9E30014-17 (Filter) Sampled: 05/23/19 8:25 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna
Chromium 6+	0.94	0.047	ug/filter	5 06/04/19 22:57

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN
Chromium, Total	2.7	1.1	ug/filter	5 06/12/19 15:22

Sample: 10562 - M425 - C2 - In(O) - R3  
9E30014-18 (Filter) Sampled: 05/23/19 8:25 by Client


Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
---------	--------	-----	-------	-----	----------	-----------

### Hexavalent Chromium by IC

Method: CARB 425	Batch ID: W9F0120	Instr: LC13	Prepared: 06/04/19 11:45	Analyst: jna
Chromium 6+	2.1	0.11	ug/filter	5 06/04/19 23:10

### Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020	Batch ID: W9F0440	Instr: ICPMS03	Prepared: 06/10/19 09:31	Analyst: ALN
Chromium, Total	19	1.0	ug/filter	5 06/12/19 15:24



WECK LABORATORIES, INC.

Almega Environmental & Technical Services
10602 Walker St
Cypress, CA 90630

Certificate of Analysis

Almega REPORT
ENVIRONMENTAL

Project Number: In (I)/In (O)/Out

Reported:
06/24/2019 14:29

Project Manager: Almega Environmental & Technical Services

Sample Results

(Continued)

Sample: 10562 - M425 - C1 - Out - R3
9E30014-19 (Filter)
Sampled: 05/23/19 8:25 by Client

Table with 7 columns: Analyte, Result, MRL, Units, Dil, Analyzed, Qualifier

Hexavalent Chromium by IC

Method: CARB 425 Batch ID: W9F0120 Instr: LC13 Prepared: 06/04/19 11:45 Analyst: jna
Chromium 6+ ND 0.050 ug/filter 5 06/04/19 23:22

Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020 Batch ID: W9F0440 Instr: ICPMS03 Prepared: 06/10/19 09:31 Analyst: ALN
Chromium, Total ND 1.0 ug/filter 5 06/12/19 15:25 M-04

Sample: 10562 - M425 - C2 - Out - R3
9E30014-20 (Filter)
Sampled: 05/23/19 8:25 by Client

Table with 7 columns: Analyte, Result, MRL, Units, Dil, Analyzed, Qualifier

Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020 Batch ID: W9F0440 Instr: ICPMS03 Prepared: 06/10/19 09:31 Analyst: ALN
Chromium, Total ND 1.0 ug/filter 5 06/12/19 15:27 M-04

Sample: 10562 - M425 - C2 - Out - R3
9E30014-20RE1 (Filter)
Sampled: 05/23/19 8:25 by Client

Table with 7 columns: Analyte, Result, MRL, Units, Dil, Analyzed, Qualifier

Hexavalent Chromium by IC

Method: CARB 425 Batch ID: W9F0369 Instr: LC13 Prepared: 06/06/19 11:40 Analyst: jna
Chromium 6+ ND 0.022 ug/filter 1 06/06/19 15:00

Sample: AQMD Facility A - M425 - RB
9E30014-21 (Filter)
Sampled: 05/23/19 11:30 by Client

Table with 7 columns: Analyte, Result, MRL, Units, Dil, Analyzed, Qualifier

Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020 Batch ID: W9F0444 Instr: ICPMS03 Prepared: 06/10/19 09:39 Analyst: ALN
Chromium, Total ND 1.0 ug/filter 5 06/12/19 15:55 M-04

Sample: AQMD Facility A - M425 - RB
9E30014-21RE1 (Filter)
Sampled: 05/23/19 11:30 by Client

Table with 7 columns: Analyte, Result, MRL, Units, Dil, Analyzed, Qualifier

Hexavalent Chromium by IC


Method: CARB 425 Batch ID: W9F0369 Instr: LC13 Prepared: 06/06/19 11:40 Analyst: jna
Chromium 6+ ND 0.010 ug/filter 1 06/06/19 15:12

Sample: AQMD Facility A - M425 - RB - Filter
9E30014-22 (Filter)
Sampled: 05/23/19 11:30 by Client

Table with 7 columns: Analyte, Result, MRL, Units, Dil, Analyzed, Qualifier

Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Method: EPA 6020 Batch ID: W9F0444 Instr: ICPMS03 Prepared: 06/10/19 09:39 Analyst: ALN
Chromium, Total ND 1.0 ug/filter 5 06/12/19 15:56 M-04



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL

**Project Number:** In (I)/In (O)/Out

**Reported:**  
06/24/2019 14:29

**Project Manager:** Almega Environmental & Technical Services


## Sample Results

(Continued)

Sample: AQMD Facility A - M425 - RB - Filter  
9E30014-22RE1 (Filter)

Sampled: 05/23/19 11:30 by Client

Analyte	Result	MRL	Units	Dil	Analyzed	Qualifier
<b>Hexavalent Chromium by IC</b>						
<b>Method:</b> CARB 425	<b>Batch ID:</b> W9F0369	<b>Instr:</b> LC13	<b>Prepared:</b> 06/06/19 11:40	<b>Analyst:</b> jna		
Chromium 6+	ND	0.020	ug/filter	1	06/06/19 15:24	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
 10602 Walker St  
 Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
 ENVIRONMENTAL

Project Number: In (I)/In (O)/Out

Reported:


06/24/2019 14:29

Project Manager: Almega Environmental & Technical Services

## Quality Control Results

Hexavalent Chromium by IC

Analyte	Result	MRL	Units	Spike Level	Source Result	%REC	Limits	RPD	RPD Limit	Qualifier
<b>Batch: W9F0120 - CARB 425</b>										
<b>Blank (W9F0120-BLK1)</b>										
Chromium 6+	ND	0.00010	ug/filter							
				<b>Prepared &amp; Analyzed: 06/04/19</b>						
<b>LCS (W9F0120-BS1)</b>										
Chromium 6+	0.00483	0.00010	ug/filter	0.00500		97	90-110			
				<b>Prepared &amp; Analyzed: 06/04/19</b>						
<b>Matrix Spike (W9F0120-MS1)</b>										
Chromium 6+	3.09	0.050	ug/filter	25.0	ND	12	85-117			MS-05
				<b>Prepared: 06/04/19 Analyzed: 06/05/19</b>						
<b>Matrix Spike (W9F0120-MS2)</b>										
Chromium 6+	8.90	0.10	ug/filter	50.0	ND	18	85-117			MS-05
				<b>Prepared &amp; Analyzed: 06/04/19</b>						
<b>Matrix Spike Dup (W9F0120-MSD1)</b>										
Chromium 6+	3.33	0.050	ug/filter	25.0	ND	13	85-117	8	20	MS-05
				<b>Prepared: 06/04/19 Analyzed: 06/05/19</b>						
<b>Matrix Spike Dup (W9F0120-MSD2)</b>										
Chromium 6+	7.37	0.10	ug/filter	50.0	ND	15	85-117	19	20	MS-05
				<b>Prepared &amp; Analyzed: 06/04/19</b>						
<b>Batch: W9F0369 - CARB 425</b>										
<b>Blank (W9F0369-BLK1)</b>										
Chromium 6+	ND	0.00010	ug/filter							
				<b>Prepared &amp; Analyzed: 06/06/19</b>						
<b>LCS (W9F0369-BS1)</b>										
Chromium 6+	0.00502	0.00010	ug/filter	0.00500		100	90-110			
				<b>Prepared &amp; Analyzed: 06/06/19</b>						
<b>Matrix Spike (W9F0369-MS1)</b>										
Chromium 6+	0.962	0.010	ug/filter	5.00	ND	19	85-117			MS-05
				<b>Prepared &amp; Analyzed: 06/06/19</b>						
<b>Matrix Spike Dup (W9F0369-MSD1)</b>										
Chromium 6+	1.01	0.010	ug/filter	5.00	ND	20	85-117	5	20	MS-05
				<b>Prepared &amp; Analyzed: 06/06/19</b>						



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL

Project Number: In (I)/In (O)/Out

Reported:  
06/24/2019 14:29

Project Manager: Almega Environmental & Technical Services

## Quality Control Results

(Continued)

Metals (Non-Aqueous) by EPA 6000/7000 Series Methods

Analyte	Result	MRL	Units	Spike Level	Source Result	%REC	Limits	RPD	RPD Limit	Qualifier
<b>Batch: W9F0440 - EPA 6020</b>										
<b>Blank (W9F0440-BLK1)</b>										
Chromium, Total	ND	0.20	ug/filter							
Prepared: 06/10/19 Analyzed: 06/12/19										
<b>LCS (W9F0440-BS1)</b>										
Chromium, Total	5.24	0.20	ug/filter	5.00		105	80-120			
Prepared: 06/10/19 Analyzed: 06/12/19										
<b>LCS Dup (W9F0440-BSD1)</b>										
Chromium, Total	5.36	0.20	ug/filter	5.00		107	80-120	2	20	
<b>Batch: W9F0444 - EPA 6020</b>										
<b>Blank (W9F0444-BLK1)</b>										
Chromium, Total	ND	0.20	ug/filter							
Prepared: 06/10/19 Analyzed: 06/12/19										
<b>LCS (W9F0444-BS1)</b>										
Chromium, Total	5.15	0.20	ug/filter	5.00		103	80-120			
Prepared: 06/10/19 Analyzed: 06/12/19										
<b>LCS Dup (W9F0444-BSD1)</b>										
Chromium, Total	5.08	0.20	ug/filter	5.00		102	80-120	1	20	



WECK LABORATORIES, INC.

Almega Environmental & Technical Services  
10602 Walker St  
Cypress, CA 90630

# Certificate of Analysis

*Almega* REPORT  
ENVIRONMENTAL

**Project Number:** In (I)/In (O)/Out

**Reported:**

06/24/2019 14:29

**Project Manager:** Almega Environmental & Technical Services



## Notes and Definitions

Item	Definition
M-04	Due to the nature of matrix interferences, sample extract was diluted prior to analysis. The MDL and MRL were raised due to the dilution.
MS-05	The spike recovery and/or RPD were outside acceptance limits for the MS and/or MSD due to possible matrix interference. The LCS and/or LCSD were within acceptance limits showing that the laboratory is in control and the data is acceptable.
O-12	The sample was originally analyzed within holding time. However, it was reanalyzed without dilution that exceeded the recommended holding time.
% Rec	Percent Recovery
Dil	Dilution
dry	Sample results reported on a dry weight basis
MDA	Minimum Detectable Activity
MDL	Method Detection Limit
MRL	The minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence. The MRL is also known as Limit of Quantitation (LOQ) and Detection Limit for Reporting (DLR)
ND	NOT DETECTED at or above the Method Reporting Limit (MRL). If Method Detection Limit (MDL) is reported, then ND means not detected at or above the MDL.
NR	Not Reportable
RPD	Relative Percent Difference
Source	Sample that was matrix spiked or duplicated.
TIC	Tentatively Identified Compound (TIC) using mass spectrometry. The reported concentration is relative concentration based on the nearest internal standard. If the library search produces no matches at, or above 85%, the compound is reported as unknown.

Any remaining sample(s) will be disposed of one month from the final report date unless other arrangements are made in advance.

An Absence of Total Coliform meets the drinking water standards as established by the California State Water Resources Control Board (SWRCB)

All results are expressed on wet weight basis unless otherwise specified.

All samples collected by Weck Laboratories have been sampled in accordance to laboratory SOP Number MIS002.



1 of 3

27

9E300M



### CHAIN OF CUSTODY RECORDS

**REPORT TO:**  
**ALMEGA Environmental & Technical Services**  
 13602 Walker St.  
 Cypress, CA 90630  
 (714) 889-4900 Fax (714) 889-7030  
 info@almegaenv.com  
 Contact: Neal Conroy

Page 1 of 1  
 PO # 10567

Turnaround Time  
 Standard: Other:  
 X  
 Rush:  
 Depends on # of Samples  
 5 - 10 days  
 3 - 7 days

In(1)	In(2)	Unit 3: Out	Sample Identification	Description	Type of Sample			No. of Containers	ANALYSIS REQUESTED			REMARKS
					L	GAS	SOLID		H	B	C	
5/22/2019	10:30	10562 - M425 - C1 - In(O) - FB	Probe Rise (Multiurb)	X			1		X			* Analyze each sample for Hex Chrom and Tol Chrom
5/22/2019	11:50-14:12	10562 - M425 - C2 - In(O) - FB	Flareings 1, 2	X			1		X			** Measure and report each sample volume
5/22/2019	11:50-14:12	10562 - M425 - C1 - In(O) - R1	Probe Rise (Multiurb)	X			1		X			*** Archive all primary sample aliquots.
5/22/2019	11:50-14:12	10562 - M425 - C2 - In(O) - R1	Flareings 1, 2	X			1		X			
5/22/2019	11:50-14:15	10562 - M425 - C1 - Out - R1	Probe Rise (Multiurb)	X			1		X			
5/22/2019	11:50-14:15	10562 - M425 - C2 - Out - R1	Flareings 1, 2	X			1		X			

476 T-07D



Relinquished by: *Neal Conroy* Date: 5/22/19 Time: 18:15  
 Relinquished by: *Johnston* Date: 5/23/19 Time: 8:45  
 Relinquished by: *Johnston* Date: 5/23/19 Time: 12:00  
 Relinquished by: *Johnston* Date: 5/23/19 Time: 10:20

2013

9E3004



CHAIN OF CUSTODY RECORDS

REPORT TO: **ALMEGA Environmental & Technical Services**  
 10602 Walker St.  
 Cypress, CA 90630  
 (714) 889-4500 Fax (714) 889-7000  
 info@almegaenv.com  
 Contact: Neal Conroy

INVOICE: \_\_\_\_\_  
 CLIENT: **ACMD Facility A**  
 JOB #: 10562  
 ATTN: \_\_\_\_\_

Page 1 of 1  
 PO # **1 D 5 6 7**

Unit 1: In (I)	Unit 2: In (I)	Unit 3: Out	Sample Date/Time	Sample Description	Sample Identification	Description	Type of Sample		No. of Containers	ANALYSIS REQUESTED				Turnaround Time
							Liquid	Solid		GC	MS	TOC	Other	
5/22/2019 14:38-16:50	10562 - M425 - C1 - In (I) - R2			Probe Rise (Methane)			X		1					X Rush: Depends on # of Samples 5 - 10 days
5/22/2019 14:38-16:50	10562 - M425 - C2 - In (I) - R2			Probe Rise (Methane)			X		1					3 - 7 days
5/22/2019 14:38-16:50	10562 - M425 - C1 - In (I) - R2			Probe Rise (Methane)			X		1					* Analyze each sample for His Chem and Tot Chem
5/22/2019 14:38-16:53	10562 - M425 - C2 - In (I) - R2			Probe Rise (Methane)			X		1					** Measure and report each sample volume
5/22/2019 14:38-16:53	10562 - M425 - C1 - Out - R2			Probe Rise (Methane)			X		1					*** Arrive all primary analysis aliquots
5/22/2019 14:38-16:53	10562 - M425 - C2 - Out - R2			Probe Rise (Methane)			X		1					47" T-000





**From:** Charles Figueroa <Charles@almegaenv.com>  
**Sent:** Tuesday, July 02, 2019 12:02 PM  
**To:** Tulasi@almegaenv.com  
**Subject:** FW: Samples submitted May 29  
**Attachments:** Chrome 10562.pdf; Metals 10562.pdf

**From:** Charles Figueroa <Charles@almegaenv.com>  
**Sent:** Wednesday, May 29, 2019 9:53 AM  
**To:** 'Brandon Gee' <Brandon.Gee@wecklabs.com>  
**Cc:** 'Joe Chau' <Joe.Chau@wecklabs.com>; 'Brian Speaks' <gspeaks@aqmd.gov>; 'doug@almegaenv.com' <doug@almegaenv.com>  
**Subject:** Samples submitted May 29

Brandon,

We are delivering two sets of samples this morning.

This is a test we are doing in conjunction with the AQMD.

One is set of hex chrome samples for CARB Method 425

Most of these instructions should be apparent on the CoC (copy attached).

- Analyze the two submitted fractions separately
- Record the pH of the solutions before analysis (as received)
- Need the lowest reporting limit (avoid dilutions if possible)
- The submitted solution is 0.1 N NaHCO<sub>3</sub> (incorrectly stated on the RB description) ✓
- The AQMD would like the opportunity to conduct their own analysis on the samples (if warranted). Please "hold" the samples after analysis (keep cold) to allow a possible re-analysis.
- Hold time is 14 days from 5/22. Please expedite.

The other set is for metals by CARB Method 436

Most of these instructions should be apparent on the CoC (copy attached).

- Combine all three fractions and report a single value
- The Hg option is not applicable to these samples
- The only metals needed on the analysis are: Cr, Ni, As and Cd
- need the lowest reporting limits (avoid dilutions if possible)
- The AQMD would like the opportunity to conduct their own analysis on the samples (if warranted). Please "hold" the samples after analysis to allow a possible re-analysis.

Thanks

*Charles M. Figueroa*

**Almega**

P (714) 889-4000

**APPENDIX D4**

**O<sub>2</sub>/CO<sub>2</sub> RESULTS – FIELD & LABORATORY DATA**

**LABORATORY REPORT**  
Carbon Dioxide & Oxygen by TCD  
by Modified SCAQMD Method 25.3 (TCA/FID)

Client: AQMD  
Project No.: c10562  
Unit Tested: Facility A  
Sampling Date: 22-May-19  
Analyzed Date: 28-May-19  
Lab No.: A 053

Client Sample ID	Lab ID	Almega Sample ID	CO <sub>2</sub> % v/v by TCD	O <sub>2</sub> % v/v by TCD
		Tank		
<b>Facility A</b>				
Tnk14 - Inlet (I) - R2	A 053 - 04	14	ND	19.9
Tnk37 - Inlet (O) - R2	A 053 - 05	37	ND	20.2
Tnk42 - Outlet - R2	A 053 - 06	42	ND	21.7
Detection Limit			0.3	0.3

Outlet -R2 not used,  
lab reporting error

\* NOTE - the BIAS FACTOR (of 1.086) is NOT applied in these results.  
ND=Not Detected

TGMNEO concentration values are reported in ppm (v/v) as Methane (carbon#-1).

The sample cylinder is analyzed for NMNEO, CO, CH<sub>4</sub>, CO<sub>2</sub> and C<sub>2</sub>H<sub>6</sub>. It is then directed to a separation column where all heavy organics (C<sub>3</sub>+) separate from the light organics (CO, CO<sub>2</sub>, CH<sub>4</sub> and C<sub>2</sub>H<sub>6</sub>). The light organics are then passed through a reduction catalyst to convert CO and CO<sub>2</sub> to CH<sub>4</sub>, and are then directed to a FID for detection and quantification. The heavy organics are backflushed off the holding column, passed through an oxidation catalyst, which convert all organics to CO<sub>2</sub>, then through a reduction catalyst to convert CO<sub>2</sub> to CH<sub>4</sub> and then to a FID for detection and quantification.

Reviewed by:     DW

## CALCULATIONS



**Client:** AQMD  
**Project No.:** c10562  
**Unit Tested:** Facility A  
**Sampling Date:** 22-May-19  
**Date tested:** 28-May-19

Lab No.: A 053

Parameter	Symbol	Units	Run #1 Tnk14 - Inlet (I) - R2 A 053 - 04	Run #2 Tnk37 - Inlet (O) - R2 A 053 - 05
Sample ID				
Lab ID				
<u>Sample Tank</u>				
Tank No			14	37
Sample Tank Volume	$V_T$	L	12.035	12.085
Barometric Pressure	$P_b$	mm Hg	763	763
Pre-test Pressure	$P_{TI}$	mm Hg (abs)	2.00	2.00
Pre-test Temperature	$t_{TI}$	°C	21	21
Abs. Pre-test Temperature	$T_{TI}$	°K	294	294
Post-test Pressure	$P_{TS}$	mm Hg (abs)	536	558
Post-test Temperature	$t_{TS}$	°C	21	21
Abs. Post-test Temperature	$c$	°K	294	294
Final Pressure	$P_{TF}$	mm Hg (abs)	926	918
Abs. Final Temperature	$T_{TF}$	°K	293	293
Dilution Factor	$DF_T$		1.74	1.66
Sample Volume	$V_s$	L	8.304	8.682

### Calculations

$$V_s = k_1 \cdot V_T \cdot (P_{TS}/T_{TS} - P_{TI}/T_{TI})$$

$$k_1 = (273 + 15.56) / 760 = 0.3799$$

$$C_{SAT} = DF \cdot C_{SA}$$

$$C_{COT} = DF \cdot C_{CO}$$

$$DF = (P_{TF}/T_{TF}) / (P_{TS}/T_{TS} - P_{TI}/T_{TI})$$

## CALCULATIONS

Client:	AQMD	Lab No.:
Project No.:	c10562	A 053
Unit Tested:	Facility A	
Sampling Date:	22-May-19	
Date tested:	28-May-19	

Parameter	Symbol	Units	Run #3
Sample ID			Tnk42 - Outlet - R2
Lab ID			A 053 - 06
<u>Sample Tank</u>			
Tank No			42
Sample Tank Volume	$V_T$	L	12.010
Barometric Pressure	$P_b$	mm Hg	763
Pre-test Pressure	$P_{TI}$	mm Hg (abs)	2.00
Pre-test Temperature	$t_{TI}$	°C	21
Abs. Pre-test Temperature	$T_{TI}$	°K	294
Post-test Pressure	$P_{TS}$	mm Hg (abs)	54
Post-test Temperature	$t_{TS}$	°C	21
Abs. Post-test Temperature	$T_{TS}$	°K	294
Final Pressure	$P_{TF}$	mm Hg (abs)	928
Abs. Final Temperature	$T_{TF}$	°K	293
Dilution Factor	$DF_T$		17.91

Sample Volume	$V_s$	L	0.807
---------------	-------	---	-------

### Calculations

$$V_s = k_1 * V_T * (P_{TS}/T_{TS} - P_{TI}/T_{TI})$$

$$k_1 = (273 + 15.56) / 760 = 0.3799$$

$$C_{SAT} = DF * C_{SA}$$

$$C_{CO2} = DF * C_{CO}$$

$$DF = (P_{TF}/T_{TF}) / (P_{TS}/T_{TS} - P_{TI}/T_{TI})$$



QA/QC SUMMARY  
(Repeat Analysis)



Client Project No.: c10562  
 Sampling Date: 22-May-19  
 Run #1

Lab No.: A 053  
 Analyzed Date: 28-May-19

Analyte	Sample ID	Area Count #1	Area Count #2	Area % diff (±20%)	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
Tank Analysis								
CO2*	A 053 - 04	ND	ND	ND	ND	ND	ND	ND
O2*	A 053 - 04	2218932	2220944	-0.09	11.4	11.4	11.4	-0.09

Run #2

Analyte	Sample ID	Area Count #1	Area Count #2	Area Count #3	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
Tank Analysis								
CO2*	A 053 - 05	ND	ND	ND	ND	ND	ND	ND
O2 *	A 053 - 05	2379775	2369627	0.43	12.2	12.2	12.2	0.43

\* - by GC/TCD

$$\text{Conc}_{\text{CO}} \text{ in tank} = \text{MeanConc}_{\text{CO}} * \text{DF}$$

$$\text{Conc}_{\text{CO}_2} \text{ in tank} = \text{MeanConc}_{\text{CO}_2} * \text{DF}$$

$$\text{Conc}_{\text{O}_2} \text{ in tank} = \text{MeanConc}_{\text{O}_2} * \text{DF}$$

QA/QC SUMMARY  
(Repeat Analysis)



Client Project No.: c10562  
 Sampling Date: 22-May-19  
 Run #3

Lab No.: A 053  
 Analyzed Date: 28-May-19

Analyte	Sample ID	Area Count #1	Area Count #2	Area Count #3	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
<b>Tank Analysis</b>								
CO2*	A 053 - 06	ND	ND	ND	ND	ND	ND	ND
O2*	A 053 - 06	235691	235545	0.06	1.2	1.2	1.2	0.06

\* - by GC/TCD

$$\text{Conc}_{\text{CO}} \text{ in tank} = \text{MeanConc}_{\text{CO}} * \text{DF}$$

$$\text{Conc}_{\text{CO}_2} \text{ in tank} = \text{MeanConc}_{\text{CO}_2} * \text{DF}$$

$$\text{Conc}_{\text{O}_2} \text{ in tank} = \text{MeanConc}_{\text{O}_2} * \text{DF}$$

## SAMPLE INVENTORY REPORT

Method 25.3 Sampling Train

Project No.: c10562  
Client: AQMD

Lab No.: A 053  
Sampling Date: 22-May-19

Laboratory ID	Client ID	Component ID
<b>Run #1</b>		
A 053 - 04	Tnk14 - Inlet (I) - R2	Tank # 14
<b>Run #2</b>		
A 053 - 05	Tnk37 - Inlet (O) - R2	Tank # 37
<b>Run #3</b>		
A 053 - 06	Tnk42 - Outlet - R2	Tank # 42



Standard Receipt  
Sample LOG in Checklist

Project No: C10562  
~~616870~~

Method: 210.1

Lab ID: AOS3

Sampling Date: 5/21, 5/22, 5/23

Location: AQMD - A Int: \_\_\_\_\_

Date & Time Rc'd: 5/22/9 9:02  
5/23/9 8:42 5/24/9 8:15

Location: LAB Int: DW

Arrived By: (circle) FedEx UPS Drop Off (Int) DS Other \_\_\_\_\_

Condition of Package(s): (comment): OK // Package Type: Box Cooler Other: /

Number of Sample Container(s): 3, 3, 3, 9 Correct Containers (per Method): (Y) N //

Preservation: (circle) ICE DryICE ICEPacks (None) //

Sample Conditions:

Sample Temp (C): 21 //

Ambient Temp (C): 21 //

Sample Temp (C): \_\_\_\_\_

Filter Condition: OK

PH: \_\_\_\_\_

Components Sealed: (Y) N //

Sample Recovery Completed On: (date & time) \_\_\_\_\_

Recovered In: (circle) (Field) Lab Other //

Silica Gel Condition: \_\_\_\_\_

Tedlar Bags -

Condensation: Y N

Comments:

Container(s) Requested: Glass \_\_\_\_\_ Plastic \_\_\_\_\_

Additional Comments:

**CHROMATOGRAM  
TEST SAMPLES**

13.79

15.662

A053  
-04


CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 191

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.942	8158781			35.319	
2	13.79	2218932			9.6152	
3	15.662	12787724	V		55.8658	
TOTAL		23877356			100	



CG3

223-02037-01

170615

⊕ Shimadzu

A053  
-04  
dup


CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 192

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.942	8173890			35.2532	
2	13.806	2228944			9.5787	
3	15.684	12791430	V		55.1681	
TOTAL		23186262			100	




CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 195

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.928	7995585			35.4683	
2	13.739	235691			1.0455	
3	15.496	14311633	V		63.4862	
TOTAL		22542988			100	



CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC


CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 196

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.918	7976595			35.4421	
2	13.697	235545			1.0466	
3	15.449	14293824	V		63.5113	
TOTAL		22505962			100	



QAQC




CHROMATOGRAM 1 MEMORIZED

*Cdr*

C-R5A CHROMATOPAC  
CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 178

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.941	8338413			35.3681	
2	6.637	10629			0.0451	
3	13.917	3875095			16.4366	
4	15.918	11351942	V		48.1502	
TOTAL		23576078			100	




CHROMATOGRAM 1 MEMORIZED

*Cdr*

C-R5A CHROMATOPAC  
CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 179

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.942	8378934			34.9693	
2	13.953	3971324			16.5742	
3	15.978	11610556	V		48.4564	
TOTAL		23960814			100	



CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 197

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.878	6832073			33.7096	
2	5.98	985018			4.8601	
3	13.758	1662447			8.2025	
4	15.767	10787908	Y		53.2278	
TOTAL		20267444			100	

070  
223-02037-01  
17

## TANK PREPARATION

**TANK PREPARATIONS**

Client: AQMD Lab No.: A 053  
 Project No.: c10562  
 Unit Tested: Facility A  
 Sampling Date: 22-May-19  
 Date pressurized: 23-May-19

Tank ID	Sample ID	Pre-test pressure mm Hg		Post-test pressure mm Hg	Final Pressure	Comments
		1	2			
14	A 053 - 04	-758	-758	-224	166	Run #1
37	A 053 - 05	-758	-758	-202	158	Run #2
42	A 053 - 06	-758	-758	-706	168	Run #3

\* - Post -test Pressure is less then 200 mm Hg.





**APPENDIX E**

**SCAQMD METHOD 5.1 – PARTICULATE MATTER (PM)**



**APPENDIX E1**

**PARTICULATE MATTER (PM) – RESULTS AND CALCULATIONS**

Location: Baghouse Outlet

## TEST RESULTS

### SCAQMD Method 5.1 (Particulate Matter)

**Facility:** AQMD Facility A

**City:** ██████████ CA

**Source:** Baghouse

**Location:** Outlet

Run Number	1	
Run Date	05/23/19	
Run Start Time	11:20	
Run Stop Time	13:30	
<b>Test Train Parameters</b>		<b>AVERAGE</b>
Volume of Dry Gas Sample, SCF*	89.20	89.20
<b>Flue Gas Parameters</b>		
CO2, Percent By Volume, Dry**	0.04	0.04
O2, Percent By Volume, Dry**	20.90	20.90
Temperature, Degrees F	86.7	86.7
Moisture, %	1.86	1.86
Air Flow Rate, ACFM	-	-
Air Flow Rate, Dry SCFM*	47,272	47,272
<b>Total Particulate</b>		
Catch, mg	3.32	3.32
Concentration, Gr/DSCF	0.000574	0.000574
Emission Rate, lb/hr	0.233	0.233

\* 60 Degrees F and 29.92 Inches of Mercury

\*\* Ambient O2/CO2 was used in gas density calculations.

## ISOKINETIC SAMPLING TRAIN RESULTS - METHOD: METHOD 5.1

Client Name	Facility A	Operator	CH/NC
Plant Name	Metal Melting facility	Project #	10562
Sampling Location	Outlet	Standard Temperature, °F	60

USE IN AVERAGE OF RUN SET? 1 or 0 =>	1			SET AVERAGE
Run Number	1			
Run Date	05/23/19			
Run Start Time	hh:mm	11:20		
Run Stop Time	hh:mm	13:30		
Meter Calibration Factor	Y	1.0376		
Pitot Tube Coefficient	C <sub>p</sub>	0.84		
Actual Nozzle Diameter	in	0.513		
Sample Volume	ft <sup>3</sup>	88.41		88.41
Total Sampling Time	min	123		123
Average Meter Temperature	°F	74.7		74.7
Average Stack Temperature	°F	86.7		86.7
Barometric Pressure	in Hg	29.80		29.8
Stack/Duct Static Pressure	in H <sub>2</sub> O	0.00		0.00
Absolute Stack/Duct Pressure	in Hg	29.8		29.8
Average Delta H	in H <sub>2</sub> O	1.77		1.77
Absolute Meter Pressure	in Hg	29.9		29.9
Avg Differential Pressure (Delta P)	in H <sub>2</sub> O	0.025		0.025
Total Water Volume Collected	mL	36.5		36.5
Volume of Water vapor @ STP	SCF	1.692		1.692
Volume Metered @ STP	DSCF	89.200		89.200
Calculated Stack Moisture	% H <sub>2</sub> O	1.86		1.9
Saturated Stack Moisture	% H <sub>2</sub> O	4.3		4.3
Reported Stack Moisture Content	% H <sub>2</sub> O	1.86		1.86
Carbon Dioxide Percentage	% CO <sub>2</sub>	0.04		0.04
Oxygen Percentage	% O <sub>2</sub>	20.90		20.90
Carbon Monoxide Percentage	% CO	0.000		0.000
Nitrogen Percentage	% N <sub>2</sub>	79.1		79.1
Dry Mole Fraction	decimal	0.981		0.981
Dry Gas Molecular Weight	lb/lb-mole	28.84		28.84
Wet Stack Gas Molecular Weight	lb/lb-mole	28.64		28.64
Flue Gas Density	lb/ft <sup>3</sup>	0.0743		0.0743
Stack Cross-Sectional Area	in <sup>2</sup>	-		
Stack Cross-Sectional Area	ft <sup>2</sup>	-		
Percent of Isokinetic Rate	% ISO	99.5		99.5

### Air Flow Rate Results

Average Stack Gas Velocity	ft/sec	9.11		9.11
Actual Stack Flow/Minute	ACFM	-		-
Dry Standard Stack Flow/Minute*	DSCFM	47,272		47,272

Note: \*Sum of 2 inlets flows.



	Water 1	Water 2	Empty	SG
Initial	738.5	720.2	628.7	837.5
Final	752.0	723.7	631.2	854.5
H2O gain	13.5	3.50	2.50	17.00
Total H2O	36.5			

Cumul. Percent ISO	Point Percent ISO	Square Root DP	Local Stack Velocity	Cumulative Meter Volume	Point Meter Volume
%	%	(in H <sub>2</sub> O) <sup>1/2</sup>	ft/sec	scf	scf
99.6	99.6	0.158	9.1	5.167	5.167
99.7	99.7	0.158	9.1	10.325	5.158
99.7	99.6	0.158	9.1	15.463	5.138
99.7	99.6	0.158	9.1	20.608	5.145
99.7	99.8	0.158	9.1	25.771	5.163
99.6	99.5	0.158	9.1	30.927	5.156
99.7	99.8	0.158	9.1	36.106	5.179
99.7	99.7	0.158	9.1	41.264	5.158
99.7	99.7	0.158	9.1	46.428	5.164
100.4	109.6	0.158	9.1	50.466	4.038
100.4	99.7	0.158	9.1	54.149	3.684
100.3	99.7	0.158	9.1	57.840	3.692
100.3	99.6	0.158	9.1	61.511	3.673
100.2	99.7	0.158	9.1	65.196	3.687
100.2	99.6	0.158	9.1	68.869	3.677
100.2	99.6	0.158	9.1	72.537	3.671
100.1	99.8	0.158	9.1	76.226	3.694
100.1	99.6	0.158	9.1	79.914	3.691
100.1	99.7	0.158	9.1	83.594	3.684
100.1	99.7	0.158	9.1	87.264	3.673
100.0	99.6	0.158	9.1	90.935	3.676
100.0	99.6	<b>Final Values</b>		90.935	3.676
		0.158	9.1		

## EXAMPLE CALCULATIONS, RUN 1

### ABSOLUTE PRESSURE, INCHES OF MERCURY

$$\begin{aligned} P_s &= P_{bar} + P_g/13.6 \\ &= 29.80 + 0.00/13.6 \\ &= 29.80 \end{aligned}$$

### VOLUME OF WATER VAPOR, STANDARD CUBIC FEET

$$\begin{aligned} V_{wstd} &= 0.002667 * [(T_{std} + 460) / P_{std}] * V_{lc} \\ &= 0.002667 * [(60 + 460) / 29.92 * 36.5 \\ &= 1.692 \end{aligned}$$

### SAMPLED VOLUME OF SOURCE GAS, DRY STANDARD CUBIC FEET

$$\begin{aligned} V_{mstd} &= [(T_{std} + 460)/P_{std}] * Y * V_m * (P_{bar} + \Delta H/13.6) / (460 + t_m) \\ &= [(60 + 460)/ 29.92] * 1.0376 * 88.407 * (29.80 + 1.766/13.6) / (460 + 75) \\ &= 89.200 \end{aligned}$$

### MOISTURE CONTENT, PERCENT BY VOLUME

$$\begin{aligned} \%H_2O &= V_{wstd} / (V_{wstd} + V_{mstd}) \\ &= 1.692 / (1.692 + 89.200) \\ &= 1.86 \end{aligned}$$

### DRY MOLE FRACTION, LB-MOLE/LB-MOLE

$$\begin{aligned} M_{fd} &= 1 - \%H_2O/100 \\ &= 1 - 1.86/100 \\ &= 0.981 \end{aligned}$$

### DRY MOLECULAR WEIGHT, LB/LB-MOLE

$$\begin{aligned} M_d &= 44*(\%CO_2/100) + 32*(\%O_2/100) + 28*\{[100-(\%CO_2+\%O_2)]/100\} \\ &= 44*(0.0/100) + 32*(20.9/100) + 28*\{[100-(0.0+20.9)]/100\} \\ &= 28.84 \end{aligned}$$

### WET MOLECULAR WEIGHT, LB/LB-MOLE

$$\begin{aligned} M_s &= M_d * M_{fd} + 18.0 * \%H_2O/100 \\ &= 28.84 * 0.981 + 18.0 * 1.86/100 \\ &= 28.64 \end{aligned}$$

### FUEL FACTOR

$$\begin{aligned} F_o &= (20.9 - \%O_2) / \%CO_2 \\ &= (20.9 - 20.9) / 0.0 \\ &= 0.000 \end{aligned}$$

### ISOKINETIC SAMPLING RATE, PERCENT

$$\begin{aligned} \%I &= P_{std}/(T_{std} + 460) * (100/60) * V_{mstd} * (t_s + 460) / [P_s * v_s * M_{fd} * \Theta * (\pi * Dia * Dia / 576)] \\ &= 29.92 / (60 + 460) * (100/60) * 89.200 * (87 + 460) / [29.80 * 9.11 * 0.981 * 123.00 * (\pi * 0.513 * 0.513 / 576)] \\ &= 99.5 \end{aligned}$$

### VELOCITY, FEET PER SECOND

$$\begin{aligned} v_s &= 85.49 * C_p * \text{SQRT}[\Delta p * (460 + t_s) / P_s / M_s] \\ &= 85.49 * 0.84 * \text{SQRT}[0.0251 * (460 + 87) / 29.80 / 28.64] \\ &= 9.11 \end{aligned}$$

### TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT

$$\begin{aligned} \text{gr/DSCF} &= (\text{Catch/Conversion}) * 7,000 / 453.592 / V_{mstd} \\ &= (3.32/1000) * 7,000 / 453.592 / 89.200 \\ &= 0.00057 \end{aligned}$$

### TOTAL PARTICULATE EMISSION RATE, POUNDS PER HOUR

$$\begin{aligned} \text{lb/hr} &= 60 * (\text{Catch/Conversion}) * Q_{sd} / 453.592 / V_{mstd} \\ &= 60 * (3.32/1000) * 47272 / 453.592 / 89.200 \\ &= 0.233 \end{aligned}$$

Location: Inlet 1 (inside)



## TEST RESULTS

### SCAQMD Method 5.1 (Particulate Matter)

**Facility:** AQMD Facility A

**City:** ██████████ CA

**Source:** Baghouse

**Location:** Inlet 1 Furnace (Inside)

Run Number	1	
Run Date	05/23/19	
Run Start Time	11:20	
Run Stop Time	13:36	
<b>Test Train Parameters</b>		<b>AVERAGE</b>
Volume of Dry Gas Sample, SCF*	101.79	101.79
<b>Flue Gas Parameters</b>		
CO2, Percent By Volume, Dry**	< 0.30	< 0.30
O2, Percent By Volume, Dry**	20.20	20.20
Temperature, Degrees F	128.0	128.0
Moisture, %	1.55	1.55
Air Flow Rate, Wet ACFM	3,142	3,142
Air Flow Rate, Dry SCFM*	2,629	2,629
<b>Total Particulate</b>		
Catch, mg	60.42	60.42
Concentration, Gr/DSCF	0.009160	0.009160
Emission Rate, lb/hr	0.206	0.206

\* 60 Degrees F and 29.92 Inches of Mercury

\*\* O2/CO2 was sampled in Tedlar bag and analysed via SCAQMD Method 10.1 by GC.

## ISOKINETIC SAMPLING TRAIN RESULTS - METHOD: METHOD 5.1

Client Name	Facility A	Operator	T. Ta/NC
Plant Name	Metal Melting facility	Project #	10562
Sampling Location	Inlet 1 (Inside)	Standard Temperature, °F	60

USE IN AVERAGE OF RUN SET? 1 or 0 =>	1			SET AVERAGE
Run Number	1			
Run Date	05/23/19			
Run Start Time	hh:mm	11:20		
Run Stop Time	hh:mm	13:36		
Meter Calibration Factor	Y	1.0274		
Pitot Tube Coefficient	C <sub>p</sub>	0.84		
Actual Nozzle Diameter	in	0.180		
Sample Volume	ft <sup>3</sup>	104.91		104.91
Total Sampling Time	min	120		120
Average Meter Temperature	°F	91.5		91.5
Average Stack Temperature	°F	128.0		128.0
Barometric Pressure	in Hg	29.80		29.8
Stack/Duct Static Pressure	in H <sub>2</sub> O	-14.20		-14.20
Absolute Stack/Duct Pressure	in Hg	28.8		28.8
Average Delta H	in H <sub>2</sub> O	2.46		2.46
Absolute Meter Pressure	in Hg	30.0		30.0
Avg Differential Pressure (Delta P)	in H <sub>2</sub> O	2.508		2.508
Total Water Volume Collected	mL	34.6		34.6
Volume of Water vapor @ STP	SCF	1.604		1.604
Volume Metered @ STP	DSCF	101.791		101.791
Calculated Stack Moisture	% H <sub>2</sub> O	1.55		1.6
Saturated Stack Moisture	% H <sub>2</sub> O	14.9		14.9
Reported Stack Moisture Content	% H <sub>2</sub> O	1.55		1.55
Carbon Dioxide Percentage	% CO <sub>2</sub>	0.30		0.30
Oxygen Percentage	% O <sub>2</sub>	20.20		20.20
Carbon Monoxide Percentage	% CO	0.000		0.000
Nitrogen Percentage	% N <sub>2</sub>	79.5		79.5
Dry Mole Fraction	decimal	0.984		0.984
Dry Gas Molecular Weight	lb/lb-mole	28.86		28.86
Wet Stack Gas Molecular Weight	lb/lb-mole	28.69		28.69
Flue Gas Density	lb/ft <sup>3</sup>	0.0745		0.0745
Stack Cross-Sectional Area	in <sup>2</sup>	78.5		78.5
Stack Cross-Sectional Area	ft <sup>2</sup>	0.55		0.55
Percent of Isokinetic Rate	% ISO	99.6		99.6

### Air Flow Rate Results

Average Stack Gas Velocity	ft/sec	96.02		96.02
Actual Stack Flow/Minute	ACFM	3,142		3,142
Dry Standard Stack Flow/Minute	DSCFM	2,629		2,629



	Water 1	Water 2	Empty	SG
Initial	743.5	621.4	634.5	871.4
Final	754.7	625.1	636.8	888.8
H2O gain	11.2	3.70	2.30	17.40
Total H2O	34.6			

Cumul. Percent ISO	Point Percent ISO	Square Root DP (in H <sub>2</sub> O) <sup>1/2</sup>	Local Stack Velocity ft/sec	Cumulative Meter Volume scf	Point Meter Volume scf
99.6	99.6	1.581	94.6	4.354	4.354
99.3	99.0	1.612	95.6	8.812	4.458
99.5	99.8	1.517	92.7	12.911	4.099
99.6	99.9	1.549	93.1	17.173	4.262
99.4	98.4	1.581	96.8	21.377	4.205
99.6	100.4	1.581	99.2	25.563	4.186
99.6	99.8	1.817	111.4	30.463	4.898
99.6	100.0	1.844	115.2	35.355	4.890
99.8	101.0	1.732	105.4	40.118	4.760
99.7	99.4	1.549	94.4	44.300	4.184
99.6	98.0	1.449	88.1	48.163	3.867
99.5	99.8	1.225	74.1	51.498	3.346
99.5	99.7	1.844	112.4	56.493	4.997
99.4	98.4	1.897	116.1	61.542	5.050
99.5	100.3	1.871	112.3	66.722	5.179
99.5	99.3	1.897	116.3	71.813	5.091
99.6	100.2	1.844	112.2	76.846	5.031
99.6	99.7	1.871	112.4	81.991	5.142
99.6	99.4	1.483	90.7	85.976	3.991
99.5	98.4	1.549	93.4	90.162	4.189
99.5	101.0	1.414	83.8	94.148	3.990
99.5	99.9	1.265	74.8	97.676	3.537
99.5	102.2	1.049	63.2	100.608	2.947
99.5	100.1	0.990	58.8	103.357	2.763
99.5	100.1	<b>Final Values</b>		103.357	2.763
		1.584	96.1		

## EXAMPLE CALCULATIONS, RUN 1

### ABSOLUTE PRESSURE, INCHES OF MERCURY

$$\begin{aligned} P_s &= P_{bar} + P_g/13.6 \\ &= 29.80 + -14.20/13.6 \\ &= 28.76 \end{aligned}$$

### VOLUME OF WATER VAPOR, STANDARD CUBIC FEET

$$\begin{aligned} V_{wstd} &= 0.002667 * [(T_{std} + 460) / P_{std}] * V_{lc} \\ &= 0.002667 * [(60 + 460) / 29.92 * 34.6 \\ &= 1.604 \end{aligned}$$

### SAMPLED VOLUME OF SOURCE GAS, DRY STANDARD CUBIC FEET

$$\begin{aligned} V_{mstd} &= [(T_{std} + 460)/P_{std}] * Y * V_m * (P_{bar} + \Delta H/13.6) / (460 + t_m) \\ &= [(60 + 460)/ 29.92] * 1.0274 * 104.907 * (29.80 + 2.459/13.6) / (460 + 92) \\ &= 101.791 \end{aligned}$$

### MOISTURE CONTENT, PERCENT BY VOLUME

$$\begin{aligned} \%H_2O &= V_{wstd} / (V_{wstd} + V_{mstd}) \\ &= 1.604 / (1.604 + 101.791) \\ &= 1.55 \end{aligned}$$

### DRY MOLE FRACTION, LB-MOLE/LB-MOLE

$$\begin{aligned} M_{fd} &= 1 - \%H_2O/100 \\ &= 1 - 1.55/100 \\ &= 0.984 \end{aligned}$$

### DRY MOLECULAR WEIGHT, LB/LB-MOLE

$$\begin{aligned} M_d &= 44*(\%CO_2/100) + 32*(\%O_2/100) + 28*\{[100-(\%CO_2+\%O_2)]/100\} \\ &= 44*(0.3/100) + 32*(20.2/100) + 28*\{[100-(0.3+20.2)]/100\} \\ &= 28.86 \end{aligned}$$

### WET MOLECULAR WEIGHT, LB/LB-MOLE

$$\begin{aligned} M_s &= M_d * M_{fd} + 18.0 * \%H_2O/100 \\ &= 28.86 * 0.984 + 18.0 * 1.55/100 \\ &= 28.69 \end{aligned}$$

### FUEL FACTOR

$$\begin{aligned} F_o &= (20.9 - \%O_2) / \%CO_2 \\ &= (20.9 - 20.2) / 0.3 \\ &= 2.333 \end{aligned}$$

### ISOKINETIC SAMPLING RATE, PERCENT

$$\begin{aligned} \%I &= P_{std}/(T_{std} + 460) * (100/60) * V_{mstd} * (t_s + 460) / [P_s * v_s * M_{fd} * \theta * (\pi * Dia * Dia / 576)] \\ &= 29.92 / (60 + 460) * (100/60) * 101.791 * (128 + 460) / [28.76 * 96.02 * 0.984 * 120.00 * (\pi * 0.180 * 0.180 / 576)] \\ &= 99.6 \end{aligned}$$

### VELOCITY, FEET PER SECOND

$$\begin{aligned} v_s &= 85.49 * C_p * \text{SQRT}[\Delta p * (460 + t_s) / P_s / M_s] \\ &= 85.49 * 0.84 * \text{SQRT}[2.5085 * (460 + 128) / 28.76 / 28.69] \\ &= 96.02 \end{aligned}$$

### VOLUMETRIC FLOW RATE, ACTUAL CUBIC FEET PER MINUTE

$$\begin{aligned} Q_{aw} &= (60/144) * v_s * A \\ &= (60/144) * 96.02 * 79 \\ &= 3142 \end{aligned}$$

### VOLUMETRIC FLOW RATE, DRY STANDARD CUBIC FEET PER MINUTE

$$\begin{aligned} Q_{sd} &= (60/144) * M_{fd} * v_s * A * (T_{std} + 460) / (t_s + 460) * (P_s / P_{std}) \\ &= (60/144) * 0.984 * 96.02 * 79 * (60 + 460) / (128 + 460) * (28.76 / 29.92) \\ &= 2629 \end{aligned}$$

**EXAMPLE CALCULATIONS, RUN 1**

TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT

$$\begin{aligned} \text{gr/DSCF} &= (\text{Catch/Conversion}) * 7,000 / 453.592 / \text{Vmstd} \\ &= (60.42/1000) * 7,000 / 453.592 / 101.791 \\ &= 0.00916 \end{aligned}$$

TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT @ 12% CO2

$$\begin{aligned} \text{Gr@12\%CO2} &= \text{gr/DSCF} * 12 / \% \text{CO2} \\ &= 0.00916 * 12 / 0.3 \\ &= 0.36641 \end{aligned}$$

TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT @ 7% O2

$$\begin{aligned} \text{Gr@7\%O2} &= \text{gr/DSCF} * (20.9-7) / (20.9-\% \text{O2}) \\ &= 0.00916 * (20.9-7) / (20.9-20.20) \\ &= 0.23424 \end{aligned}$$

TOTAL PARTICULATE EMISSION RATE, POUNDS PER HOUR

$$\begin{aligned} \text{lb/hr} &= 60 * (\text{Catch/Conversion}) * \text{Qsd} / 453.592 / \text{Vmstd} \\ &= 60 * (60.42/1000) * 2629 / 453.592 / 101.791 \\ &= 0.206 \end{aligned}$$

Location: Inlet 2 (downstream/outside)

## TEST RESULTS

### SCAQMD Method 5.1 (Particulate Matter)

**Facility:** AQMD Facility A

**City:** ██████████ CA

**Source:** Baghouse

**Location:** Inlet 1 (Upstream to Baghouse)

Run Number	1	
Run Date	05/23/19	
Run Start Time	11:20	
Run Stop Time	13:36	
<b>Test Train Parameters</b>		<b>AVERAGE</b>
Volume of Dry Gas Sample, SCF*	100.62	100.62
<b>Flue Gas Parameters</b>		
CO2, Percent By Volume, Dry**	< 0.30	< 0.30
O2, Percent By Volume, Dry**	19.90	19.90
Temperature, Degrees F	83.7	83.7
Moisture, %	1.84	1.84
Air Flow Rate, Wet ACFM	40,129	40,129
Air Flow Rate, Dry SCFM*	36,230	36,230
<b>Total Particulate</b>		
Catch, mg	16.27	16.27
Concentration, Gr/DSCF	0.002495	0.002495
Emission Rate, lb/hr	0.775	0.775

\* 60 Degrees F and 29.92 Inches of Mercury

\*\* O2/CO2 was sampled in Tedlar bag and analysed via SCAQMD Method 10.1 by GC.



## ISOKINETIC SAMPLING TRAIN RESULTS - METHOD: METHOD 5.1

Client Name	Facility A	Operator	MN
Plant Name	Metal Melting facility	Project #	10562
Sampling Location	Inlet 2 (downstream)	Standard Temperature, °F	60

USE IN AVERAGE OF RUN SET? 1 or 0 =>	1			SET AVERAGE
Run Number	1			
Run Date	05/23/19			
Run Start Time	hh:mm	11:20		
Run Stop Time	hh:mm	13:36		
Meter Calibration Factor	Y	1.0395		
Pitot Tube Coefficient	C <sub>p</sub>	0.84		
Actual Nozzle Diameter	in	0.173		
Sample Volume	ft <sup>3</sup>	100.88		100.88
Total Sampling Time	min	120		120
Average Meter Temperature	°F	82.8		82.8
Average Stack Temperature	°F	83.7		83.7
Barometric Pressure	in Hg	29.80		29.8
Stack/Duct Static Pressure	in H <sub>2</sub> O	-14.00		-14.00
Absolute Stack/Duct Pressure	in Hg	28.8		28.8
Average Delta H	in H <sub>2</sub> O	2.46		2.46
Absolute Meter Pressure	in Hg	30.0		30.0
Avg Differential Pressure (Delta P)	in H <sub>2</sub> O	2.632		2.632
Total Water Volume Collected	mL	40.6		40.6
Volume of Water vapor @ STP	SCF	1.882		1.882
Volume Metered @ STP	DSCF	100.620		100.620
Calculated Stack Moisture	% H <sub>2</sub> O	1.84		1.8
Saturated Stack Moisture	% H <sub>2</sub> O	4.0		4.0
Reported Stack Moisture Content	% H <sub>2</sub> O	1.84		1.84
Carbon Dioxide Percentage	% CO <sub>2</sub>	0.30		0.30
Oxygen Percentage	% O <sub>2</sub>	19.90		19.90
Carbon Monoxide Percentage	% CO	0.000		0.000
Nitrogen Percentage	% N <sub>2</sub>	79.8		79.8
Dry Mole Fraction	decimal	0.982		0.982
Dry Gas Molecular Weight	lb/lb-mole	28.84		28.84
Wet Stack Gas Molecular Weight	lb/lb-mole	28.64		28.64
Flue Gas Density	lb/ft <sup>3</sup>	0.0743		0.0743
Stack Cross-Sectional Area	in <sup>2</sup>	1017.9		1017.9
Stack Cross-Sectional Area	ft <sup>2</sup>	7.07		7.07
Percent of Isokinetic Rate	% ISO	100.3		100.3

### Air Flow Rate Results

Average Stack Gas Velocity	ft/sec	94.62		94.62
Actual Stack Flow/Minute	ACFM	40,129		40,129
Dry Standard Stack Flow/Minute	DSCFM	36,230		36,230



	Water 1	Water 2	Empty	SG
Initial	754.1	765.0	626.8	869.4
Final	771.5	768.4	629.2	886.8
H2O gain	17.4	3.40	2.40	17.40
Total H2O	40.6			

Cumul. Percent ISO	Point Percent ISO	Square Root DP (in H <sub>2</sub> O) <sup>1/2</sup>	Local Stack Velocity ft/sec	Cumulative Meter Volume scf	Point Meter Volume scf
104.2	104.2	1.549	90.2	4.229	4.229
101.0	98.1	1.732	100.8	8.681	4.451
100.9	100.7	1.844	107.5	13.535	4.853
100.5	99.3	1.789	104.2	18.183	4.648
100.4	99.9	1.703	99.5	22.624	4.441
100.4	100.8	1.673	98.0	27.016	4.392
100.5	101.1	1.673	97.7	31.431	4.416
100.6	101.0	1.517	88.8	35.415	3.989
100.4	98.9	1.342	78.4	38.866	3.459
100.4	100.4	1.342	78.1	42.390	3.530
100.3	100.1	1.378	80.4	45.990	3.605
100.4	100.6	1.581	92.1	50.152	4.162
100.4	101.0	1.817	106.0	54.946	4.794
100.5	101.0	1.789	104.6	59.660	4.713
100.4	99.1	1.732	101.0	64.149	4.489
100.4	100.0	1.732	101.2	68.671	4.521
100.4	100.7	1.703	99.4	73.151	4.479
100.4	100.8	1.703	99.3	77.641	4.490
100.4	100.5	1.703	99.6	82.105	4.463
100.5	102.9	1.549	90.7	86.258	4.154
100.5	99.3	1.323	77.2	89.685	3.432
100.4	99.6	1.414	82.6	93.358	3.676
100.4	100.2	1.643	95.7	97.666	4.308
100.4	100.3	1.703	98.5	102.168	4.502
100.4	100.3	<b>Final Values</b>		102.168	4.502
		1.622	94.6		

## EXAMPLE CALCULATIONS, RUN 1

### ABSOLUTE PRESSURE, INCHES OF MERCURY

$$\begin{aligned} P_s &= P_{bar} + P_g/13.6 \\ &= 29.80 + -14.00/13.6 \\ &= 28.77 \end{aligned}$$

### VOLUME OF WATER VAPOR, STANDARD CUBIC FEET

$$\begin{aligned} V_{wstd} &= 0.002667 * [(T_{std} + 460) / P_{std}] * V_{lc} \\ &= 0.002667 * [(60 + 460) / 29.92] * 40.6 \\ &= 1.882 \end{aligned}$$

### SAMPLED VOLUME OF SOURCE GAS, DRY STANDARD CUBIC FEET

$$\begin{aligned} V_{mstd} &= [(T_{std} + 460)/P_{std}] * Y * V_m * (P_{bar} + \Delta H/13.6) / (460 + t_m) \\ &= [(60 + 460)/ 29.92] * 1.0395 * 100.882 * (29.80 + 2.460/13.6) / (460 + 83) \\ &= 100.620 \end{aligned}$$

### MOISTURE CONTENT, PERCENT BY VOLUME

$$\begin{aligned} \%H_2O &= V_{wstd} / (V_{wstd} + V_{mstd}) \\ &= 1.882 / (1.882 + 100.620) \\ &= 1.84 \end{aligned}$$

### DRY MOLE FRACTION, LB-MOLE/LB-MOLE

$$\begin{aligned} M_{fd} &= 1 - \%H_2O/100 \\ &= 1 - 1.84/100 \\ &= 0.982 \end{aligned}$$

### DRY MOLECULAR WEIGHT, LB/LB-MOLE

$$\begin{aligned} M_d &= 44 * (\%CO_2/100) + 32 * (\%O_2/100) + 28 * \{[100 - (\%CO_2 + \%O_2)]/100\} \\ &= 44 * (0.3/100) + 32 * (19.9/100) + 28 * \{[100 - (0.3 + 19.9)]/100\} \\ &= 28.84 \end{aligned}$$

### WET MOLECULAR WEIGHT, LB/LB-MOLE

$$\begin{aligned} M_s &= M_d * M_{fd} + 18.0 * \%H_2O/100 \\ &= 28.84 * 0.982 + 18.0 * 1.84/100 \\ &= 28.64 \end{aligned}$$

### FUEL FACTOR

$$\begin{aligned} F_o &= (20.9 - \%O_2) / \%CO_2 \\ &= (20.9 - 19.9) / 0.3 \\ &= 3.333 \end{aligned}$$

### ISOKINETIC SAMPLING RATE, PERCENT

$$\begin{aligned} \%I &= P_{std} / (T_{std} + 460) * (100/60) * V_{mstd} * (t_s + 460) / [P_s * v_s * M_{fd} * \theta * (\pi * D_{ia} * D_{ia} / 576)] \\ &= 29.92 / (60 + 460) * (100/60) * 100.620 * (84 + 460) / [28.77 * 94.62 * 0.982 * 120.00 * (\pi * 0.173 * 0.173 / 576)] \\ &= 100.3 \end{aligned}$$

### VELOCITY, FEET PER SECOND

$$\begin{aligned} v_s &= 85.49 * C_p * \text{SQRT}[\Delta p * (460 + t_s) / P_s / M_s] \\ &= 85.49 * 0.84 * \text{SQRT}[2.6317 * (460 + 84) / 28.77 / 28.64] \\ &= 94.62 \end{aligned}$$

### VOLUMETRIC FLOW RATE, ACTUAL CUBIC FEET PER MINUTE

$$\begin{aligned} Q_{aw} &= (60/144) * v_s * A \\ &= (60/144) * 94.62 * 1018 \\ &= 40129 \end{aligned}$$

### VOLUMETRIC FLOW RATE, DRY STANDARD CUBIC FEET PER MINUTE

$$\begin{aligned} Q_{sd} &= (60/144) * M_{fd} * v_s * A * (T_{std} + 460) / (t_s + 460) * (P_s / P_{std}) \\ &= (60/144) * 0.982 * 94.62 * 1018 * (60 + 460) / (84 + 460) * (28.77 / 29.92) \\ &= 36230 \end{aligned}$$

**EXAMPLE CALCULATIONS, RUN 1**

TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT

$$\begin{aligned} \text{gr/DSCF} &= (\text{Catch/Conversion}) * 7,000 / 453.592 / \text{Vmstd} \\ &= (16.27/1000) * 7,000 / 453.592 / 100.620 \\ &= 0.00250 \end{aligned}$$

TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT @ 12% CO2

$$\begin{aligned} \text{Gr@12\%CO2} &= \text{gr/DSCF} * 12 / \% \text{CO2} \\ &= 0.00250 * 12 / 0.3 \\ &= 0.09981 \end{aligned}$$

TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT @ 7% O2

$$\begin{aligned} \text{Gr@7\%O2} &= \text{gr/DSCF} * (20.9-7) / (20.9-\% \text{O2}) \\ &= 0.00250 * (20.9-7) / (20.9-19.90) \\ &= 0.04467 \end{aligned}$$

TOTAL PARTICULATE EMISSION RATE, POUNDS PER HOUR

$$\begin{aligned} \text{lb/hr} &= 60 * (\text{Catch/Conversion}) * \text{Qsd} / 453.592 / \text{Vmstd} \\ &= 60 * (16.27/1000) * 36230 / 453.592 / 100.620 \\ &= 0.775 \end{aligned}$$

**APPENDIX E2**  
**PARTICULATE MATTER (PM) – FIELD DATA**


Location: Baghouse Outlet

Sampling Access

The exhaust test location was accessed via a man lift for one side of the exhaust.

For the others side, the facility installed a platform with guardrails that extends from the roof to the exhaust stack.

146 inches divided by 4, and then by 2  
 36.50 Div 4  
 18.25 Div 2  
 54.75 Sum  
 60 minutes at 5 minutes a point



9 Points Roof Side

12 Points Lot Side



Flows Determined by  
Combined 2 later Scales

Run #: <b>1</b>	Pilot ID: <b>41</b>	Impinger #	Initial	Final	Net	Pilot Leak Check	
Date: <b>5-23-19</b>	Pilot Coeff.: <b>.84</b>	1	<b>738.5</b>	<b>752.0</b>		Initial: <b>NA</b>	Final: <b>NA</b>
Client: <b>Facility A</b>	Meter Box #: <b>A-6</b>	2	<b>720.2</b>	<b>729.5</b>		Initial: <b>NA</b>	Final: <b>NA</b>
Unit: <b>Outlet 1</b>	Meter @ Dh: <b>1.289</b>	3	<b>639.1</b>	<b>639.2</b>		Meter Box Leak Check	
Operator: <b>CH</b>	Meter Y: <b>1.0376</b>	4	<b>832.5</b>	<b>854.5</b>		Rate	"HG
Stack Dia:	TC #: <b>41</b>	5				Initial: <b>000</b>	Final: <b>20"</b>
Amb. Press: <b>29.50</b>	Start Time: <b>1120</b>	Nozzle Dia	H2O Gain =		Filter: <b>009438</b>		
Static Press: <b>NA</b>	Stop Time: <b>1376</b>	<b>.513</b>					

Traverse Points	Time (Minute)	Delta P (H2O)	Stack Temp. (F)	Set delta H (H2O)	Meter Volume (scf)	Mr. Inlet Temp. (F)	Mr. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Visc. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
0	0	-	-	-	196.362	-	-	NA	NA	-	-	NA	
1	7	.0251	84	1.76	201.361	70	70			54	5		
2	14	.0251	87	1.75	206.342	69	69			54	5		
3	21	.0251	90	1.74	211.913	70	70			54	5		
4	28	.0251	88	1.75	216.310	72	72			54	5		
5	35	.0251	86	1.77	221.343	74	74			54	5		
6	42	.0251	85	1.77	226.378	75	75			54	5		
7	49	.0251	83	1.78	231.445	76	76			54	5		
8	56	.0251	87	1.77	236.501	77	77	↓	↓	55	5	↓	
9	63	.0251	85	1.78	241.572	78	78	NA	NA	55	5	NA	
					241.926								
1	5	.0251	90	1.75	245.501	73	73	NA	NA	55	5	NA	
2	10	.0251	87	1.76	249.082	74	74			55	5		
3	15	.0251	84	1.77	252.691	74	74			55	5		
4	20	.0251	89	1.76	256.271	74	74			55	5		
5	25	.0251	86	1.77	259.872	75	75			55	5		
6	30	.0251	87	1.77	263.470	76	76			55	5		
7	35	.0251	89	1.76	267.062	76	76			55	5		
8	40	.0251	85	1.78	270.683	77	77			55	5		
9	45	.0251	83	1.77	274.301	77	77			55	5		
10	50	.0251	87	1.77	277.912	77	77			55	5		
11	55	.0251	90	1.76	281.513	77	77	↓	↓	55	5	↓	
12	60	.0251	88	1.77	285.123	78	78	NA	NA	55	5	NA	

Height @ 133c  
 Addition 160c  
 Check

**Isokinetic Factor Setup**

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: **2%**

Estimated O2: **20.7**

Estimated CO2: **0.5**

**Equipment Evaluation, OK? Y or N**

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

**Dry Gas Meter Leak Checks**

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Location: Inlet 1 (Inside)

**SAMPLING AND VELOCITY TRAVERSE POINT DETERMINATION  
SCAQMD METHOD 1.2**

CLIENT: AQMD Facility A  
 PLANT NAME: Metal Melting Facility  
 CITY, STATE: ██████████ CA  
 SAMPLING LOCATION: Inlet Furnace  
 TYPE OF TESTING: Metals & Particulate

NO. OF PORTS AVAILABLE: 2  
 NO. OF PORTS TO BE USED: 2  
 PORT INSIDE DIAMETER: 3 inches


DISTANCE FROM FAR WALL TO OUTSIDE OF PORT: 13.50 inches  
 NIPPLE LENGTH AND/OR WALL THICKNESS: 3.50 inches  
 DEPTH OF STACK OR DUCT, D: 10.00 inches  
 STACK OR DUCT WIDTH (IF RECTANGULAR), W: #N/A inches

EQUIVALENT DIAMETER  
 $De = 2 * (DEPTH) * (WIDTH) / (DEPTH + WIDTH) =$  10.00 inches  
 MAKE SURE TO USE METHOD A  
 STACK/DUCT AREA = 0.55 sq. feet 78.5 sq. inches

	DISTANCE OF TEST PORT LOCATION:	DOWNSTREAM FROM FLOW DISTURBANCE	UPSTREAM FROM FLOW DISTURBANCE
		B	A
# OF INCHES	25.00	16.50	
# OF DIAMETERS	2.50	1.65	

MINIMUM NUMBER OF TRAVERSE POINTS: 24

POINT NO.	% OF DUCT DEPTH	DISTANCE FROM INSIDE WALL (in.)	DISTANCE FROM OUTSIDE OF PORT (in.)
1	2.1	0.50	4
2	6.7	0.67	4 1/8
3	11.8	1.18	4 5/8
4	17.7	1.77	5 1/4
5	25.0	2.50	6
6	35.6	3.56	7
7	64.4	6.44	10
8	75.0	7.50	11
9	82.3	8.23	11 3/4
10	88.2	8.82	12 3/8
11	93.3	9.33	12 7/8
12	97.9	9.50	13



DRAWING NOT TO SCALE

Run #:	1	Pilot ID:	28	Impinger #:	Initial	Final	Net	Pilot Leak Check		
Date:	05/23/19	Pilot Coeff.:	.84	1	743.5	754.7		Initial:	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Client:	Facility A	Meter Box #:	A-7	2	621.4	625.1		Final:	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Unit:	Inlet 1 (Inside)	Meter @ Dh:	1.736	3	634.5	636.8		Meter Box Leak Check		
Operator:	T. TR	Meter Y:	1.0274	4	873.5	889.8		Rate:		THG
Stack Dia:	10.6	TC #:	29	5		1.4		Initial:	0.006	20.0
Amb. Press:	29.8	Start Time:	1120	Nozzle Dia:	H2O Gain =			Final:	0.009	21.0
Static Press:	-14.2	Stop Time:	1336	180	Filter:		009434			

TOP

side

Inverse Points	Time (Minute)	Delta P (H2O)	Stack Temp. (F)	Set delta H (H2O)	Meter Volume (scf)	Mt. Inlet Temp. (F)	Mt. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
0	0	1.8			859.04								
A-1	5	2.6	113	2.43	863.40	84	84	NA	NA	56	4.0		
2	10	2.6	102	2.58	867.87	85	85			50	4.0		
3	15	2.30	138	2.15	872.0	87	87			52	3.50		
4	20	2.40	118	2.33	876.30	88	88			53	4.0		
5	25	2.50	140	2.34	880.55	89	89			53	4.0		
6	30	2.50	170	2.23	884.79	90	90			52	4.0		
7	35	3.30	141	3.09	889.74	90	90			52	5.0		
8	40	3.40	164	3.07	894.70	92	92			53	5.0		
9	45	3.0	132	2.86	899.54	93	93			54	5.0		
10	50	2.40	134	2.78	903.80	93	93			53	4.50		
11	55	2.10	131	2.01	907.74	93	93			53	4.0		
12	60	1.50	125	1.45	911.16	94	94			53	4.0		stop @ 1220
B-1	65	3.40	134	3.21	916.20	89	89			57	5.0		start @ 1236
2	70	3.60	139	3.38	921.30	90	90			48	5.0		
3	75	3.50	116	3.42	926.54	91	91			50	5.50		
4	80	3.60	141	3.38	931.70	92	92			50	5.50		
5	85	3.40	132	3.25	936.81	93	93			51	5.50		
6	90	3.50	117	3.43	942.04	94	94			52	5.50		
7	95	2.20	138	2.09	946.12	95	95			52	4.50		
8	100	2.40	121	2.34	950.40	95	95			52	4.50		
9	105	2.0	102	2.02	954.48	95	95			52	4.0		
10	110	1.60	100	1.62	958.10	95	95			53	4.0		
11	115	1.10	120	1.08	961.12	95	95			52	3.50		
12	120	.98	104	.98	963.94	94	94			52	3.50		
1 In to out 12													

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: \_\_\_\_\_

Estimated O2: \_\_\_\_\_

Estimated CO2: \_\_\_\_\_

Equipment Evaluation, OK? Y or N

Ambient Temp.: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pilot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pilot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						

Location: Inlet 2 (downstream/outside)

**SAMPLING AND VELOCITY TRAVERSE POINT DETERMINATION  
SCAQMD METHOD 1.1**

CLIENT: AQMD Facility A  
 PLANT NAME: Metal Melting Facility  
 CITY, STATE: ██████████ CA  
 SAMPLING LOCATION Inlet (Upstream of Baghouse)  
 TYPE OF TESTING: Metals/Particulate

NO. OF PORTS AVAILABLE: 1  
 NO. OF PORTS TO BE USED: 1  
 PORT INSIDE DIAMETER: 2.5 inches

DISTANCE FROM FAR WALL TO OUTSIDE OF PORT: 38.00 inches  
 NIPPLE LENGTH AND/OR WALL THICKNESS: 2.00 inches  
 DEPTH OF STACK OR DUCT, D: 36.00 inches  
 STACK OR DUCT WIDTH (IF RECTANGULAR), W: #N/A inches


EQUIVALENT DIAMETER  
 $De = 2 * (DEPTH) * (WIDTH) / (DEPTH + WIDTH) =$  36.00 inches

STACK/DUCT AREA = 7.07 sq.feet 1017.9 sq.inches

DISTANCE OF TEST PORT LOCATION:	DOWNSTREAM	UPSTREAM
	FROM FLOW	FROM FLOW
	<u>DISTURBANCE</u>	<u>DISTURBANCE</u>
	B	A
# OF INCHES	87.00	48.50
# OF DIAMETERS	2.42	1.35

MINIMUM NUMBER OF TRAVERSE POINTS: 24

POINT NO.	% OF DUCT DEPTH	DISTANCE FROM INSIDE WALL (in.)	DISTANCE FROM OUTSIDE OF PORT (in.)
1	2.1	0.76	2 3/4
2	6.7	2.41	4 3/8
3	11.8	4.25	6 1/4
4	17.7	6.37	8 3/8
5	25.0	9.00	11
6	35.6	12.82	14 7/8
7	64.4	23.18	25 1/8
8	75.0	27.00	29
9	82.3	29.63	31 5/8
10	88.2	31.75	33 3/4
11	93.3	33.59	35 5/8
12	97.9	35.24	37 1/4



DRAWING NOT TO SCALE

Run #:	1	Pitot ID:	34	Impinger #:	Initial	Final	Net	Pitot Leak Check		
Date:	5-23-19	Pitot Coeff.:	0.84	1	754.1	771.7		Initial:	0	0
Client:	Facility A	Meter Box #:	A-B	2	765.0	768.4		Final:	0	0
Unit:	Inlet 2 (Outside)	Meter @ Dh:	1.834	3	626.8	629.7		Meter Box Leak Check		
Operator:	MN	Meter Y:	1.0395	4	809.4	886.8		Rate:		7HG
Stack Dia:	36.0	TC #:	84	5				Initial:	0.000	20
Amb. Press:	29.8	Start Time:	1120	Nozzle Dia:	H2O Gain =			Final:	0.020	21
Static Press:	-14	Stop Time:	1336	Filter:	009437					

Traverse Points	Time (Minutes)	Delta P (H2O)	Stack Temp. (F)	Set delta H (H2O)	Meter Volume (scf)	Mr. Inlet Temp. (F)	Mr. Outlet Temp. (F)	Oven Temp. (F)	Probe Temp. (F)	Impinger Temp. (F)	Pump Vac. (HG)	TE Cooler Temp. (F)	Cyclonic Flow (H2O)
12	0.0	2.40	81	2.25	489.58	NA	75	NA	NA	52	5.0	NA	40
11	5.0	3.00	81	2.80	493.56		77			47	5.0		410
10	10.0	3.40	83	3.15	498.00		79			50	5.0		
9	15.0	3.20	82	2.95	502.75		80			51	5.0		
8	20.0	2.90	85	2.70	507.31		80			52	5.0		
7	25.0	2.80	86	2.50	511.67		82			52	5.0		
6	30.0	2.80	85	2.60	516.00		83			52	5.0		
5	35.0	2.30	87	2.15	520.36		84			52	5.0		
4	40.0	1.80	86	1.65	524.31		84			52	4.0		
3	45.0	1.80	81	1.65	527.74		84			52	4.0		
2	50.0	1.90	84	1.75	531.24		85			52	4.0		
1	55.0	2.50	82	2.30	534.82	↓	84	↓	↓	52	4.0	↓	↓
0	60.0	3.30	84	3.05	538.94	NA	82	NA	NA	52	5.0	NA	210
12	65.0	3.20	86	2.95	543.660		83			49	5.0		
11	70.0	3.00	83	2.80	548.31		83			49	5.0		
10	75.0	3.00	85	2.80	552.74		84			49	5.0		
9	80.0	2.90	84	2.70	557.21		84			50	5.0		
8	85.0	2.90	84 <sup>83</sup>	2.70	561.64		84			50	5.0		
7	90.0	2.90	86	2.7	566.08		86			50	5.0		
6	95.0	2.40	87	2.25	570.51		85			51	5.0		
5	100.0	1.75	84	1.60	574.63		85			51	5.0		
4	105.0	2.00	85	1.85	578.04		85			51	5.0		
3	110.0	2.70	82	2.50	581.69		85			52	5.0		
2	115.0	2.90	74	2.70	585.96	↓	85	↓	↓	52	5.0	↓	↓
1	120.0				590.42								
0													

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp: \_\_\_\_\_

Estimated Stack Temp: \_\_\_\_\_

Estimated Delta P: \_\_\_\_\_

Estimated Moisture Content: \_\_\_\_\_

Estimated O2: \_\_\_\_\_

Estimated CO2: \_\_\_\_\_

Equipment Evaluation, OK? Y or N

Ambient Temp: \_\_\_\_\_

TC Check: \_\_\_\_\_

Pitot Check: \_\_\_\_\_

Tedlar Bag: \_\_\_\_\_

Pitot Exp Date: \_\_\_\_\_

TC Exp Date: \_\_\_\_\_

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial:						
Vacuum:						
Leak Rate:						
DGM Final:						





**APPENDIX E3**

**PARTICULATE MATTER (PM) – LABORATORY DATA**


**LABORATORY REPORT**  
SCAQMD M5.1

Lab Report No. A 053  
Client Name: AQMD  
Unit Tested: Facility A

Project No.: c10562  
Date Sampled: 23-May-19  
Analyst: DW

Client ID	Run #1	Run #2	Run #3	Field Blank
<b>Container No 1 (Filter)</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>
Client ID No.:	10562-M5.1-C1-In(I)-R1	10562-M5.1-C1-In(O)-R1	10562-M5.1-C1-Out-R1	10562-M5.1-C1-In(O)-FB
Lab ID No.:	A 053 - R1 - C1	A 053 - R2 - C1	A 053 - R3 - C1	A 053 - FB - C1
Filter ID #	9434	9437	9438	9441
Filter wt., total, mg (m <sub>T</sub> )	12.35	0.60	0.40	0.00
Filter Acid, mg	ND	NA	NA	NA
Filter SO <sub>4</sub> , mg	ND	NA	NA	NA
Filter wt., net, mg (m <sub>PM</sub> )	<b>12.35</b>	<b>0.60</b>	<b>0.40</b>	<b>0.00</b>
<b>Container No 2 (Impinger) -Water org</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>
Client ID No.:	10562-M5.1-C2-In(I)-R1	10562-M5.1-C2-In(O)-R1	10562-M5.1-C2-Out-R1	10562-M5.1-C2-In(O)-FB
Lab ID No.:	A 053 - R1 - C2 org	A 053 - R2 - C2 org	A 053 - R3 - C2 org	A 053 - FB - C2 org
Volume, ml (V <sub>imp</sub> )	100	100	100	100
Impinger Catch, total, mg (m <sub>IMP</sub> )	0.35	0.30	0.85	0.00
Methylen Chloride Blank, mg (W <sub>MB</sub> )	0.03	0.03	0.03	0.03
Impinger Catch, net, mg (m <sub>IMP</sub> ) (m <sub>IMP</sub> - m <sub>MB</sub> - W <sub>MB</sub> )	<b>0.32</b>	<b>0.27</b>	<b>0.82</b>	<b>0.00</b>
<b>Container No 2 (Impinger) -Water sr</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>
Client ID No.:	10562-M5.1-C2-In(I)-R1	10562-M5.1-C2-In(O)-R1	10562-M5.1-C2-Out-R1	10562-M5.1-C2-In(O)-FB
Lab ID No.:	A 053 - R1 - C2 sr	A 053 - R2 - C2 sr	A 053 - R3 - C2 sr	A 053 - FB - C2 sr
Volume, L (V <sub>imp</sub> )	495	415	465	457
Impinger Catch, total, mg (m <sub>IMP</sub> )	47.75	15.40	2.10	0.05
DI Water Blank, mg (W <sub>DI</sub> )	0.00	0.00	0.00	0.00
Impinger Acid, mg (m <sub>IMP</sub> )	ND	ND	ND	ND
Impinger SO <sub>4</sub> , mg (m <sub>IMP</sub> )	ND	ND	ND	ND
Impinger Catch, net, mg (m <sub>IMP</sub> ) (m <sub>IMP</sub> - m <sub>DI</sub> - W <sub>DI</sub> )	<b>47.75</b>	<b>15.40</b>	<b>2.10</b>	<b>0.05</b>
<b>Total Particulate mass, net, mg (m<sub>T</sub>)</b>	<b>60.45</b>	<b>16.30</b>	<b>3.35</b>	<b>0.05</b>
<b>Blank correction weight of PM, mg (m<sub>FB</sub>)</b>	<b>60.42</b>	<b>16.27</b>	<b>3.32</b>	<b>0.05</b>

$$m_T = m_{IN} + m_{FB} + m_{FB}$$

Checked by:  Inlet 1 (Inside) Inlet 2 (Upstream B.H.) B. H. Outlet

**SUMMARY**  
**SCAQMD M5.1**

Laboratory: **Almega**  
Project: **AQMD**  
Unit Tested: **Facility A**  
Lab. ID No.: **A 053**

Project No.: **c10562**  
Filter, Beaker Wt. Log Page(s): **#34-35, #21-22**

Sample Number	Lab ID	Tare Wt. (avg. g)	Final Wt. (avg. g)	Net Change (mg)	Volume ml	Blank mg	Comments
10562-M5.1-C1-In(I)-R1	A 053 - R1 - C1	0.3727	0.3851	12.45	-		Inlet - In
10562-M5.1-C2-In(I)-R1	A 053 - R1 - C2 org	27.5299	27.5302	0.35	100	0.03	Inlet - In
10562-M5.1-C2-In(I)-R1	A 053 - R1 - C2 sr	28.0260	28.0737	47.75	495	0.00	Inlet - In
10562-M5.1-C1-In(O)-R1	A 053 - R2 - C1	0.3722	0.3729	0.70	-		Inlet - Out
10562-M5.1-C2-In(O)-R1	A 053 - R2 - C2 org	27.8769	27.8772	0.30	100	0.03	Inlet - Out
10562-M5.1-C2-In(O)-R1	A 053 - R2 - C2 sr	29.4475	29.4629	15.40	415	0.00	Inlet - Out
10562-M5.1-C1-Out-R1	A 053 - R3 - C1	0.3710	0.3715	0.55	-		Outlet
10562-M5.1-C2-Out-R1	A 053 - R3 - C2 org	27.8941	27.8950	0.85	100	0.03	Outlet
10562-M5.1-C2-Out-R1	A 053 - R3 - C2 sr	27.8207	27.8228	2.10	465	0.00	Outlet
10562-M5.1-C1-In(O)-FB	A 053 - FB - C1	0.3730	0.3730	0.00	-		Field Blank
10562-M5.1-C2-In(O)-FB	A 053 - FB - C2 org	29.6511	29.6511	0.00	100	0.03	Field Blank
10562-M5.1-C2-In(O)-FB	A 053 - FB - C2 sr	29.6182	29.6182	0.05	457	0.00	Field Blank
Reagent Blank		28.6642	28.6641	-0.05	500		DI Water
Reagent Blank		28.7205	28.7207	0.15	500		Methylene Chloride

**CALCULATIONS**

$$C_A = m_A / (V_A * \rho_A)$$

Where:

$C_A$  - Blank Concentration  
 $m_A$  - Mass of residue of after evaporation, mg  
 $V_A$  - Volume of blank, ml  
 $\rho_A$  - Density, g/ml

$$W_A = C_A * V_{WA} * \rho_A$$

Where:

$W_A$  - Weight of residue, mg  
 $V_{WA}$  - Volume of liquid use, ml

**Reagent Blank**

**Methylene Chloride**

Density of methylene chloride  $\rho_M$ , g/ml = 1.3550  
Methylene Chloride blank volume  $V_M$ , ml = 500  
Methylene Chloride blank concentration  $C_M$ , mg/g = 0.0002

MeCl Lot No. 186645 Fisher Scientific Optima

**DI Water**

Density of Water  $\rho_W$ , g/ml = 0.998  
Water blank volume  $V_W$ , ml = 500  
Water blank concentration  $C_W$ , mg/g = 0.0000

DI Water System - Pure Water Tech

SULFURIC ACID & SULFUR OXIDES - LABORATORY DATA SHEET

Client: AQMD Project #: c10562 Checked by: DW  
 Site Location: NA Unit Tested: Facility A  
 Analyst: DW Date Analyzed: 19-Jun-19

Sample No.	Sample		Factor, F = V/A	Sample Titration			Acid, as H <sub>2</sub> SO <sub>4</sub> *2H <sub>2</sub> O mg	Sulfate, as H <sub>2</sub> SO <sub>4</sub> *2H <sub>2</sub> O mg
	Total, V (mL)	Aliquot, A (mL)		T1 (mL)	T2 (mL)	Avg, V (mL)		
ANALYSIS FOR ACID								
A 053 - R1 - C1	50	10	5	0.00	0.00	0.00	ND	ND
A 053 - R1 - C2 sr	50	10	5	0.00	0.00	0.00	ND	ND
A 053 - R2 - C2 sr	50	10	5	0.00	0.00	0.00	ND	ND
A 053 - R3 - C2 sr	50	10	5	0.00	0.00	0.00	ND	ND
A 053 - FB - C2 sr	50	10	5	0.00	0.00	0.00	ND	ND
ANALYSIS FOR SULFATE								
A 053 - R1 - C1	50	10	5	0.00	0.00	0.00	ND	ND
A 053 - R1 - C2 sr	50	10	5	0.00	0.00	0.00	ND	ND
A 053 - R2 - C2 sr	50	10	5	0.00	0.00	0.00	ND	ND
A 053 - R3 - C2 sr	50	10	5	0.00	0.00	0.00	ND	ND
A 053 - FB - C2 sr	50	10	5	0.00	0.00	0.00	ND	ND

No.	Sodium Hydroxide Titration		Barium Chloride Titration		Detection Limit
	KHP (mg)	Volume, Vs (mL)	Aliquot, Vt (10 mL)	Volume, VT (mL)	
Blank	-	0.00	-	0.02	Sulfate, as H <sub>2</sub> SO <sub>4</sub> *2H <sub>2</sub> O, mg
1	0.00000		4	3.98	0.01
2	0.00000		4	4.00	Acid, as H <sub>2</sub> SO <sub>4</sub> *2H <sub>2</sub> O, mg
Avg.	0.10000			0.01010	0.13

Sulfuric Acid Concentration 0.01000N  
 Rieca Lot 4610D98 Exp Sept 2019  
 Sodium Hydroxide Solution 0.100 N  
 BDH Lot 18J1156571 Exp Sept 2021

Sulfate as SO<sub>4</sub>, mg=(V<sub>s</sub>-V<sub>tb</sub>) x N<sub>B</sub> x 134.11/2 x F  
 Acid as SO<sub>4</sub>, mg=(V<sub>s</sub>-V<sub>tb</sub>) x N<sub>S</sub> x 134.11/2 x F

Calculations: N<sub>S</sub> = (mg KHP/203.44)/(V<sub>s</sub>-V<sub>tb</sub>)  
 N<sub>B</sub> = (V<sub>1</sub> x N<sub>1,25504</sub>)/(V<sub>T</sub>-V<sub>TB</sub>)





**Standard Receipt  
Sample LOG in Checklist**

Project No: 10562  
~~61670~~

Method: M10.1

Lab ID: ACS3

Sampling Date: 5/21, 5/22, 5/23

Location: AQMD - A Int: \_\_\_\_\_

Date & Time Rc'd: 5/22/19 9:02  
5/23/19 8:42 5/24/19 8:15

Location: LAB Int: DN

Arrived By: (circle) FedEx UPS Drop Off (Int) DS Other \_\_\_\_\_

Condition of Package(s): (comment) OK // Package Type: Box Cooler Other: /

Number of Sample Container(s): 3, 3, 3, 9 Correct Containers (per Method): (Y) N ✓

Preservation: (circle) ICE DryICE ICEPacks (None) ✓ ✓

**Sample Conditions:**

Sample Temp (C): 21 ✓ ✓

Ambient Temp (C): 21 ✓ ✓

Sample Temp (C): \_\_\_\_\_

Filter Condition: OK

pH: \_\_\_\_\_

Components Sealed: (Y) N ✓ ✓

Sample Recovery Completed On: (date & time) \_\_\_\_\_

Recovered In: (circle) (Field) Lab Other ✓ ✓ Silica Gel Condition: \_\_\_\_\_

Tedlar Bags -  
Condensation: Y N

Comments:

Container(s) Requested: Glass \_\_\_\_\_ Plastic \_\_\_\_\_

Additional Comments:

**Beakers Weight Record**

Laboratory: Alsecan  
 Project No.: ADMMD  
 Unit Tested: e10562  
 Lab. ID No.: Facility A  
 A.053

X. Pretest

(page of )  
 Balanced ID: A&D ER-100A  
 Serial No.: 4702666  
 Last Calibration: 5/June-18  
 Beaker Weight Log Page(s): #671 - 22



Sample Number	Lab ID	Beaker ID	Date/Time		By		Beaker Weights (g)		D.Wt. (mg)	Volume ml	Comments
			1	2	1	2	WT. 1	WT. 2			
10562-M5.1-C2-In(D)-R1	A.053 - R1 - C2 0g	1748	6/2/19 11:00	6/4/19 11:00	DW	DW	27.5298	27.5299	0.10	100	Inlet - In
10562-M5.1-C2-In(D)-R1	A.053 - R1 - C2 0r	1752	6/2/19 11:00	6/4/19 11:00	DW	DW	28.0259	28.0260	0.10	495	Inlet - In
10562-M5.1-C2-In(D)-R1	A.053 - R2 - C2 0g	1749	6/2/19 11:00	6/4/19 11:00	DW	DW	27.8769	27.8769	0.00	100	Inlet - Out
10562-M5.1-C2-In(D)-R1	A.053 - R2 - C2 0r	1753	6/2/19 11:00	6/4/19 11:00	DW	DW	29.4474	29.4475	0.20	415	Inlet - Out
10562-M5.1-C2-Out-R1	A.053 - R3 - C2 0g	1750	6/2/19 11:00	6/4/19 11:00	DW	DW	27.8941	27.8941	0.00	100	Outlet
10562-M5.1-C2-Out-R1	A.053 - R3 - C2 0r	1754	6/2/19 11:00	6/4/19 11:00	DW	DW	27.8206	27.8207	0.10	465	Outlet
10562-M5.1-C2-In(D)-FB	A.053 - FB - C2 0g	1756	6/2/19 11:00	6/4/19 11:00	DW	DW	29.6512	29.6511	0.20	100	Field Blank
10562-M5.1-C2-In(D)-FB	A.053 - FB - C2 0r	1751	6/2/19 11:00	6/4/19 11:00	DW	DW	29.6181	29.6182	0.10	457	Field Blank
Reagent Blank		4321	5/24/19 17:00	5/31/19 17:00	DW	DW	28.6641	28.6642	0.10	500	DI Water
Reagent Blank		7965	11/1/18 11:00	11/2/18 11:00	DW	DW	28.7206	28.7204	0.20	500	Methylene Chloride
10562-M5.1-RB		1757	6/4/19 11:00	6/4/19 11:00	DW	DW	27.6165	27.6166	0.10	500	Reagent Blank

Beakers Weight Record

x Post-test (page\_of\_)

Laboratory: Almega  
Project: 60261D  
Project No.: c10562  
Unit Tested: Facility A  
Lab. ID No.: A.051

Balanced ID: A&D ER-182A  
Serial No.: 4702866  
Last Calibration: 5-Jun-18  
Beaker Weight Log Page(s): #21 - 22

Sample Number	Lab ID	Beaker ID	Beaker Weights (g)				D WL (mg)	Volume (ml)	Comments
			Date/Time	By	Wt. 1	Wt. 2			
10562-M5.1-C2-In(O)-R1	A.053-R1-C2-078	1748	6/12/19 14:00	DW	27.5301	6/13/19 10:00	27.5303	-0.20	Inlet - In
10562-M5.1-C2-In(O)-R1	A.053-R1-C2-078	1752	6/12/19 14:00	DW	28.0735	6/13/19 10:00	28.0739	-0.40	Inlet - In
10562-M5.1-C2-In(O)-R1	A.053-R2-C2-078	1749	6/12/19 14:00	DW	27.8771	6/13/19 10:00	27.8773	-0.20	Inlet - Out
10562-M5.1-C2-In(O)-R1	A.053-R2-C2-078	1753	6/12/19 14:00	DW	29.4628	6/13/19 10:00	29.4629	-0.20	Inlet - Out
10562-M5.1-C2-Out-R1	A.053-R3-C2-078	1750	6/12/19 14:00	DW	27.8949	6/13/19 10:00	27.8950	-0.10	Outlet
10562-M5.1-C2-Out-R1	A.053-R3-C2-078	1754	6/12/19 14:00	DW	27.8226	6/13/19 10:00	27.8229	-0.30	Outlet
10562-M5.1-C2-In(O)-FB	A.053-FB-C2-078	1756	6/12/19 14:00	DW	29.6510	6/13/19 10:00	29.6512	-0.20	Field Blank
10562-M5.1-C2-In(O)-FB	A.053-FB-C2-078	1751	6/12/19 14:00	DW	29.6181	6/13/19 10:00	29.6183	-0.20	Field Blank
Reagent Blank		4321	6/10/19 11:00	DW	28.6641	6/13/19 14:00	28.6641	0.00	DI Water
Reagent Blank		7965	11/15/18 11:00	DW	28.7207	11/16/18 12:00	28.7206	0.10	Methylene Chloride
10562-M5.1-RB		1757	6/12/19 14:00	DW	27.6167	6/13/19 10:00	27.6168	-0.10	Reagent Blank



**Filter Weight Record**

x \_\_\_\_\_ Pretest (page \_\_\_ of \_\_\_)

Laboratory: Almega  
 Project: AQMD  
 Project No.: 10562  
 Unit Tested: Facility A  
 Lab. ID No.: A.053

Balanced ID: A&D ER-182A  
 Serial No.: 4702866  
 Last Calibration: 5-Jun-18  
 Filter Weight Log Page(s): ##34 - 35

Client Sample No.	Lab ID	Filter ID	Filter Weights (g)				D Wt. (mg)	Comments			
			Date/Time	By	Wt. 1	Date/Time			By	Wt. 2	Average
10562-M5.1-C1- <u>In(I)</u> -R1	A 053 - R1 - C1	9434	5/16/19 11:00	DW	0.3727	5/17/19 11:00	DW	0.3726	0.3727	0.10	Inlet - In
10562-M5.1-C1- <u>In(O)</u> -R1	A 053 - R2 - C1	9437	5/16/19 11:00	DW	0.3723	5/17/19 11:00	DW	0.3721	0.3722	0.20	Inlet - Out
10562-M5.1-C1- <u>Out</u> -R1	A 053 - R3 - C1	9438	5/16/19 11:00	DW	0.3710	5/17/19 11:00	DW	0.3709	0.3710	0.10	Outlet
10562-M5.1-C1- <u>In(O)</u> -FB	A 053 - FB - C1	9441	5/16/19 11:00	DW	0.3730	5/17/19 11:00	DW	0.3730	0.3730	0.00	Field Blank

**Filter Weight Record**

x Post-test (page of )

Laboratory: Almega  
 Project: AQMD  
 Project No.: 10562  
 Unit Tested: Facility A  
 Lab. ID No.: A 053

Balanced ID: A&D ER-182A  
 Serial No.: 4702866  
 Last Calibration: 5-Jun-18  
 Filter Weight Log Page(s): #034 - 35

Client Sample No.	Lab ID	Filter ID	Filter Weights (g)				D Wt. (mg)	Comments
			Date/Time	By	Wt. 1	Wt. 2		
10562-M5.1-C1-Im(I)-R1	A 053 - R1 - C1	9434	1/0/00 0:00	DW	0.3851		385.10	Inlet - In
10562-M5.1-C1-Im(O)-R1	A 053 - R2 - C1	9437	1/0/00 0:00	DW	0.3729		372.90	Inlet - Out
10562-M5.1-C1-Out-R1	A 053 - R3 - C1	9438	1/0/00 0:00	DW	0.3715		371.50	Outlet
10562-M5.1-C1-Im(O)-FB	A 053 - FB - C1	9441	1/0/00 0:00	DW	0.3730		373.00	Field Blank

# TITRATION

C10562      m5.1  
Acids      A/5

Page: # 16

No	Sample ID	Date	Sample Volume		DF (S/A)	mL used	Note
			ml (S)	aliquot (A)			
1	A053 R1-cl	6/19	50	10	5	0.00	0.1 N NaOH
2	Dup		"	"	"	0.00	↓
3	R1-clsr		"	"	"	0.00	
4	Dup		"	"	"	0.00	
5	R2-clsr		"	"	"	0.00	
6	Dup		"	"	"	0.00	
7	R3-clsr		"	"	"	0.00	
8	Dup		"	"	"	0.00	
9	R3-clsr		"	"	"	0.00	
10	Dup		"	"	"	0.00	
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							

DF = Dilution Factor

Comments \*0.1 N NaOH Lot # 1851156571 Exp. Sept 2021-BDH

TITRATION

C10562

mS. (

Sulfates

A/S

Page: # 17

No	Sample ID	Date	Sample Volume		DF (S/A)	mL used	Note
			ml (S)	aliquot (A)			
1	0.01N H2SO4	6/19	4	4	1	3.98	0.01N BaCl2
2	Dup		"	"	"	4.08	↓
3	IPA BIK		100	100	1	6.00	
4	Dup		"	"	"	0.00	
5	A053 RI-CI		50	10	5	0.00	
6	Dup		"	"	"	0.00	
7	R1-C2-SR		"	"	"	0.00	
8	Dup		"	"	"	0.00	
9	R2-C2-SR		"	"	"	0.00	
10	Dup		"	"	"	0.00	
11	R3-C2-SR		"	"	"	0.00	
12	Dup		"	"	"	0.00	
13	R8-C2-SR		"	"	"	0.00	
14	Dup		"	"	"	0.00	
15							
16							
17							
18							
19							
20							
21							

1754  
1752  
1753  
1754  
1751

DF = Dilution Factor

Comments \* 0.01N Sulfuric Acid Lot# K610D98 Exp. Sept. 2019 - Ricca

**APPENDIX E4**

**O<sub>2</sub>/CO<sub>2</sub> RESULTS – FIELD & LABORATORY DATA**

**LABORATORY REPORT**  
Carbon Dioxide & Oxygen by TCD  
by Modified SCAQMD Method 25.3 (TCA/FID)

Client: AQMD  
Project No.: c10562  
Unit Tested: Facility A  
Sampling Date: 23-May-19  
Analyzed Date: 29-May-19  
Lab No.: A 053

Client Sample ID	Lab ID	Almega Sample ID	CO <sub>2</sub> % v/v by TCD	O <sub>2</sub> % v/v by TCD
		Tank		
<b>Facility A</b>				
Tnk18 - Inlet (I) - R3	A 053 - 07	18	ND	20.2
Tnk5 - Inlet (O) - R3	A 053 - 08	5	ND	19.9
Tnk6 - Outlet - R3	A 053 - 09	6	ND	12.1
Detection Limit			0.3	0.3

Outlet-R3 Error values, not used

\* NOTE - the BIAS FACTOR (of 1.086) is NOT applied in these results.

ND=Not Detected

TGMNEO concentration values are reported in ppm (v/v) as Methane (carbon#1).

The sample cylinder is analyzed for NMNEO, CO, CH<sub>4</sub>, CO<sub>2</sub> and C<sub>2</sub>H<sub>6</sub>. It is then directed to a separation column where all heavy organics (C<sub>3</sub>+) separate from the light organics (CO, CO<sub>2</sub>, CH<sub>4</sub> and C<sub>2</sub>H<sub>6</sub>). The light organics are then passed through a reduction catalyst to convert CO and CO<sub>2</sub> to CH<sub>4</sub>, and are then directed to a FID for detection and quantification. The heavy organics are backflushed off the holding column, passed through an oxidation catalyst, which convert all organics to CO<sub>2</sub>, then through a reduction catalyst to convert CO<sub>2</sub> to CH<sub>4</sub> and then to a FID for detection and quantification.

Reviewed by: 

## CALCULATIONS



**Client:** AQMD  
**Project No.:** c10562  
**Unit Tested:** Facility A  
**Sampling Date:** 23-May-19  
**Date tested:** 29-May-19

Lab No.: A 053

Parameter	Symbol	Units	Run #1 Tnk18 - Inlet (I) - R3 A 053 - 07	Run #2 Tnk5 - Inlet (O) - R3 A 053 - 08
Sample ID				
Lab ID				
<u>Sample Tank</u>				
Tank No			18	5
Sample Tank Volume	$V_T$	L	12.001	12.090
Barometric Pressure	$P_b$	mm Hg	763	763
Pre-test Pressure	$P_{TI}$	mm Hg (abs)	2.00	2.00
Pre-test Temperature	$t_{TI}$	°C	21	21
Abs. Pre-test Temperature	$T_{TI}$	°K	294	294
Post-test Pressure	$P_{TS}$	mm Hg (abs)	530	572
Post-test Temperature	$t_{TS}$	°C	21	21
Abs. Post-test Temperature	$c$	°K	294	294
Final Pressure	$P_{TF}$	mm Hg (abs)	930	926
Abs. Final Temperature	$T_{TF}$	°K	293	293
Dilution Factor	$DF_T$		1.77	1.63
Sample Volume	$V_s$	L	8.188	8.905

**Calculations**

$$V_s = k_1 \cdot V_T \cdot (P_{TS}/T_{TS} - P_{TF}/T_{TF})$$

$$k_1 = (273 + 15.56) / 760 = 0.3799$$

$$C_{SAT} = DF \cdot C_{SA}$$

$$C_{COT} = DF \cdot C_{CO}$$

$$DF = (P_{TF}/T_{TF}) / (P_{TS}/T_{TS} - P_{TF}/T_{TF})$$

## CALCULATIONS

Client:	AQMD	Lab No.:
Project No.:	c10562	A 053
Unit Tested:	Facility A	
Sampling Date:	23-May-19	
Date tested:	29-May-19	

Parameter	Symbol	Units	Run #3
Sample ID			Tnk6 - Outlet - R3
Lab ID			A 053 - 09
<u>Sample Tank</u>			
Tank No			6
Sample Tank Volume	$V_T$	L	12.305
Barometric Pressure	$P_b$	mm Hg	763
Pre-test Pressure	$P_{T1}$	mm Hg (abs)	2.00
Pre-test Temperature	$t_{T1}$	°C	21
Abs. Pre-test Temperature	$T_{T1}$	°K	294
Post-test Pressure	$P_{TS}$	mm Hg (abs)	96
Post-test Temperature	$t_{TS}$	°C	21
Abs. Post-test Temperature	$T_{TS}$	°K	294
Final Pressure	$P_{TF}$	mm Hg (abs)	932
Abs. Final Temperature	$T_{TF}$	°K	293
Dilution Factor	$DF_T$		9.95

Sample Volume	$V_s$	L	1.495
---------------	-------	---	-------

### Calculations

$$V_s = k_1 * V_T * (P_{TS}/T_{TS} - P_{T1}/T_{T1})$$

$$k_1 = (273 + 15.56) / 760 = 0.3799$$

$$C_{SAT} = DF * C_{SA}$$

$$C_{COT} = DF * C_{CO}$$

$$DF = (P_{TF}/T_{TF}) / (P_{TS}/T_{TS} - P_{T1}/T_{T1})$$



QA/QC SUMMARY  
(Repeat Analysis)



Client Project No.: c10562  
 Sampling Date: 23-May-19  
 Run #1

Lab No.: A 053  
 Analyzed Date: 29-May-19

Analyte	Sample ID	Area Count #1	Area Count #2	Area % diff (±20%)	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
---------	-----------	---------------	---------------	--------------------	----------	----------	---------------	------------------

Tank Analysis

CO2*	A 053 - 07	ND	ND	ND	ND	ND	ND	ND
O2*	A 053 - 07	2218932	2220944	-0.09	11.4	11.4	11.4	-0.09

Run #2

Analyte	Sample ID	Area Count #1	Area Count #2	Area Count #3	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
---------	-----------	---------------	---------------	---------------	----------	----------	---------------	------------------

Tank Analysis

CO2*	A 053 - 08	ND	ND	ND	ND	ND	ND	ND
O2 *	A 053 - 08	2379775	2369627	0.43	12.3	12.2	12.2	0.43

\* - by GC/TCD

$$\text{Conc}_{\text{CO}} \text{ in tank} = \text{MeanConc}_{\text{CO}} \cdot \text{DF}$$

$$\text{Conc}_{\text{CO}_2} \text{ in tank} = \text{MeanConc}_{\text{CO}_2} \cdot \text{DF}$$

$$\text{Conc}_{\text{O}_2} \text{ in tank} = \text{MeanConc}_{\text{O}_2} \cdot \text{DF}$$





Standard Receipt  
Sample LOG in Checklist

Project No: c10562  
~~61870~~

Method: M10.1

Lab ID: A053

Sampling Date: 5/21, 5/22, 5/23

Location: AQMD - A Int: \_\_\_\_\_

Date & Time Rc'd: 5/22/9 9:02  
5/23/9 8:42 5/24/9 8:15

Location: LAB Int: DW

Arrived By: (circle) FedEx UPS Drop Off (Int) DS Other \_\_\_\_\_

Condition of Package(s): (comment): OK // Package Type: Box Cooler Other: /

Number of Sample Container(s): 3, 3, 3, 9 Correct Containers (per Method): (Y) N //

Preservation: (circle) ICE DryICE ICEPacks (None) //

Sample Conditions:

Sample Temp (C): 21 //

Ambient Temp (C): 21 //

Sample Temp (C): \_\_\_\_\_

Filter Condition: OK

PH: \_\_\_\_\_

Components Sealed: (Y) N //

Sample Recovery Completed On: (date & time) \_\_\_\_\_

Recovered In: (circle) (Field) Lab Other // Silica Gel Condition: \_\_\_\_\_

Tedlar Bags -


Condensation: Y N

Comments:

Container(s) Requested: Glass \_\_\_\_\_ Plastic \_\_\_\_\_

Additional Comments:

**CHROMATOGRAM  
TEST SAMPLES**




A053  
-07

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 204

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.92	8232470			35.4617	
2	13.882	2234336			9.6245	
3	15.684	12748326	V		54.9139	
TOTAL		23215130			100	



A053  
-07  
lyp

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 205


FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.929	8213154			35.2316	
2	13.818	2257186			9.6825	
3	15.704	12841576	V		55.0859	
TOTAL		23311914			100	

073

223-02037-01

17




A053  
-08

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 206  
FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.935	8255851			35.3486	
2	13.828	2598140			11.1243	
3	15.732	12501518	V		53.5271	
TOTAL		23355508			100	



A053  
-08  
040

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 207  
FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.922	8256490			35.437	
2	13.784	2575298			11.0532	
3	15.681	12467265	V		53.5097	
TOTAL		23299052			100	



3 947  
**Almega**  
 ENVIRONMENTAL  
 15.607

*AS3*  
*-09*

074  
 223-02037-01  
 170615  
 ⊕ Standard


CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
 SAMPLE NO 0  
 REPORT NO 208

FILE 0  
 METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.947	8020342			35.0678	
2	13.822	421778			1.8442	
3	15.607	14428865	Y		63.0881	
TOTAL		22870984			100	



*AS3*  
*-09*  
*dy*

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC


CHANNEL NO 1  
 SAMPLE NO 0  
 REPORT NO 209

FILE 0  
 METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.942	7996030			35.3035	
2	13.758	415744			1.8356	
3	15.526	14237596	Y		62.8609	
TOTAL		22649368			100	

QAQC






CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
 SAMPLE NO 0  
 REPORT NO 198

FILE 0  
 METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.941	8343072			35.1993	
2	13.984	3912339			16.5061	
3	15.913	11446985	V		48.2946	
TOTAL		23702396			100	




CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
 SAMPLE NO 0  
 REPORT NO 199

FILE 0  
 METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.948	8409960			35.213	
2	13.879	3932295			16.4648	
3	15.873	11540828	V		48.3222	
TOTAL		23883082			100	




223-02037-01  
170615  
⊕ Shimadzu

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1 FILE 0  
SAMPLE NO 0 METHOD 41  
REPORT NO 200

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.892	6547774			29.3922	
2	4.409	952775	V		4.2769	
3	6.086	816942			3.6672	
4	13.849	777322			3.4893	
5	15.886	18445339	V		46.888	
6	25.195	952478			4.2756	
7	27.797	1784598	V		8.0109	
TOTAL		22277224			100	




CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1 FILE 0  
SAMPLE NO 0 METHOD 41  
REPORT NO 201

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.889	6502749			29.1142	
2	4.405	954814	V		4.2749	
3	6.081	821659			3.6787	
4	13.802	775800			3.4738	
5	15.834	10525073	V		47.123	
6	25.142	959386	V		4.2954	
7	27.821	1795744	V		8.0399	
TOTAL		22355302			100	




CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC  
 CHANNEL NO 1  
 SAMPLE NO 0  
 REPORT NO 254

FILE 0  
 METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.87	6544913			29.6233	
2	4.384	958693	V		4.3392	
3	6.056	828544			3.7501	
4	13.774	768741			3.4794	
5	15.798	10277015	V		46.5154	
6	25.04	951905	V		4.3085	
7	27.622	1763976	V		7.984	
TOTAL		22093780			100	

60



CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 202

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.935	8918973			34.7446	
2	7.988	2220694			8.6587	
3	15.622	14515404			56.5967	
TOTAL		25647072			100	



CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1  
SAMPLE NO 0  
REPORT NO 203

FILE 0  
METHOD 41

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.933	8895068			34.9909	
2	7.985	2204612			8.6724	
3	15.543	14321374			56.3367	
TOTAL		25421052			100	

20e

072

223-02037-01

170615

⊕ Shimadzu

7.969 He

15.523

2% He

Skimmed

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1

FILE 0

SAMPLE NO 0

METHOD 41

REPORT NO 253

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.916	8930439			35.1677	
2	7.969	2199025			8.6597	
3	15.523	14264424			56.1727	
TOTAL		25393888			100	

## TANK PREPARATION

### TANK PREPARATIONS

Client: AQMD Lab No.: A 053  
 Project No.: c10562  
 Unit Tested: Facility A  
 Sampling Date: 23-May-19  
 Date pressurized: 24-May-19

Tank ID	Sample ID	Pre-test pressure mm Hg		Post-test pressure mm Hg	Final Pressure	Comments
		1	2			
18	A 053 - 07	-758	-758	-230	170	Run #1
5	A 053 - 08	-758	-758	-188 *	166	Run #2
6	A 053 - 09	-758	-758	-664	172	Run #3

\* - Post -test Pressure is less then 200 mm Hg.



VOC FIELD DATA SHEET - SCAQMD METHOD 25.1 10.1

Date: 05/23/19 Test No.: 3  
 Client: Facility A Barometric Pressure (in. Hg): 29.80  
 Unit: Inlet no. 1 Pretest Leak Check: \_\_\_\_\_  
 Operator Name: T.TA A:  B: \_\_\_\_\_  
 Fuel: \_\_\_\_\_ Post-test Leak check: \_\_\_\_\_  
 Location: Inside A:  B: \_\_\_\_\_

SAMPLE A

SAMPLE B

Time		Tank # <u>18</u>	Trap # <u>NA</u>
24 Hours	Start Time	Control ID:	
		Flow ml/min.	Vacuum inch Hg
0	0829	2.10	28.50
10	0839		25.50
20	0849		21.50
30	0859		18.0
40	0909		15.0
50	0919 End Time		12.0
60	0929		8.50

Time		Tank # _____	Trap # _____
24 Hours	Start Time	Control ID:	
		Flow ml/min.	Vacuum inch Hg





**APPENDIX F**  
**COLLECTION/CAPTURE EFFICIENCY TEST**

**From:** Charles Figueroa <Charles@almegaenv.com>  
**Sent:** Monday, July 01, 2019 3:15 PM  
**To:** Tulasi@almegaenv.com  
**Subject:** FW: Facility A Capture Efficiency  
**Attachments:** IMG\_0097.JPG; IMG\_0102.JPG; IMG\_0105.JPG

Capture documentation

**From:** Brian Speaks <gspeaks@aqmd.gov>  
**Sent:** Thursday, May 23, 2019 11:55 AM  
**To:** Charles Figueroa <Charles@almegaenv.com>; 'Neal' <neal@almegaenv.com>  
**Cc:** Bill Welch <bwelch@aqmd.gov>  
**Subject:** Facility A Capture Efficiency

Charles,


As previously discussed we verified the capture efficiency of the control system for the electric furnace at Facility A currently undergoing testing.


Measured velocities around the perimeter of the furnace lid with the furnace off were between 1360 – 1937 feet per minute with a lid opening of roughly 1-3". Velocities with the furnace off were between 511-600 feet per minute with a lid opening of roughly 4-6".


A smoke test was performed while the furnace was in full operation with a lid opening of 1-3" which was the typical operating position for normal periods. The lid was observed to be open more than this for short periods while the furnace was being de-slugged (2-4 minutes on average), for periods when charged with large scrap (less than 10 minutes), or when charge with finer material (1-2 minutes on average).

A few pictures have been included for reference, a video of the smoke test was also recorded but I am unable to send as it exceeds our email file size limits. Did you guys end up having to postpone testing today for the last 2 runs due to rain?

Thanks,  
G. Brian Speaks  
Air Quality Engineer  
[gspeaks@aqmd.gov](mailto:gspeaks@aqmd.gov)  
909.396.3212







**APPENDIX G**  
**QUALITY ASSURANCE AND QUALITY CONTROL (QA/QC)**

**APPENDIX G1**  
**TEST EQUIPMENT CALIBRATION DATA**













**TYPE S PITOT TUBE SEMIANNUAL INSPECTION SHEET**

CAL DATE: 1/4/2019

NEXT DUE DATE: 7/6/2019

PITOT ID: 47

	Degree indicating level position for determining $\alpha_1$ and $\alpha_2$		<b>Parameter</b>	<b>Values</b>	<b>Allowable Range</b>
	Degree indicating level position for determining $\beta_1$ and $\beta_2$		Level and Perpendicular?	Yes OR No	Yes
	Degree indicating level position for determining $\theta$		Obstruction?	Yes OR No	No
	Degree indicating level position for determining $\gamma$		Damaged?	Yes OR No	No
	Degree indicating level position for determining $z$		$\alpha_1$	0	$-10^\circ \leq \alpha_1 \leq +10^\circ$
			$\alpha_2$	0	$-10^\circ \leq \alpha_2 \leq +10^\circ$
			$\beta_1$	2	$-5^\circ \leq \beta_1 \leq +5^\circ$
			$\beta_2$	1	$-5^\circ \leq \beta_2 \leq +5^\circ$
			$\gamma$	-2	NA
			$\theta$	1	NA
			$Z = A (\tan \gamma)$	0.012	$\leq 0.125$ in.
			$W = A (\tan \theta)$	0.016	$\leq 0.031$ in.
			Dt	0.364	$0.188 \leq Dt \leq 0.375$
			A	0.925	NA
			$A/2(Dt)$	1.28	$1.05 \leq PA/Dt \leq 1.5$

**Certification:**

I certify that this pitot tube meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor Cp of 0.84.

Certified By: James Odulio  Date: 1/4/2019

### TYPE S PITOT TUBE SEMIANNUAL INSPECTION SHEET

CAL DATE: 1/4/2019

NEXT DUE DATE: 7/5/2019

PITOT ID: 16

Parameter	Values	Allowable Range
Level and Perpendicular?	Yes OR No	Yes
Obstruction?	Yes OR No	No
Damaged?	Yes OR No	No
$\alpha 1$	1	$-10^\circ \leq \alpha 1 \leq +10^\circ$
$\alpha 2$	-1	$-10^\circ \leq \alpha 2 \leq +10^\circ$
$\beta 1$	-1	$-5^\circ \leq \beta 1 \leq +5^\circ$
$\beta 2$	-3	$-5^\circ \leq \beta 2 \leq +5^\circ$
$\gamma$	-1	NA
$\theta$	-1	NA
$Z = A (\tan \gamma)$	-0.019	$\leq 0.125$ in.
$W = A (\tan \theta)$	-0.019	$\leq 0.031$ in.
Dt	0.37	$0.188 \leq Dt \leq 0.375$
A	1.113	NA
$A/2(D0)$	1.59	$1.05 \leq PA/Dt \leq 1.5$

**Certification:**

I certify that this pitot tube meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor Cp of 0.84.

Certified By: Morgan Nguyen  Date: 1/4/2019

### TYPE S PITOT TUBE SEMIANNUAL INSPECTION SHEET

CAL DATE: 1/4/2019

NEXT DUE DATE: 7-5-2019

PITOT ID: 34

Parameter	Values	Allowable Range
Level and Perpendicular?	Yes OR No	Yes
Obstruction?	Yes OR No	No
Damaged?	Yes OR No	No
$\alpha_1$	-4	$-10^\circ \leq \alpha_1 \leq +10^\circ$
$\alpha_2$	-1	$-10^\circ \leq \alpha_2 \leq +10^\circ$
$\beta_1$	-1	$-5^\circ \leq \beta_1 \leq +5^\circ$
$\beta_2$	-1	$-5^\circ \leq \beta_2 \leq +5^\circ$
$\gamma$	1	NA
$\theta$	-1	NA
$Z = A (\tan \gamma)$	0.016	$\leq 0.125$ in.
$W = A (\tan \theta)$	-0.016	$\leq 0.031$ in.
Dt	0.372	$0.188 \leq Dt \leq 0.375$
A	0.933	NA
$A/(D_0)$	1.75	$1.05 \leq PA/Dt \leq 1.5$

**Certification:**

I certify that this pitot tube meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor Cp of 0.84.

Certified By: James Odalio  Date: 1/4/2019

### TYPE S PITOT TUBE SEMIANNUAL INSPECTION SHEET

CAL DATE: 1/4/2019

NEXT DUE DATE: 7/5/2019

PITOT ID: 31

Parameter	Values	Allowable Range
Level and Perpendicular?	Yes OR No	Yes
Obstruction?	Yes OR No	No
Damaged?	Yes OR No	No
$\alpha 1$	-3	$-10^{\circ} \leq \alpha 1 \leq +10^{\circ}$
$\alpha 2$	-3	$-10^{\circ} \leq \alpha 2 \leq +10^{\circ}$
$\beta 1$	-2	$-5^{\circ} \leq \beta 1 \leq +5^{\circ}$
$\beta 2$	-2	$-5^{\circ} \leq \beta 2 \leq +5^{\circ}$
$\gamma$	-3	NA
$\theta$	0	NA
$Z = A (\tan \gamma)$	-0.042	$\leq 0.125$ in.
$W = A (\tan \theta)$	0.0001	$\leq 0.031$ in.
Dt	0.369	$0.188 \leq Dt \leq 0.375$
A	0.943	NA
$A/2(Dt)$	1.28	$1.05 \leq PA/Dt \leq 1.5$

**Certification:**

I certify that this pitot tube meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor Cp of 0.84.

Certified By: James Odulio  Date: 1/4/2019

### TYPE S PITOT TUBE SEMIANNUAL INSPECTION SHEET

CAL DATE: 1/4/2019

NEXT DUE DATE: 7/5/2019

PITOT ID: 85

Parameter	Values	Allowable Range
Level and Perpendicular?	Yes OR No	Yes
Obstruction?	Yes OR No	No
Damaged?	Yes OR No	No
$\alpha 1$	-1	$-10^\circ \leq \alpha 1 \leq +10^\circ$
$\alpha 2$	-2	$-10^\circ \leq \alpha 2 \leq +10^\circ$
$\beta 1$	4	$-5^\circ \leq \beta 1 \leq +5^\circ$
$\beta 2$	5	$-5^\circ \leq \beta 2 \leq +5^\circ$
$\gamma$	-3	NA
$\theta$	1	NA
$Z = A (\tan \gamma)$	-0.047	$\leq 0.125$ in.
$W = A (\tan \theta)$	0.016	$\leq 0.031$ in.
$Dt$	0.37	$0.188 \leq Dt \leq 0.375$
$A$	0.899	NA
$A2/(Dt)$	1.21	$1.05 \leq PA/Dt \leq 1.5$

**Certification:**

I certify that this pitot tube meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor  $C_p$  of 0.84.

Certified By: Morgan Nguyen  Date: 1/4/2019

### TYPE S PITOT TUBE SEMIANNUAL INSPECTION SHEET

CAL DATE: 01-04-2019  
 NEXT DUE DATE: 7-5-2019  
 PITOT ID: 28

Parameter	Values	Allowable Range
Level and Perpendicular?	Yes OR No	<u>Yes</u>
Obstruction?	Yes OR No	<u>No</u>
Damaged?	Yes OR No	<u>No</u>
$\alpha 1$	<u>4</u>	$-10^\circ \leq \alpha 1 \leq +10^\circ$
$\alpha 2$	<u>3</u>	$-10^\circ \leq \alpha 2 \leq +10^\circ$
$\beta 1$	<u>0</u>	$-5^\circ \leq \beta 1 \leq +5^\circ$
$\beta 2$	<u>0</u>	$-5^\circ \leq \beta 2 \leq +5^\circ$
$\gamma$	<u>1</u>	NA
$\theta$	<u>1</u>	NA
$Z = A (\tan \gamma)$	<u>0.000</u>	$\leq 0.125$ in.
$W = A (\tan \theta)$	<u>0.000</u>	$\leq 0.031$ in.
Dt	<u>0.369</u>	$0.188 \leq Dt \leq 0.375$
A	<u>0.928</u>	NA
$A/(Dt)$	<u>#DIV/0!</u>	$1.05 \leq P A/Dt \leq 1.5$

**Certification:**

I certify that this pitot tube meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor Cp of 0.84.

Certified By: Morgan Nguyen Date: 01-04-19



**ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES**  
 10802 WALKER STREET  
 CYPRESS, CA 90630

**STACK TEMPERATURE SENSOR SEMI-ANNUAL CALIBRATION**

TEMPERATURE SENSOR I.D:	16	REF. DIGITAL NIST TRACEABLE THERMOMETEI: 1, 2 & 3
READ OUT I.D:	VA710	ICE BATH: YES
PITOT TUBE I.D:	16	BOILING WATER: YES
PITOT TUBE LENGTH:	100"	HOT OIL: YES
DATE:	1/3/2019	CALIBRATED BY: JOMN <i>JOHN</i>

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
23NU22				
Due Date				
12/28/2019				
	32.5	32.4	0.1	0.3
	32.3	32.3	0.0	0.0
	32.4	32.5	0.1	0.3

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
160784579				
Due Date				
11/13/2019				
	215.2	215.0	0.2	0.1
	215.0	215.8	0.8	0.3
	215.0	214.1	0.9	0.4

HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
160784568				
Due Date				
11/13/2019				
	515.3	515.0	0.3	0.1
	514.2	516.1	1.9	0.4
	516.3	518.3	2.0	0.4

**NOTE:**  
 MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
 TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
 REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
 REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)



**ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES**  
 10602 WALKER STREET  
 CYPRESS, CA 90630

**STACK TEMPERATURE SENSOR SEMI-ANNUAL CALIBRATION**

TEMPERATURE SENSOR I.D.:	28	REF. DIGITAL NIST TRACEABLE THERMOMETE: 1, 2 & 3
READ OUT I.D.:	VA710	ICE BATH: YES
PITOT TUBE I.D.:	28	BOILING WATER: YES
PITOT TUBE LENGTH:	37"	HOT OIL: YES
DATE:	1/3/2019	CALIBRATED BY: JOMN <i>Matt</i>

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
23NU22				
Due Date				
12/28/2019				
	31.5	31.7	0.2	0.6
	31.5	31.8	0.3	1.0
	31.6	31.3	0.3	0.9

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
160764579				
Due Date				
11/13/2019				
	215.1	214.8	0.3	0.1
	215.0	213.1	1.9	0.9
	215.0	214.2	0.8	0.4

HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
160764588				
Due Date				
11/13/2019				
	520.0	520.1	0.1	0.0
	523.1	524.6	1.5	0.3
	522.8	520.1	2.5	0.5

**NOTE:**  
 MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
 TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
 REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
 REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)



**ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES**  
10602 WALKER STREET  
CYPRESS, CA 90630

**STACK TEMPERATURE SENSOR SEMI-ANNUAL CALIBRATION**

TEMPERATURE SENSOR I.D.:	31	REF. DIGITAL NIST TRACEABLE THERMOMETER: 1, 2 & 3
READ OUT I.D.:	VA710	ICE BATH: YES
PITOT TUBE I.D.:	31	BOILING WATER: YES
PITOT TUBE LENGTH:	49"	HOT OIL: YES
DATE:	1/2/2019	CALIBRATED BY: JO/MN <i>WJ</i>

ICE BATH				
S/N: 23NU22 Due Date 12/28/2019	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
	31.8	31.8	0.2	0.6
	31.9	31.6	0.3	0.9
	31.8	31.6	0.2	0.6

BOILING WATER				
S/N: 180764579 Due Date 11/13/2019	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
	215.2	215.1	0.1	0.0
	215.0	215.2	0.2	0.1
	215.0	214.8	0.2	0.1

HOT OIL				
S/N: 160764568 Due Date 11/13/2019	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
	500.3	497.3	3.0	0.6
	502.7	503.9	1.2	0.2
	504.6	507.3	2.7	0.5

**NOTE:**  
MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)



ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES  
 10602 WALKER STREET  
 CYPRESS, CA 90630

STACK TEMPERATURE SENSOR SEM-ANNUAL CALIBRATION

TEMPERATURE SENSOR I.D.:	34	REF. DIGITAL NIST TRACEABLE THERMOMETER: 1, 2 & 3
READ OUT I.D.:	VA710	ICE BATH: YES
PITOT TUBE I.D.:	34	BOILING WATER: YES
PITOT TUBE LENGTH:	49"	HOT OIL: YES
DATE:	1/3/2019	CALIBRATED BY: JOHN <i>Woj</i>

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
23NU22				
Due Date				
12/28/2019				
	31.6	31.4	0.2	0.6
	31.8	32.0	0.2	0.6
	31.7	31.9	0.2	0.6

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
160784579				
Due Date				
11/13/2019				
	215.1	214.9	0.2	0.1
	215.0	214.2	0.8	0.4
	215.0	215.4	0.4	0.2

HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
160784568				
Due Date				
11/13/2019				
	524.8	524.9	0.1	0.0
	526.1	527.4	1.3	0.2
	525.6	526.3	0.7	0.1


**NOTE:**  
 MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
 TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
 REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
 REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)



**ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES**  
**10602 WALKER STREET**  
**CYPRESS, CA 90630**

**STACK TEMPERATURE SENSOR SEMI-ANNUAL CALIBRATION**

TEMPERATURE SENSOR I.D.:	47	REF. DIGITAL NIST TRACEABLE THERMOMETEI: 1, 2 & 3
READ OUT I.D.:	VA710	ICE BATH: YES
PITOT TUBE I.D.:	47	BOILING WATER: YES
PITOT TUBE LENGTH:	88"	HOT OIL: YES
DATE:	1/3/2019	CALIBRATED BY: JO/MN 

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
23NU22				
Due Date				
12/28/2019				
	31.5	31.2	0.3	1.0
	31.5	31.4	0.1	0.3
	31.6	31.9	0.3	0.8

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
160764579				
Due Date				
11/13/2019				
	215.0	215.1	0.1	0.0
	215.0	215.0	0.0	0.0
	215.0	214.3	0.7	0.3

HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
160764568				
Due Date				
11/13/2019				
	521.9	521.8	0.1	0.0
	520.3	520.9	0.6	0.1
	522.6	523.9	1.3	0.2


**NOTE:**  
 MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
 TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
 REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
 REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)



**ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES**  
 10602 WALKER STREET  
 CYPRESS, CA 90630

**STACK TEMPERATURE SENSOR SEMI-ANNUAL CALIBRATION**

TEMPERATURE SENSOR I.D.:	85	REF. DIGITAL NIST TRACEABLE THERMOMETER: 1, 2 & 3
READ OUT I.D.:	VA710	ICE BATH: YES
PITOT TUBE I.D.:	85	BOILING WATER: YES
PITOT TUBE LENGTH:	37"	HOT OIL: YES
DATE:	1/2/2019	CALIBRATED BY: JO/MN 

ICE BATH				
S/N: 23NU22 Due Date 12/28/2019	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
	31.7	31.5	0.2	0.6
	31.8	32.1	0.3	0.9
	31.8	31.5	0.3	0.9

BOILING WATER				
S/N: 180764579 Due Date 11/13/2019	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
	215.2	216.7	1.5	0.7
	215.0	214.2	0.8	0.4
	215.0	214.8	0.2	0.1


HOT OIL				
S/N: 160764568 Due Date 11/13/2019	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	DIFFERENCE (%)
	493.8	490.9	2.9	0.6
	494.4	491.2	3.2	0.6
	494.9	493.1	1.8	0.4

**NOTE:**  
 MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
 TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
 REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
 REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)

ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES  
10602 WALKER STREET  
CYPRESS, CA 90630

STACK TEMPERATURE SENSOR BI-MONTHLY CALIBRATION

TEMPERATURE SENSOR I.D.:	47	REF. DIGITAL NIST TRACEABLE THERMOMETER ID: 1, 2 & 3
READ OUT I.D.:	VA-710	ICE BATH YES
PITOT TUBE I.D.:	47	BOILING WATER: YES
PITOT TUBE LENGTH:	88"	HOT OIL: YES
DATE:	4/26/2019	CALIBRATED BY: EOJO 

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764570				
Due Date				
11/13/2019	32.2	32.1	0.1	0.3

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764579				
Due Date				
11/13/2019	212.0	212.0	0.0	0.0

HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764557				
Due Date				
11/13/2019	485.0	487.0	2.0	0.4


**NOTE:**  
MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)



ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES  
 10602 WALKER STREET  
 CYPRESS, CA 90630

STACK TEMPERATURE SENSOR BI-MONTHLY CALIBRATION

TEMPERATURE SENSOR I.D.:	85	REF. DIGITAL NIST TRACEABLE THERMOMETER ID: 1, 2 & 3
READ OUT I.D.:	VA-710	ICE BATH YES
PITOT TUBE I.D.:	85	BOILING WATER: YES
PITOT TUBE LENGTH:	37"	HOT OIL: YES
DATE:	4/26/2019	CALIBRATED BY: JO/LB 

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
180764570				
Due Date				
11/13/2019	35.1	35.3	0.2	0.6

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
180764579				
Due Date				
11/13/2019	212.1	211.9	0.2	0.1

HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
180764557				
Due Date				
11/13/2019	511.6	513.3	1.7	0.3

NOTE:  
 MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
 TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
 REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
 REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)



ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES  
10602 WALKER STREET  
CYPRESS, CA 90630

STACK TEMPERATURE SENSOR BI-MONTHLY CALIBRATION

TEMPERATURE SENSOR I.D.:	28	REF. DIGITAL NIST TRACEABLE THERMOMETER ID: 1, 2 & 3
READ OUT I.D.:	VA-710	ICE BATH YES
PITOT TUBE I.D.:	28	BOILING WATER: YES
PITOT TUBE LENGTH:	37"	HOT OIL: YES
DATE:	4/28/2019	CALIBRATED BY: JO/LB

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764570	34.9	34.8	0.1	0.3
Due Date	11/13/2019			

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764579	211.7	212.1	0.4	0.2
Due Date	11/13/2019			


HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764557	510.9	512.7	1.8	0.4
Due Date	11/13/2019			

**NOTE:**  
MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)

ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES  
10602 WALKER STREET  
CYPRESS, CA 90630

STACK TEMPERATURE SENSOR BI-MONTHLY CALIBRATION

TEMPERATURE SENSOR I.D.:	16	REF. DIGITAL NIST TRACEABLE THERMOMETER ID: 1, 2 & 3
READ OUT I.D.:	VA-710	ICE BATH YES
PITOT TUBE I.D.:	16	BOILING WATER: YES
PITOT TUBE LENGTH:	100"	HOT OIL: YES
DATE:	4/26/2019	CALIBRATED BY: EO/JO 

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764570				
Due Date				
11/13/2019				
	31.2	31.3	0.1	0.3

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764579				
Due Date				
11/13/2019				
	212.0	213.0	1.0	0.5

HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764557				
Due Date				
11/13/2019				
	462.0	467.0	5.0	1.1

**NOTE:**  
MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)



ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES  
10602 WALKER STREET  
CYPRESS, CA 90630

STACK TEMPERATURE SENSOR BI-MONTHLY CALIBRATION

TEMPERATURE SENSOR I.D.:	34	REF. DIGITAL NIST TRACEABLE THERMOMETER ID: 1, 2 & 3
READ OUT I.D.:	VA-710	ICE BATH YES
PITOT TUBE I.D.:	34	BOILING WATER: YES
PITOT TUBE LENGTH:	49"	HOT OIL: YES
DATE:	4/28/2019	CALIBRATED BY: EOWB <i>EO</i>

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764570				
Due Date				
11/13/2019	32.2	32.3	0.1	0.3

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764579				
Due Date				
11/13/2019	213.1	212.8	0.3	0.1

HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764557				
Due Date				
11/13/2019	486.0	488.0	2.0	0.4

**NOTE:**  
MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)



ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES  
10602 WALKER STREET  
CYPRESS, CA 90630

STACK TEMPERATURE SENSOR BI-MONTHLY CALIBRATION

TEMPERATURE SENSOR I.D.:	31	REF. DIGITAL NIST TRACEABLE THERMOMETER ID: 1, 2 & 3
READ OUT I.D.:	VA-710	ICE BATH YES
PITOT TUBE I.D.:	31	BOILING WATER: YES
PITOT TUBE LENGTH:	37"	HOT OIL: YES
DATE:	4/26/2019	CALIBRATED BY: EO/WB <i>EO</i>

ICE BATH				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764570	31.1	30.9	0.2	0.6
Due Date	11/13/2019			

BOILING WATER				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764579	212.7	214.1	1.4	0.7
Due Date	11/13/2019			

HOT OIL				
S/N:	REF. DIGITAL NIST TRACEABLE THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
160764557	468.0	471.0	3.0	0.6
Due Date	11/13/2019			

**NOTE:**  
MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.  
TAKE READING EVERY ONE MINUTE.

REF. T1 ICE BATH THERMOMETER: -58 - 572 (F)  
REF. T2 BOILING WATER THERMOMETER: -58 - 572 (F)  
REF. T3 HOT OIL THERMOMETER: -58 - 572 (F)

Semi-Annual Field Dry Gas Meter Calibration\* Calibration Date: 3/18/2019

Orifice Series: 33-73  
 Serial Number: AE/MS  
 Cell Type: Semi-Annual

Calibrated by: L. Barry  
 (signature)  
 Reviewed by:

**DRY GAS METER CALIBRATION FACTOR**  
**Y**  
**Yds = 1.0376**

**ORIFICE CALIBRATION FACTOR**  
**dH@**  
**dH@ = 1.789**

DRY GAS METER READINGS										
DGM INLET	DGM OUTLET		Meter Reading		Orifice Reading		QUALITY CONTROL CHECKS			
	Final (F)	Initial (F)	Final (cu.ft.)	Initial (cu.ft.)	Final (in.H2O)	Initial (in.H2O)	(V <sub>meas</sub> - Y <sub>meas</sub> ) < 0.010 **	0.98 < (V <sub>meas</sub> /Y <sub>meas</sub> ) < 1.02	Average Coeff (Y) (0.95 < Y < 1.05)	dH@ (in.Hg) ± 0.15
N/A	N/A	62.0	323.972	329.539	0.130	0.130	0.0033	0.985	1.022	1.776
		63.0	329.539	335.123	0.130	0.130	PASS	PASS	PASS	PASS
		64.0	335.123	340.724	0.130	0.130				
N/A	N/A	67.0	341.902	347.625	0.730	0.730	0.0004	1.003	1.044	1.662
		68.0	347.625	353.359	0.730	0.730	PASS	PASS	PASS	PASS
		69.0	353.359	359.096	0.730	0.730				
N/A	N/A	71.0	361.007	366.266	1.900	1.900	0.0019	1.006	1.046	1.754
		72.0	366.266	371.518	1.900	1.900	PASS	PASS	PASS	PASS
		73.0	371.518	376.762	1.900	1.900				
N/A	N/A	74.0	377.702	383.953	3.800	3.800	0.0036	1.001	1.030	1.908
		75.0	383.953	390.181	3.800	3.800	PASS	PASS	PASS	PASS
		76.0	390.181	396.363	3.800	3.800				
		77.0								

Orifice Series No.	Run Time (min)	CRITICAL ORIFICE				DRY GAS METER				CALCULATIONS		
		Orifice K-factor	Tested Vacuum (in.Hg)	Ambient Temp. (°F)	Flowrate (SCFM)	Corrected Volume (cu.ft.)	Orifice dH (in.H2O)	AVG Temp. (°F)	NET Volume (cu.ft.)	Flowrate (SCFM)	Corrected Volume (SCF)	Coefficient Y <sub>meas</sub> (0.95 < Y <sub>meas</sub> < 1.05)
33	28	0.1549	27.50	63.0	0.2028	5.670	0.130	62.60	5.507	0.198	5.540	1.777
33	28	0.1548	27.50	64.0	0.202	5.665	0.130	63.50	5.594	0.198	5.646	1.777
33	28	0.1549	27.50	64.0	0.202	5.665	0.130	64.50	5.601	0.198	5.653	1.773
52	12	0.3769	24.50	66.0	0.491	5.868	0.730	67.50	5.723	0.471	5.860	1.664
52	12	0.3768	24.50	66.0	0.491	5.865	0.730	68.50	5.734	0.471	5.850	1.661
52	12	0.3769	24.50	67.0	0.491	5.861	0.730	69.50	5.737	0.470	5.842	1.661
53	7	0.8106	21.00	67.0	0.767	6.370	1.900	71.50	6.229	0.734	6.136	1.662
53	7	0.8100	21.00	68.0	0.768	6.365	1.900	72.50	6.232	0.733	6.131	1.765
53	7	0.8100	21.00	68.0	0.768	6.365	1.900	73.50	6.234	0.732	6.123	1.761
73	6	0.8108	16.00	69.0	1.054	6.325	3.800	74.50	6.266	1.015	6.092	1.908
73	6	0.8108	16.00	69.0	1.054	6.325	3.800	75.50	6.223	1.016	6.097	1.904
73	6	0.8106	16.00	70.0	1.053	6.318	3.800	76.50	6.207	1.012	6.070	1.804

\* Critical Orifice used. Note: This Apert Meter Box, Console Model # XC-522-D does not have a temperature sensor at the Inlet. Hence, DGM inlet columns are intentionally left blank.

Semi-Annual Field Dry Gas Meter Calibration\* Calibration Date: 3/18/2019

Orifice Series: 33-73  
 Serial Number: AE/AE<sub>2</sub>  
 Cal Type: Semi-Annual

Calibrated by: E. Ortiz  
 (Signature)  
 Reviewed by: [Signature]

**DRY GAS METER CALIBRATION FACTOR**  
 $Y_{ds} = 1.0274$

**ORIFICE CALIBRATION FACTOR**  
 $dH@ = 1.736$

DRY GAS METER READINGS										QUALITY CONTROL CHECKS				DGM ID: A-7		
Orifice Series No	DGM INLET		DGM OUTLET		Meter Reading		Orifice Reading		$(Y_{ds}/Y_{cal}) < 1.02$	Average Coeff (Y) $(0.95 < Y < 1.05)$	dH@ $< (dH@ \pm 0.16)$	DGM ID: A-7	Serial #: 20180216	Model #: XC-622-D		
	Initial (°F)	Final (°F)	Initial (°F)	Final (°F)	Initial (scf)	Final (scf)	Initial (in H2O)	Final (in H2O)								
33	N/A	66.0	67.0	68.0	740.651	740.651	0.120	0.120	1.020	1.027	1.638	Semi-Annual: X				
33	N/A	67.0	68.0	69.0	748.229	748.229	0.120	0.120	1.020	PASS	PASS	Bi-monthly:				
33	N/A	68.0	69.0	70.0	751.829	751.829	0.120	0.120	1.020	PASS	PASS	Other:				
52	N/A	69.0	70.0	71.0	767.544	767.544	0.730	0.730	1.016	1.044	1.668	Standard				
52	N/A	70.0	71.0	72.0	767.544	767.544	0.730	0.730	1.016	PASS	PASS	Temperature (Ideals)				
52	N/A	71.0	72.0	73.0	763.274	763.274	0.730	0.730	1.016	PASS	PASS	Yield = 60				
52	N/A	72.0	73.0	74.0	769.057	769.057	0.730	0.730	1.016	1.023	1.806	Barometric				
52	N/A	73.0	74.0	75.0	774.450	774.450	1.900	1.900	0.998	PASS	PASS	Pressure (in Hg)				
52	N/A	74.0	75.0	76.0	779.778	779.778	1.900	1.900	0.998	PASS	PASS	Initial: 29.85				
52	N/A	75.0	76.0	77.0	785.145	785.145	1.900	1.900	0.998	PASS	PASS	Final: 29.85				
52	N/A	76.0	77.0	78.0	804.278	810.824	3.600	3.600	0.998	PASS	PASS	Pressure:				
52	N/A	77.0	78.0	79.0	816.951	816.951	3.600	3.600	0.998	PASS	PASS					
52	N/A	78.0	79.0	80.0	823.329	823.329	3.600	3.600	0.998	PASS	PASS					

Orifice Series No	Run Time (min)	CRITICAL ORIFICE				DRY GAS METER				CALCULATIONS		
		Orifice K-factor	Tested Vacuum (in.Hg)	Ambient Temp (°F)	Orifice dH (in.H2O)	NET Volume (scf)	AVG Temp (°F)	Flowrate Q <sub>fm</sub> (SCFM)	Flowrate Q <sub>fm</sub> (SCFM)	Volume (SCF)	Coefficient $(Y_{ds} < 1.05)$	Orifice dH@ (in.H2O)
33	26	0.1549	26.00	67.0	0.120	5.873	66.50	0.196	0.196	5.902	1.0254	1.641
33	26	0.1549	26.00	67.0	0.120	5.878	67.50	0.196	0.196	5.489	1.0274	1.638
33	26	0.1549	26.00	68.0	0.120	5.590	68.50	0.196	0.196	5.489	1.0280	1.638
52	12	0.3769	24.00	69.0	0.730	5.735	69.50	0.470	0.470	5.638	1.0425	1.668
52	12	0.3769	24.00	70.0	0.730	5.730	70.50	0.469	0.469	5.623	1.0443	1.668
52	12	0.3769	24.00	71.0	0.730	5.733	71.00	0.468	0.468	5.620	1.0438	1.668
63	7	0.5990	20.00	72.0	1.900	5.322	73.00	0.745	0.745	5.213	1.0260	1.607
63	7	0.5990	20.00	72.0	1.900	5.328	73.50	0.745	0.745	5.214	1.0248	1.606
63	7	0.5990	20.00	72.0	1.900	5.387	74.50	0.749	0.749	5.342	1.0192	1.602
73	6	0.8109	18.00	72.0	3.600	6.325	75.50	1.032	1.032	6.193	1.0181	1.513
73	6	0.8109	16.00	73.0	3.600	6.347	77.00	1.033	1.033	6.198	1.0168	1.512
73	6	0.8109	16.00	74.0	3.600	6.376	78.00	1.036	1.036	6.215	1.0128	1.512

\* Critical Orifices used. Note: This Apex Meter Box, Console Model # XC-622-D does not have a temperature sensor at the inlet. Hence, DGM inlet columns are intentionally left blank.

Semi-Annual Field Dry Gas Meter Calibration\* Calibration Date: 4/26/2019

Orifice Series: 33-73  
 Social Number: AE-14614  
 Cal Type: Semi-Annual

Calibrated by: L. BROWN  
 (signature)  
 Reviewed by: [signature]

**DRY GAS METER CALIBRATION FACTOR**  
**Y**  
**Yds = 1.0395**

**ORIFICE CALIBRATION FACTOR**  
**dH@**  
**dH@ = 1.819**

DGM INLET		DGM OUTLET		Meter Reading		Orifice Reading		QUALITY CONTROL CHECKS			
Initial (°F)	Final (°F)	Initial (cu.ft.)	Final (cu.ft.)	Initial (cu.ft.)	Final (cu.ft.)	Initial (in.H2O)	Final (in.H2O)	(Y <sub>Actual</sub> / Y <sub>Normal</sub> ) ±	Average Coeff (Y)	dH <sub>nom</sub> < (dH <sub>g</sub> )	DGM ID: A-B
N/A	N/A	67.0	67.0	369.954	369.963	0.140	0.140	0.010 ±	1.02	0.95 < (Y < 1.05)	Serial #: 1612035
		67.0	67.0	369.954	370.604	0.140	0.140				Model #: XC-622
		67.0	68.0	370.004	376.129	0.140	0.140				Calibration Interval:
		68.0	68.0	376.148	381.862	0.760	0.760				Semi-Annual
		68.0	68.0	381.862	387.576	0.760	0.760				Bi-monthly
		68.0	69.0	387.576	393.278	0.760	0.760				Other
		69.0	69.0	393.278	399.498	1.900	1.900				Standard
		69.0	69.0	399.498	403.739	1.900	1.900				Temperature (deg.F)
		69.0	70.0	403.739	408.966	1.900	1.900				Yield = 60
		70.0	70.0	410.470	416.979	3.600	3.600				Barometric
		70.0	71.0	416.979	422.871	3.600	3.600				Estimate (in.Hg)
		71.0	71.0	422.871	429.077	3.600	3.600				Initial: 29.69
											Final: 29.69
											Pressure: 29.69

Orifice Series No.	Run Time (min)	CRITICAL ORIFICE				DRY GAS METER				CALCULATIONS		
		Orifice K-factor	Tested Vacuum (in.Hg)	Ambient Temp (°F)	Flowrate Orim (SCFM)	Flowrate Orim (SCFM)	NET Volume (cu.ft.)	AVG Temp (°F)	Orifice dH (in.H2O)	Orifice dH (in.H2O)	Coefficient (0.95 < Y < 1.05)	Orifice dH (in.H2O)
33	28	0.1549	28.50	66.0	0.2021	5.660	67.00	0.146	5.529	0.195	1.0376	1.908
33	28	0.1549	28.50	66.0	0.202	5.654	67.00	0.146	5.521	0.195	1.0360	1.908
33	26	0.1549	28.50	66.0	0.202	5.654	67.50	0.140	5.525	0.195	1.0362	1.908
52	12	0.3769	23.00	66.0	0.491	5.896	68.00	0.760	5.713	0.470	1.0464	1.762
52	12	0.3769	23.00	66.0	0.491	5.896	68.00	0.760	5.713	0.470	1.0464	1.762
52	12	0.3769	23.00	67.0	0.491	5.891	68.50	0.760	5.703	0.466	1.0462	1.763
63	7	0.5900	20.50	67.0	0.767	6.370	69.00	1.900	5.220	0.736	1.0421	1.803
63	7	0.5900	20.50	67.0	0.767	6.370	69.00	1.900	5.241	0.739	1.0379	1.803
63	7	0.5900	20.50	67.0	0.767	6.370	68.50	1.900	5.227	0.736	1.0416	1.802
73	6	0.8109	18.00	68.0	1.055	6.331	70.00	3.600	6.209	1.024	1.0366	1.818
73	6	0.8109	18.00	68.0	1.055	6.331	70.50	3.600	6.192	1.020	1.0343	1.818
73	6	0.8109	18.00	68.0	1.055	6.331	71.00	3.600	6.206	1.021	1.0329	1.814

\* Critical Orifice used. Note: This Apex Meter Box, Console Model # XC-622 does not have a temperature sensor at the inlet. Hence, DGM inlet columns are intentionally left blank.

**BI-Monthly Field Dry Gas Meter Calibration\***

Calibration Date: 5/7/2018

Orifice Series: 52.63  
 Serial Number: AE/AE2  
 Cell Type: BI-Monthly

Calibrated by: WBI Bryant  
 (signature): *WBI Bryant*  
 Reviewed by: *[Signature]*

<b>SEMI TO BI CHECK</b>		<b>DRY GAS METER CALIBRATION FACTOR</b>		<b>ORIFICE CALIBRATION FACTOR</b>	
(+2% of Y)	(-2% of Y)	<b>Y</b>		<b>dH@</b>	
1.0584	1.0168	<b>Yds = 1.0433</b>		<b>dH@ = 1.774</b>	
PASS					

DRY GAS METER READINGS										QUALITY CONTROL CHECKS			DGM ID: A-8	
DGM INLET	DGM OUTLET		Meter Reading		Orifice Reading		Average Coeff. Y <sub>avg</sub>	dH@ <sub>avg</sub> < (dH@ ± 0.15)	DGM ID: A-8	Serial #: 20182568				
	Initial (F)	Final (F)	Initial (cu.ft.)	Final (cu.ft.)	Initial (in.H2O)	Final (in.H2O)								
N/A	71.0	72.0	607.271	615.094	0.750	0.750								
	72.0	73.0	613.034	618.791	0.750	0.750	1.041	1.718						
N/A	73.0	73.0	616.791	624.567	0.750	0.750	PASS	PASS						
	74.0	74.0	625.645	630.668	1.950	1.950								
	74.0	75.0	630.668	636.118	1.950	1.950	1.002	1.832						
	75.0	76.0	636.118	641.370	1.950	1.950	PASS	PASS						

CRITICAL ORIFICE										DRY GAS METER					CALCULATIONS	
Orifice Series No.	Run Time (min)	Orifice K-factor	Tested Vacuum (in.Hg)	Ambient Temp. (F)	Corrected Flowrate Q <sub>fm</sub> (SCFM)	Corrected Volume (cu.ft.)	Orifice dH (in.H2O)	AVG Temp. (F)	NET Volume (cu.ft.)	Flowrate Q <sub>fm</sub> (SCFM)	Corrected Volume (SCF)	Coefficient Y <sub>fmj</sub> (0.85 < Y <sub>fmj</sub> < 1.05)	Orifice dH@ (in.H2O)	CALCULATIONS		
														Flowrate Q <sub>fm</sub> (SCFM)	Volume (SCF)	
52	12	0.3769	24.5	70.0	0.493	5.914	0.750	5.763	0.474	5.685	1.0403	1.718				
52	12	0.3769	24.5	70.0	0.493	5.914	0.750	5.757	0.472	5.698	1.0433	1.715				
52	12	0.3769	24.5	70.0	0.493	5.914	0.750	5.776	0.473	5.682	1.0408	1.714				
63	7	0.5990	22.0	70.0	0.770	5.391	1.950	5.241	0.737	5.161	1.0448	1.832				
63	7	0.5990	22.0	71.0	0.768	5.386	1.950	5.232	0.735	5.147	1.0464	1.833				
63	7	0.5990	22.0	71.0	0.768	5.386	1.950	5.252	0.737	5.157	1.0444	1.830				

\* Critical Orifice used. Note: This Apex Meter Box, Console Model # XC-622-D does not have a temperature sensor at the inlet. Hence, DGM inlet columns are left intentionally blank.

**Bi-Monthly Field Dry Gas Meter Calibration\***

Calibration Date: 5/7/2019

Office Series: 52,63  
 Serial Number: AE/AE5  
 Cal Type: Bi-Monthly

Called by: Will Bryant  
 (signature): [Signature]  
 Reviewed by: [Signature]

<b>SEMI TO BI CHECK</b>		<b>DRY GAS METER CALIBRATION FACTOR</b> Y Y <sub>ds</sub> = 1.0430	<b>ORIFICE CALIBRATION FACTOR</b> dH@ dH@ = 1.746
(±2% of Y)	(±2% of Y)		
1.0479	1.0069		
PASS			

DRY GAS METER READINGS										QUALITY CONTROL CHECKS		
DGM INLET	DGM OUTLET	Meter Reading		Orifice Reading		Average Coeff. Y <sub>ds</sub>	dH@ <sub>avg</sub> < (dH@ ± 0.15)	0.98 < (Y <sub>actual</sub> / Y <sub>meas</sub> ) < 1.02	0.0005 < Y <sub>meas</sub> < 0.010	DGM ID: A-7		
		Initial (cu.ft.)	Final (cu.ft.)	Initial (in.H2O)	Final (in.H2O)							
N/A	73.0	237.519	243.282	0.750	0.750	1.043	1.713	1.000	0.0005	20162818		
	74.0	243.282	249.055	0.750	0.750	PASS	PASS	PASS	0.0020	Serial A Ymc: 1.0274		
	75.0	249.055	254.840	0.750	0.750					Calibration Interval: Bi-monthly: x		
N/A	76.0	255.200	260.550	1.900	1.900					Standard Temperature (dco.F)		
	77.0	260.550	265.821	1.900	1.900					Told = 60		
	78.0	265.821	271.106	1.900	1.900					Barometric Pressure (in.Hg) P <sub>bar</sub> : 30.08		

Orifice Series No.	Run Time (min)	CRITICAL ORIFICE				DRY GAS METER				CALCULATIONS	
		Orifice K-factor	Tested Vacuum (in.Hg)	Ambient Temp. (°F)	Flowrate Q <sub>fm</sub> (SCFM)	AVG Temp. (°F)	NET Volume (cu.ft.)	Flowrate Q <sub>fm</sub> (SCFM)	Volume (SCF)	Coefficient Y <sub>ds</sub> (0.95 < Y <sub>ds</sub> < 1.05)	Orifice dH@ (in.H2O)
52	12	0.3769	23.5	71.0	0.492	73.50	5.764	0.472	5.862	1.0431	1.716
52	12	0.3769	23.5	71.0	0.492	74.50	5.772	0.472	5.859	1.0435	1.713
52	12	0.3769	23.5	71.0	0.492	75.50	5.786	0.472	5.862	1.0430	1.710
53	7	0.5890	21.0	71.0	0.769	78.00	5.260	0.737	5.157	1.0439	1.782
53	7	0.5890	21.0	71.0	0.769	78.50	5.271	0.738	5.163	1.0427	1.780
53	7	0.5890	21.0	71.0	0.769	77.50	5.285	0.738	5.167	1.0419	1.777

\* Critical Orifice used. Note: This Apex Meter Box, Console Model # XC-522-D does not have a temperature sensor at the Inlet. Hence, DGM inlet columns are left intentionally blank.

NOZZLE CALIBRATION FORM

NOZZLE ID #:

CLIENT

CALIPER ID:

Husky

DATE:

05/21/19

CALIBRATOR:

T. TA

LOCATION:

Inlet Furnace


SIGNATURE:

Measured Diameter A: .156 inch

Measured Diameter B: .155 inch

Measured Diameter C: .153 inch

Average: .155 inch



Inside Diameter

Is the Nozzle Free from Nicks, Dents, or Corrosion?

Yes \_\_\_\_\_

No  \_\_\_\_\_

If "No", please describe deviations below:


Nozzle Deviations (if any):



**NOZZLE CALIBRATION FORM**

NOZZLE ID #: Inlet 1 (Inside) CLIENT: \_\_\_\_\_  
CALIPER ID: \_\_\_\_\_ DATE: 5/22/19  
CALIBRATOR: \_\_\_\_\_ LOCATION: \_\_\_\_\_  
SIGNATURE: \_\_\_\_\_

Measured Diameter A: 0.182 inch  
Measured Diameter B: 0.179 inch  
Measured Diameter C: 0.180 inch  
Average: 0.180 inch



**Inside Diameter**

**Is the Nozzle Free from Nicks, Dents, or Corrosion?**

Yes \_\_\_\_\_

No \_\_\_\_\_

If "No", please describe deviations below:

Nozzle Deviations (if any):



NOZZLE CALIBRATION FORM


NOZZLE ID #: 0.513

CLIENT: AQMD

CALIPER ID: Trailer 1

DATE: 5-21-19


CALIBRATOR: C.H

SIGNATURE: 

Measured Diameter A: 0.512 inch

Measured Diameter B: 0.513 inch

Measured Diameter C: 0.514 inch



Inside Diameter

Is the Nozzle Free from Nicks, Dents, or Corrosion?

Yes

No

If "No", please describe deviations below:

Nozzle Deviations (if any):

NOZZLE CALIBRATION FORM

NOZZLE ID #: Outlet

CLIENT:

CALIPER ID:

DATE: 9/21/19

CALIBRATOR:

LOCATION:


SIGNATURE:

Measured Diameter A: 0.528 inch

Measured Diameter B: 0.528 inch

Measured Diameter C: 0.527 inch

**Average:** 0.528 inch



Inside Diameter

Is the Nozzle Free from Nicks, Dents, or Corrosion?

Yes \_\_\_\_\_

No \_\_\_\_\_


If "No", please describe deviations below:

Nozzle Deviations (if any):

NOZZLE CALIBRATION FORM

NOZZLE ID #: Inlet 1 (outside) CLIENT: Facility A  
CALIPER ID: \_\_\_\_\_ DATE: 5/21/19  
CALIBRATOR: \_\_\_\_\_ LOCATION: Inlet 1 (outside)  
SIGNATURE: \_\_\_\_\_

Measured Diameter A: 0.155 inch  
Measured Diameter B: 0.156 inch  
Measured Diameter C: 0.154 inch  
Average: 0.155 inch



Inside Diameter

Is the Nozzle Free from Nicks, Dents, or Corrosion?

Yes \_\_\_\_\_

No \_\_\_\_\_


If "No", please describe deviations below:

Nozzle Deviations (if any):

NOZZLE CALIBRATION FORM

NOZZLE ID #: Inlet 1 (Inside) CLIENT: Facility A  
CALIPER ID: \_\_\_\_\_ DATE: 5/23  
CALIBRATOR: \_\_\_\_\_ LOCATION: \_\_\_\_\_  
SIGNATURE: \_\_\_\_\_

Measured Diameter A: 0.186 inch  
Measured Diameter B: 0.188 inch  
Measured Diameter C: 0.187 inch  
Average: 0.187 inch



Inside Diameter

Is the Nozzle Free from Nicks, Dents, or Corrosion?

Yes \_\_\_\_\_

No \_\_\_\_\_

If "No", please describe deviations below:

Nozzle Deviations (if any):

**APPENDIX H**  
**FACILITY PROCESS DATA**

**Facility Process Data**

Charge During CARB Method 436 Metals Testing				
Date	Test	Furnace #	Materials	Weight (lbs)
5/21/2019	Metals Run 1	#2 Furnace	AMS 4881	200
		#3 Furnace	AMS 4881	600
		#7 Furnace	SS316	2250
5/21/2019	Metals Run 2	#2 Furnace	AMS 4881	600
		#3 Furnace	AMS 4881	600
		#7 Furnace	SS316	2250
5/22/2019	Metals Run 2	#2 Furnace	AMS 4881	440
		#3 Furnace	AMS 4881	500
		#7 Furnace	SS316	1800

Charge During CARB Method 425 Chromium Testing				
Date	Test	Furnace #	Materials	Weight (lbs)
5/22/2019	Chromium R1	#2 Furnace	AMS 4881	600
		#3 Furnace	AMS 4881	600
		#7 Furnace	SS316	2250
5/22/2019	Chromium R2	#2 Furnace	AMS 4881	600
		#3 Furnace	AMS 4881	600
		#7 Furnace	SS316	2250
5/23/2019	Chromium R3	#2 Furnace	AMS 4881	440
		#3 Furnace	AMS 4881	500
		#7 Furnace	SS316	1800

Charge During SCAQMD Method 5.1 PM Testing				
Date	Test	Furnace #	Materials	Weight (lbs)
5/23/2019	PM Testing	#2 Furnace	AMS 4881	560
		#3 Furnace	AMS 4881	650
		#7 Furnace	SS316	2250



**From:** Charles Figueroa <Charles@almegaenv.com>  
**Sent:** Monday, July 01, 2019 3:09 PM  
**To:** Tulasi@almegaenv.com  
**Subject:** FW: Facility A - facility Data

**From:** [REDACTED]  
**Sent:** Friday, May 31, 2019 9:08 AM  
**To:** 'Charles Figueroa' <Charles@almegaenv.com>  
**Subject:** RE: Facility A - facility Data

**Testing data**

**Metals R1- #2 furnace AMS4881**

200#'s 5 x 40# pours  
#3 furnace AMS 4881  
600#'s 12 x 50# pours  
#7 furnace 316ss  
2250#'s 5 x 450# pours

**Metals R2- #2 furnace AMS 4881**

600# 15 x 40# pours  
#3 furnace AMS 4881  
600# 12 x 50# pours  
#7 furnace 316ss  
2250#'s 5 x 450# pours

**Metals R3- #2 furnace AMS 4881**

440#'s 11 x 40# pours  
#3 furnace AMS 4881  
500#'s 10 x 50# pours  
#7 furnace 316ss  
1800#'s 4 x 450# pours

**Chromium R1- #2 furnace AMS 4881**

600#'s 15 x 40 # pours  
#3 furnace AMS 4881  
600#'s 12 x 50# pours  
#7 furnace 316ss  
2250# 5 450# pours

**Chromium R2- #2 furnace AMS 4881**

600#'s 15 x 40# pours  
#3 furnace AMS 4881  
600# 15 x 50# pours  
#7 furnace 316ss  
2250# 5 450# pours

**Chromium R3- #2 furnace AMS 4881**

440#'S 11 X 40 # POURS  
#3 furnace AMS 4881  
500#'s 10 x 50# pours  
#7 furnace 316ss

PM R1 1800#'s 4 450# pours  
- #2 furnace AMS 4881  
560#'s 16 x 35# Pours  
#3 furnace AMS 4881  
650# 10 x 65# pours  
#7 furnace 316ss  
2250#'s 5 x 450# pours

AMS 4881 11% al, .5% mn, 4% fe, 5% ni balance cu

All furnaces started at full capacity and metal was back charged to maintain that level of capacity after every pour. AMS 4881 was back charged with pre-alloyed ingot. 316ss was back charged with clean turnings of known chemistry (recycled)

None of the data points constituted 1 heat. AMS4881 2000# heat size and 316 is a 10,000# heat size.

Let me know if you need something more



**From:** Charles Figueroa <[Charles@almegaenv.com](mailto:Charles@almegaenv.com)>

**Sent:** Thursday, May 30, 2019 10:01 AM

**To:** [Redacted]

**Cc:** 'Brian Speaks' <[gspeaks@aqmd.gov](mailto:gspeaks@aqmd.gov)>

**Subject:** RE: Facility A - facility Data

All production that was going to the control device...

**From:** [Redacted]

**Sent:** Thursday, May 30, 2019 9:58 AM

**To:** 'Charles Figueroa' <[Charles@almegaenv.com](mailto:Charles@almegaenv.com)>

**Subject:** RE: Facility A - facility Data

Does production include non-stainless or just production?

**From:** Charles Figueroa <[Charles@almegaenv.com](mailto:Charles@almegaenv.com)>

**Sent:** Tuesday, May 28, 2019 1:10 PM

**To:** [Redacted]

**Cc:** 'Brian Speaks' <[gspeaks@aqmd.gov](mailto:gspeaks@aqmd.gov)>

**Subject:** Facility A - facility Data



We successfully collected the required samples last week.

Please provide facility data in regards to the production during the following test times. Specifically we are looking for:

- List all processes operated during each test run
- Specific material processed during each test run
- Material condition (new, re-run, recycled, etc.)
- Number of heats performed
- Total material charged (lbs)

Test Times

		Date	Time
Metals	R1	5/21/2019	12:10 - 14:33
	R2	5/21/2019	15:10 - 17:40
	R3	5/22/2019	08:30 - 10:45
Chromium	R1	5/22/2019	11:50 - 14:12
	R2	5/22/2019	14:38 - 16:50
	R3	5/23/2019	08:25 - 10:42
PM	R1	5/23/2019	11:20 - 13:36

Thanks

*Charles M. Figueroa*

**Almega**

P (714) 889-4000

C (714) 809-9681

[Charles@almegaenv.com](mailto:Charles@almegaenv.com)

**From:** Charles Figueroa <Charles@almegaenv.com>  
**Sent:** Monday, July 01, 2019 3:09 PM  
**To:** Tulasi@almegaenv.com  
**Subject:** FW: Facility A - facility Data

**From:** [REDACTED]  
**Sent:** Thursday, June 06, 2019 12:09 PM  
**To:** 'Charles Figueroa' <Charles@almegaenv.com>  
**Subject:** RE: Facility A - facility Data

Charles  
Pouring temps for 316-2925 ,ams 4881 2425f  
Chem for 4881 is proprietary but general chem should be fine for general purpose.  
Heat size is how much can go in to a heat before we change a heat number, each drum of back charge  
Material is about 5-600#.  
Furnace is about 21 x 36"= 3500 #'s prox

**From:** Charles Figueroa <Charles@almegaenv.com>  
**Sent:** Thursday, June 06, 2019 11:26 AM  
**To:** [REDACTED]  
**Cc:** 'Tulasi Gyawali' <tulasi@almegaenv.com>  
**Subject:** FW: Facility A - facility Data

[REDACTED]

The following additional information regarding the production during the testing has been requested from the District. This is as follows:

1. Melt temperatures for the two materials, While I was observing, the stainless melt was in the 2800 – 3000 degree F range I would like to confirm what is normal/typical for this as well as the hold temperature for the AMS 4881 melt.
2. I have include a copy of the 316SS analysis Don provided for the melt taking place on the first day of testing. I would also like to see if we could include a similar report for the AMS4881 as it is a bit more formal than the description below.
3. I am a bit unclear on what he is referring to as stainless being a 10,000# heat size, does that make sense to you? 55 gallons of stainless steel = 3672 lb based on density of 0.289lb/in<sup>3</sup>, it didn't seem like the furnace held 2.5 of those drums worth of material but I may be wrong. Do you have the dimensions or volume of the furnace ?

Thanks

*Charles M. Figueroa*

# STAINLESS CHEMICAL ANALYSIS

316-1-19557/BSCA316-2 5/21/2019 11:38:22 AM 5334

Average	0.041	0.92	1.15	0.028	0.011	19.5	9.57
Std. Deviation	0.00	0.00	0.00	0.00	0.00	0.00	0.00
%RSD	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Average	2.43	0.354	0.00	0.239	0.003	0.001	0.072
Std. Deviation	0.00	0.00	0.00	0.00	0.00	0.00	0.00
%RSD	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Average	0.056	0.015	0.00	0.00	0.001	0.00	66.2
Std. Deviation	0.00	0.00	0.00	0.00	0.00	0.00	0.00
%RSD	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Average	0.00
Std. Deviation	0.00
%RSD	0.00

CORRESPONDS TO  
MOLTEN SAMPLE  
COLLECTED @ FACILITY

# STAINLESS CHEMICAL ANALYSIS

316-1-19557/BSCA316-2 5/21/2019 8:44:18AM 5334 66003

ASTM-A-743-13ACF8M

	Cr	Ni	Mo	C	Mn	P	S
Average	0.039	0.94	1.18	0.030	0.009	19.6	9.56
Std. Deviation	0.001	0.00	0.029	0.000	0.001	0.0574	0.0113
%RSD	3.17	0.00	2.51	0.46	15.15	0.29	0.12
Average	2.38	0.339	0.00	0.233	0.002	0.001	0.077
Std. Deviation	0.0071	0.002	0.00	0.002	0.000	0.001	0.001
%RSD	0.30	0.51	0.00	0.74	3.81	75.56	1.42
Average	0.056	0.016	0.00	0.00	0.001	0.00	66.1
Std. Deviation	0.002	0.000	0.00	0.00	0.000	0.00	0.009
%RSD	3.51	2.50	0.00	0.00	0.86	0.00	0.01
Average	0.00						
Std. Deviation	0.00						
%RSD	0.00						

3400# ✓

# STAINLESS CHEMICAL ANALYSIS

316-1-19557 BSCA316-2 5/21/2019 11:38:22 AM 5334							
Average	0.041	0.92	1.15	0.028	0.011	19.5	9.57
Std. Deviation	0.00	0.00	0.00	0.00	0.00	0.00	0.00
%RSD	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Average	2.43	0.354	0.00	0.239	0.003	0.001	0.072
Std. Deviation	0.00	0.00	0.00	0.00	0.00	0.00	0.00
%RSD	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Average	0.056	0.015	0.00	0.00	0.001	0.00	66.2
Std. Deviation	0.00	0.00	0.00	0.00	0.00	0.00	0.00
%RSD	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Average	0.00						
Std. Deviation	0.00						
%RSD	0.00						

3400#

5/21/19



Run 1 (A) 12:10

Baghouse  
in H<sub>2</sub>O  
2.5

HEPA  
in H<sub>2</sub>O  
~~.10~~ - .30

Pre-Filter  
in H<sub>2</sub>O  
~~.15~~ - .30

12:25

2.5

.20 - .30

.15 - .30

12:40

2.5

.20 - .30

.15 - .30

12:55

2.5

.15 - .30

.15 - .30

13:10

2.5

.15 - .30

.15 - .30

(B) 13:30

2.5

.15 - .30

.15 - .30

13:45

2.5

.20 - .30

.15 - .30

14:00

2.5

.15 - .25

.15 - .26

14:15

2.5

.15 - .25

.15 - .24

14:30

2.5

.15 - .25

.15 - .26

Run 2

(A) 15:10

2.5

.15 - .25

.15 - .30

15:25

2.5

.15 - .30

.15 - .30

15:40

2.5

.15 - .30

.15 - .26

15:55

2.5

.15 - .30

.15 - .26

16:10

2.5

.20 - .30

.15 - .24

16:40

2.5

.15 - .25

.15 - .30

16:55

2.5

.15 - .30

.15 - .30

17:10

2.5

.15 - .25

.15 - .25

17:25

2.5

.15 - .25

.15 - .25

17:40

2.5

.15 - .30

.15 - .30



Cr Run 3

	<u>Baghouse</u> in H <sub>2</sub> O	<u>HEPA</u> in H <sub>2</sub> O	<u>Pre</u> in H <sub>2</sub> O
(A) 8:25	2.0	.12 .30	0.15-.30
8:40	2.0	.10-.30	.15-.32
8:55	2.0	.10-.30	.10-.30
9:10	2.0	.10-.30	.10-.30
9:25	2.0	.15-.30	.12-.30
9:40	2.0	.15-.30	.12-.30

(B) 9:45	2.0	.15-.30	.12-.30
10:00	2.0	.15-.35	.15-.32
10:15	2.0	.15-.35	.15-.30
10:30	2.0		
10:45	2.0		

Pm Run 1  
(A)

11:20	2.0	.15-.30	.15-.32
11:35	2.0	.15-.30	.15-.28
11:50	2.0	.15-.30	.15-.26
12:05	2.0	.15-.35	.15-.32
12:20	2.0	.15-.30	.15-.30
(B) 12:30	2.0	.15-.35	.10-.26
12:51	2.0	.15-.35	.10-.26
13:06	2.1	.15-.30	.10-.26
13:21	2.1	.15-.30	.15-.30
13:36	2.1	.15-.30	.15-.30

Run	Time	Baghouse in H <sub>2</sub> O	HEPA in H <sub>2</sub> O	Pre Filter (in H <sub>2</sub> O)
A	9:45	2.2	.1 - .25	.15 - .25
	9:00	2.2	.1 - .25	.15 - .30
	9:15	2.2	.1 - .25	.15 - .25
	9:30	2.2	.1 - .25	.15 - .30
B	9:45	2.2	.1 - .30	.15 - .24
	10:00	2.2	.1 - .30	.1 - .28
	10:15	2.2	.1 - .30	.1 - .28
	10:30	2.2	.1 - .30	.1 - .28
		2.3	.1 - .25	.12 - .24

**APPENDIX I**  
**SCAQMD SOURCE TEST PLAN**



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

---

SOURCE TEST PLAN  
TO BE CONDUCTED AT

METAL MELTING FACILITY A

METAL MELTING FACILITY B

METAL MELTING FACILITY C

TO DETERMINE PARTICULATE MATTER (PM), ARSENIC, CADMIUM,  
NICKEL, CHROMIUM, AND HEXAVALENT CHROMIUM (Cr<sup>+6</sup>)  
EMISSIONS FROM CHROMIUM ALLOY MELTING OPERATIONS

ISSUED: November 21, 2018

REVISED: March 27, 2019

REVIEWED BY:

A handwritten signature in blue ink, appearing to read "Michael Garibay".

Michael Garibay  
Acting Source Testing Manager

SOURCE TEST ENGINEERING BRANCH

---

SCIENCE & TECHNOLOGY ADVANCEMENT

*Cleaning the air that we breathe...™*

Metal Melting Test Plan

-2-

Date: 3/27/19

**TABLE OF CONTENTS**

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
<b>INTRODUCTION</b>	<b>3</b>
<b>EQUIPMENT &amp; PROCESS DESCRIPTION</b>	<b>4</b>
<b>SAMPLING AND ANALYTICAL PROCEDURES</b>	<b>6</b>
<i>Gas Flow Rate</i>	<b>8</b>
<i>Particulate Matter Sampling (Method 5.1)</i>	<b>10</b>
<i>Hexavalent Chromium Sampling (CARB Method 425)</i>	<b>11</b>
<i>Multiple Metals Sampling (CARB Method 436)</i>	<b>13</b>
<i>Capture Efficiency</i>	<b>14</b>
<i>Integrated Gas Sampling (Method 10.1)</i>	<b>14</b>
<b>QUALITY ASSURANCE</b>	<b>15</b>
<b>FINAL TEST REPORT</b>	<b>16</b>
<b>APPENDICES</b>	<b>18</b>
<i>Appendix A: (Process Operating Parameters &amp;         Results Reporting Requirements)</i>	<b>19</b>
<i>Appendix B: (Facility Process Flow         Diagrams and Photos) – (Confidential)</i>	<b>22</b>

## INTRODUCTION

Ambient monitoring in the city of Paramount in 2016 and 2017 indicated the presence of elevated levels of hexavalent chromium. During an investigation of the emission sources, the SCAQMD identified hexavalent chromium emissions were being generated by sources including heat treating and forging facilities. Screening source tests were performed on heat treating and forging furnaces processing metals or using materials that contained chromium at several facilities. Results showed elevated hexavalent chromium levels in the outlet of the furnaces which were operated between 1,725 to 2100°F. These temperatures are lower than those experienced during metal melting operations.

An internal review was initiated for previously conducted source tests at metal melting facilities. Most of the source tests on file only tested for elemental chromium and did not perform the separate test required to determine hexavalent chromium emissions as they were not suspected from this process. SCAQMD staff was able to identify one metal melting facility which was tested for both total chromium and hexavalent chromium using CARB Method 425. Review of this test indicated that conversion of chromium to hexavalent chromium did occur and result in emissions of hexavalent chromium during the melting operation.

SCAQMD staff initiated the rule development process to amend Rule 1407 to address toxic air contaminant emissions from ferrous metal melting operations and update existing requirements for non-ferrous metal melting operations currently regulated under the rule. Through working group meetings with industry stakeholders it was requested that the rule be separated in to two rules for ferrous and non-ferrous metal melting. After additional input and working group meetings SCAQMD staff decided to bifurcate the rule and reclassify characterization in to non-chromium alloy (Rule 1407) and chromium alloy (Rule 1407.1) metal melting.

Additional data from melting operations of metals with a chromium content greater than 0.5% is needed to quantify the conversion rate of chromium to hexavalent chromium and quantify toxic air contaminant emissions from these facilities to aid in the rulemaking process.

Three facilities have agreed to allow source testing for the purposes of collecting this data. Testing will be performed by a third party source test contractor. The purpose of this test plan is to allow for the source test contractors to provide bids as part of the RFP process, while eliminating the need for multiple contractors to visit the facilities who have volunteered as host sites for the source testing. Testing contractors must be SCAQMD Laboratory Approval Program certified for SCAQMD Methods 1-5 to be able to participate in the RFP process and testing upon award of contract.

Metal Melting Test Plan

-4-

Date: 3/27/19

During the source testing at each facility, control system inlet and outlet emissions and associated emission rates will be determined for the following:

- Particulate Matter (PM)
- Total Chromium (Cr)
- Hexavalent Chromium (Cr<sup>+6</sup>)
- Arsenic (As)
- Cadmium (Cd)
- Nickel (Ni)

Testing will be performed according to SCAQMD Method 5.1, CARB Method 425, and CARB Method 436. Flow rates will be determined according to SCAQMD Methods 1-4, with the use of EPA Method 5D for the outlet of the HEPA filters at one of the three facilities.

## EQUIPMENT AND PROCESS DESCRIPTION

Pursuant to the agreement with the participants to keep the names of the host facilities anonymous, they will be identified as Facilities A, B, and C. [REDACTED]

### Metal Melting Facility A

Metal melting Facility A uses electric induction furnaces for the processing of materials including Brass, Zinc, Steel, Stainless Steel, Iron, Aluminum, Cobalt, and Nickel. The facility has eight electric induction furnaces in three sizes as follows:

800 lb material capacity with a power rating of 250 kW

3,000 lb material capacity with a power rating of 350 kW

4,500 lb material capacity with a power rating of 1,000 kW (shared power supply)

[REDACTED] A heat cycle (or “heat”) begins when the metal is placed in the electric induction furnace. Electrical current is applied and the material becomes molten. Testing will be performed during heats of 316 stainless steel. The stainless steel materials are typically melted in one of the 4,500 lb furnaces. Typical temperatures are in the 3000°F range. During the melting process emissions are captured by an exhaust system which mounts to the furnace lid and utilizes a slot design. Suction is provided by the blower which is part of the baghouse and HEPA system. The HEPA filters are mounted in an enclosure above the baghouse and exhaust through two rectangular openings on either side of the enclosure. Because the exhaust does not exit through an exhaust stack special consideration must be given for the outlet testing.

[REDACTED] A typical heat lasts for approximately 2 hours. Each furnace has individual exhaust ducting allowing for testing during a specific heat before being combined in to a common exhaust header. The baghouse and HEPA filter system controls emissions from the eight electric induction furnaces, five casting machines, one Hawley system, four mold spray and coating stations. [REDACTED]

A complete list of process operating parameters to be obtained for the period during testing as well as results reporting requirements is located in **Appendix A**. A basic process flow diagram has been included in **Appendix B**.

#### **Metal Melting Facility B**

Metal melting facility B uses electric induction furnaces for the processing of primarily stainless steel. The facility has two 300 lb capacity electric induction furnaces but typically only uses one at a time. The facility makes small precision parts primarily through an investment casting process.

The furnace is loaded with 17-4 PH stainless steel and the heat begins. Electrical current is applied and the material becomes molten. Typical temperatures are in the 3000°F range during the melting process. Castings are placed in an oven which serves the purpose of removing the wax core from the casting while simultaneously preheating the casting to 1600-1800°F to prevent thermal shock during the pouring process. The molten metal from the furnace is poured in to a ladle before being poured in to the casting mold.

Emissions from the furnace are collected by a hood placed directly above each furnace. The hoods have blast gates installed which can be closed during emissions testing to prevent room air dilution from the adjacent non-operational unit. The facility has agreed to install a hood extension on the furnace in use to ensure that all furnace emissions will be captured during the source test operation. Hood emissions are currently routed through a baghouse. The facility is currently in the process of a control system upgrade to install a HEPA filtration downstream of the baghouse for improved emission control. It is anticipated that the HEPA system will be completed around January of 2019.

The facility does approximately 6 heats a day. Each heat follows a repeating cycle of roughly one hour on during the melt followed by a period of roughly one hour with the furnace off.

A complete list of process operating parameters to be obtained for the period during testing as well as results reporting requirements is located in **Appendix A**. A basic process flow diagram has been included in **Appendix B**.



### **Metal Melting Facility C**

Metal melting facility C uses electric induction furnaces for the processing of white iron, cast iron, ductile iron, and stainless steel. The facility has four electric induction furnaces in sizes as follows:

- 7,000 lb material capacity with a power rating of 1,500 kW
- 6,000 lb material capacity with a power rating of 1,500 kW
- 4,000 lb material capacity with a power rating of 1,000 kW
- 2,000 lb material capacity with a power rating of 400 kW

90% of facility operations involve melting of the various irons and approximately 10% percent of operations are stainless steel melts. Raw materials for iron melts are frequently re-runs while the stainless melts tend to be new certified material. The stainless steel processed at the facility is CF8M, CF3M, CF8, and CF3. The facility normally runs 2 furnaces at a time, most frequently the 7,000 lb and 6,000 lb furnaces. Stainless steels are only processed in either the 4,000 lb or 2,000 lb furnace. The furnaces are loaded with the applicable material and the heat begins. Electrical current is applied and the material becomes molten. Typical temperatures are in the 2400-2700°F range during iron melting operations and in the 3000°F range during stainless steel melting operations. Material from the furnace is poured in to pre-heated ladles for transport by forklift to the casting area. All casting at the facility is green sand casting. The casting area is in a separate location within the building.

During the melting process emissions are captured by an exhaust system which mounts to the furnace and utilizes a slot design. Suction is provided by the blower which is part of the baghouse and HEPA system. Each furnace has a closable damper installed which allows for isolation from the system when a furnace is not in use. In the exhaust header there is one non closable exhaust hood which pulls room air in to the system. The HEPA filters are installed between the baghouse and the exhaust stack. The exhaust stack outlet in its current configuration undergoes multiple small angular changes prior to exit to the atmosphere. The facility has agreed to modify the outlet such that a straight run of duct will be provided downstream of the exhaust muffler to meet the requirements of at least two duct diameters downstream and one half of a diameter upstream of any flow disturbances.

The facility does approximately 4-5 heats a day. The iron heats performed in the 7,000 lb and 6,000 lb furnaces take 1.5 – 2 hours. The stainless heats performed in the smaller 4,000 lb and 2,000 lb furnaces take up to 3 hours.

A complete list of process operating parameters to be obtained for the period during testing as well as results reporting requirements is located in **Appendix A**. A basic process flow diagram has been included in **Appendix B**.

## SAMPLING AND ANALYTICAL PROCEDURES

Two hour test runs at each location within the system will be performed based on the reference methods described below at the locations specified in Table 1. Refer to **Appendix B** for Facility photos depicting equipment, sample locations, and testing logistical notes.

Sampling times may need to be adjusted on the test days to match the facility's batch time for melting and pouring. It is anticipated these times will end up being close to the proposed two hours per run. Material samples will be collected by the facility and/or source test contractor SCAQMD at each facility corresponding to each heat which occurs during emissions testing. Samples should include all raw materials, molten material, final product, slag, dross, and baghouse catch. If any such samples are un-available at the time of testing, it should be noted in the final test report. The materials shall be properly identified and delivered to the SCAQMD for materials composition testing. Additionally, if the facility has performed in-house analysis for each or any sample(s) it should be provided to the SCAQMD. Results of material analysis conducted by SCAQMD will be provided to the contractor conducting testing (where applicable). Analysis of Weck Laboratory detection limits are satisfactory for meeting the objectives of the contract and the proposed rulemaking efforts. SCAQMD method reporting limits (MRL) will be adjusted to match Weck Laboratory for consistency.

***Table 1: Sampling Details***

Facility	Sample Location	Test Method	Number of Runs	Sample Ports	Sample Port Access
A	Inlet Header, For 4.5k lb. Furnace for Stainless Melting	SCAQMD Method 5.1	1	To Be Installed by Facility	Accessed by a removable floor grate from ground level.
		CARB Method 425	3		
		CARB Method 436	3		
A	Inlet Header, Upstream of Baghouse	SCAQMD Method 5.1	1	In Place	Can be reached with a ladder.
		CARB Method 425	3		
		CARB Method 436	3		
A	Exhaust Outlet, Downstream of Baghouse/HEPA Filters	SCAQMD Method 5.1	1	No Ports, Use EPA Method 5D	Accessible by facility owned man lift.
		CARB Method 425	3		
		CARB Method 436	3		

Facility	Sample Location	Test Method	Number of Runs	Sample Ports	Sample Port Access
B	Inlet Header, Upstream of Baghouse	SCAQMD Method 5.1	1	To Be Installed by Facility	Accessible from ground level.
		CARB Method 425	3		
		CARB Method 436	3		
B	Exhaust Outlet, Downstream of Baghouse/HEPA Filters	SCAQMD Method 5.1	1	To Be Installed by Facility	Will be accessible by a facility provided man lift.
		CARB Method 425	3		
		CARB Method 436	3		

Facility	Sample Location	Test Method	Number of Runs	Sample Ports	Sample Port Access
C	Inlet Header, Common to 6k, 4k and 2k lb. Furnaces for Stainless Melting	SCAQMD Method 5.1	1	To Be Installed by Facility	Accessible from raised floor.
		CARB Method 425	3		
		CARB Method 436	3		
C	Inlet Header, Common to all Furnaces, Upstream of Baghouse	SCAQMD Method 5.1	1	To Be Installed by Facility	Accessible from facility provided man lift or scaffolding.
		CARB Method 425	3		
		CARB Method 436	3		
C	Exhaust Outlet, Downstream of Baghouse/HEPA Filters	SCAQMD Method 5.1	1	To Be Installed by Facility	Accessible from facility provided man lift.
		CARB Method 425	3		
		CARB Method 436	3		

**Gas Flow Rate**


The gas velocity will be measured at the inlet duct and outlet duct\* in accordance with SCAQMD Methods 1.1 and 2.1. This will be done using an S type Pitot tube, a differential pressure manometer, and a type "K" thermocouple with a digital potentiometer a diagram of this arrangement is presented in Figure 1 below as well as in the appropriate test method. The apparatus will be leak checked both before and after use by introducing a pressure head of at least 80 percent of full scale and blocking the flow at the Pitot tip. An observation of the resulting non diminishing pressure for at least 15 seconds at the manometer should be verified to confirm the absence of leaks in the system.

The velocity measurement location is at least two diameters downstream and one half diameter upstream of any flow disturbances. The sample traverse at each facility will be in accordance with SCAQMD Method 1.1. Traverse sampling is necessary for the determination of stack gas velocity. The number of traverse points must be determined in accordance with SCAQMD Method 1.1 for stacks with diameters greater than 12 inches.


The inlet and outlet\* volumetric flow rate is calculated from the duct cross sectional area and average gas velocity. The absence of cyclonic flow conditions must be verified. The flow rate must be corrected to standard conditions using the measured duct temperatures and velocity pressures along with the barometric pressure measured with a calibrated aneroïd barometer. The exhaust flow rate must also corrected to dry conditions using the moisture content as determined by SCAQMD Method 4.1 weight gain from the SCAQMD Method 5.1, CARB Method 425, and CARB Method 436 sample trains described in the following sections.

\*Facility A does not have an exhaust stack, the HEPA filters are mounted in an enclosure directly on top of the baghouse. Exhaust exits from two rectangular openings in a horizontal direction on either side of the HEPA enclosure (see Figure 2 below for details). Due to the anticipated low velocity pressure exiting the baghouse/HEPA system EPA Method 5D must be used which allows for the velocity and exhaust flow to be determined at the inlet to the baghouse and then applied over the entire area of the exhaust. Isokinetic sampling rates and sampling probe nozzle size will need to be based on these calculations. If it turns out that the velocities can be measured at this location by pitot tube, then isokinetic rate can be set by the measured velocity heads.

**Figure 1: Gas Velocity Measurement Apparatus**




**Figure 2: Facility A Exhaust Diagram (EPA Method 5D Required)**



**Particulate Matter Sampling**

Samples are collected using SCAQMD Method 5.1. Particulate matter is withdrawn isokinetically from the source through a sample train by a metering system. Particulate matter is collected in impingers containing deionized water and on a backup filter. The impingers are contained in an ice bath to maintain a sampled gas Temperature of approximately 60°F. The filter is not heated. A diagram of the test apparatus is pictured in Figure 3 below. Total particulate matter mass is defined as the sum of the mass collected in the impingers and the probe, and on the filter after removal of combined water, plus extractable organic matter and sulfuric acid. Samples are analyzed for water gain, PM, acids, sulfates, and organics. For the purposes of this testing, the analysis should include the organic and acid/sulfate traditional analysis. Following analysis, samples shall be retained and made available for 3<sup>rd</sup> party inspection. This is requested with the understanding that portions of the analytical method are destructive and do not allow for samples to be split. A photograph of residue “inspection” of each sample should be taken prior to analysis. The SCAQMD will reserve the right to physically inspect the samples as necessary, while giving the Contractor ample notice. Although not required by the SCAQMD Method 5.1, optional field blank runs may be performed and analyzed.

***Figure 3: Particulate Sampling Train***



- |  |   |
|--|---|
| 1. Temperature Sensor                    | 11. Ice Bath                              |
| 2. Nozzle                                | 12. Filter                                |
| 3. Glass Lined Stainless Steel Probe     | 13. Sealed Pump (Leak Free)               |
| 4. S-type Pitot Tube                     | 14. Filter for Pump                       |
| 5. Stack Wall                            | 15. Metering Valve                        |
| 6. Temperature Sensor Meter              | 16. Vacuum Gauge                          |
| 7. Pitot Tube Inclined Manometer         | 17. By-pass Valve                         |
| 8. Impinger with 100 ml H <sub>2</sub> O | 18. Temperature Compensated Dry Gas Meter |
| 9. Empty Bubbler                         | 19. Orifice                               |
| 10. Bubbler with Silica Gel              | 20. Orifice Inclined Manometer            |

### **Hexavalent Chrome Sampling**

CARB Method 425 applies to the determination of hexavalent chromium (Cr<sup>+6</sup>) and total chromium (Cr) emissions from stationary sources. Emissions are collected from the source in a sampling train consisting of a glass probe and nozzle connected by non-reactive tubing to the first of two Greenburg-Smith impingers each containing 100 ml of 0.1N sodium bicarbonate (NaHCO<sub>3</sub>), an empty bubbler, a Teflon filter, and a bubbler containing tared silica gel desiccant (see Figure 4).


The same batch of 0.1N NaHCO<sub>3</sub> solution shall be used for field blanks, impinger sampling, sample recovery, preparation, extraction, and analysis. One batch of solution should be prepared for each facility. Substituting NaHCO<sub>3</sub> for NaOH is an approved Alternative Test Method as outlined in Sections 10 and 21 of CARB Method 425.

The impinger assembly must be connected to a vacuum pump and a calibrated dry gas meter. The sampling apparatus shall be checked for leaks both before and after sampling by blocking the flow at the probe tip. An observation of the resulting decrease in flow at the meter should be less than 0.02 cfm or four percent of the sampling rate indicated an acceptable leak rate. The impinger train must be contained within an ice bath to condense water and other condensable matter present in the sample stream.

The impinger train will be returned to the laboratory for recovery. The pH of the recovered solution must be verified as being greater than 8.0 as specified in CARB Method 425. Hexavalent chromium collected in the nozzle, probe, and impingers will be determined using ion chromatography with post column reactor (IC/PCR). The probe and line rinse shall be separated and itemized by weight separately from the rest of the analysis. For each facility a minimum of one field blank run shall be analyzed. Each blank sample train shall be brought onto the test site, assembled, leak checked, and analyzed as above for quality control purposes. No sampling should occur on the blank train.

Following testing, CARB Method 425 samples must be recovered within 24 hours. Samples should be split with remaining aliquots after primary analysis to be held for possible 3<sup>rd</sup> party analysis. Holding time for Method 425 following recovery is 14 days if stored at < 4° C.

***Figure 4: CARB Method 425 Sample Train***





**Multiple Metals Sampling**

CARB Method 436 applies to the determination of aluminum (Al), antimony (Sb), arsenic (As), barium (Ba), beryllium (Be), cadmium (Cd), chromium (Cr), cobalt (Co), copper (Cu), lead (Pb), manganese (Mn), mercury (Hg), nickel (Ni), phosphorus (P), selenium (Se), silver (Ag), thallium (Tl), vanadium (Vn), and zinc (Zn) stack emissions from stationary sources. For this source test the metals of specific interest are Cr, As, Cd, and Ni. Sampling is conducted using a modified CARB Method 5 sample train. The stack sample is withdrawn isokinetically from the source, with particulate emissions collected in the heated probe and on a heated filter maintained in the temperature range of  $248 \pm 25^{\circ}\text{F}$  and gaseous emissions collected in a series of chilled impingers containing an aqueous solution of dilute nitric acid combined with dilute hydrogen peroxide in two impingers (analyzed for metals). If necessary for sampling the vertical port on horizontal ducts, the addition of flexible Teflon tubing between the heated probe and heated filter, or sampling train sections may be allowed; depending on sampling location.


The same batch of 5% HNO<sub>3</sub>/10% H<sub>2</sub>O<sub>2</sub> solution shall be used for field blanks, impinger sampling, sample recovery, preparation, extraction, and analysis. One batch of solution should be prepared for each facility.

For each facility a minimum of one field blank run shall be analyzed. Each blank sample train shall be brought onto the test site, assembled, leak checked, and analyzed for quality control purposes. No sampling should occur on the blank train.

Sampling train (see Figure 5) components are recovered into separate front and back half fractions and acid digested using conventional Parr<sup>R</sup> Bomb or microwave digestion techniques to dissolve inorganics and to remove organic constituents that may create analytical interferences.

Following testing Method 436 samples must be recovered as soon as practical. Samples should be split with remaining aliquots after primary analysis to be held for possible 3<sup>rd</sup> party analysis. Holding time for Method 436 following recovery is 60 days.

***Figure 5: CARB Method 436 Sample Train***



After digestion, portions of the probe, filter and nitric acid/hydrogen peroxide digestion solutions are combined into a single front half composite and analyzed for Cr, As, Cd, and Ni. Refer to the test method document for additional details.


### **Capture Efficiency**

During source testing capture efficiency testing will be performed by SCAQMD personnel (not required for contractor to perform this testing) to determine the efficiency of the collection system. A hot-wire anemometer, vane anemometer, or other device capable of directly measuring air velocity, will quantitatively measure the air velocity at the slots or hood, as applicable, of the furnace emissions collection system. Additionally, a qualitative test shall be performed and photo or video recorded using smoke tubes or smoke sticks. Documentation of these measurements will be provided to the test contractor following measurement.

### **Integrated Gas Sampling**

An integrated gas sample will be taken at each sample location and analyzed for CO, CO<sub>2</sub>, and O<sub>2</sub>. The sampling procedure shall be according to SCAQMD Method 10.1. The sampling apparatus should consist of a stainless steel probe, a Teflon line, and a 6-liter summa canister (see Figure 6 below for details).

***Figure 5: Integrated Gas Sample***



Samples will be analyzed for carbon monoxide, carbon dioxide, and oxygen. The gasses should be separated by gas chromatography. Determination shall be by a gas chromatograph with a nickel catalyzed methanizer and flame ionization detector (GC/Ni-FID) for carbon dioxide. Carbon monoxide must be combusted to carbon dioxide and analyzed by SCAQMD Method 25.1. Oxygen will be analyzed by thermal conductivity.

## QUALITY ASSURANCE

All applicable pieces of source test and process equipment used directly or indirectly for measurement of source test emission data must be calibrated, and the calibrations included in the final report (this includes gas meters, Pitot tubes, pressure gages, nozzles, temperature devices, calibration gases, fuel usage meters, totalizers, etc.).

All raw data field data sheets, as well as recorder strip charts, must accompany the test report. Additionally, all gas cylinders used to calibrate the analyzers must be certified, and a copy of the gas certificates shall be submitted with the report.

Where laboratory instrument analysis is required, instrument raw stripcharts, calibrations and standards, and limit of detection must be included in the source test report. This also includes equipment transfer and “chain-of-custody” form clearly describing all equipment and laboratory ID

Metal Melting Test Plan

-17-

Date: 3/27/19

numbers, dates and times, required analysis, and the signature/initials of persons involved in transfers.

The terms “non-detect” or “non-detectable” are no longer used for emission reporting purposes. Instead, non-detectable results are reported with respect to the limit of detection of the analytical instrument or method (e.g. report “<10 ppm”, if detection limit is 10 parts per million). Non-detectable emission results must have supporting documentation to show that acceptable sample volume was collected pursuant to rule or permit limits and analytical method limit of detection.

Equipment used by the source testing contractors must adhere to the Chapter III calibration and maintenance requirements of the District Source Test Manual.

All source testing firms used in monitoring emissions or analyzing samples shall be District LAP contractors in good standing, and must perform testing in accordance with District procedures, as clarified in this evaluation.

## **FINAL TEST REPORT**

The final Source Test Report must include the following information:

- 1) Signed “Statement of Non-Conflict as an Independent Laboratory” (District Rule 304(k)) and CARB Lab Approval or District Lab Approval Program (LAP) document (if applicable).
- 2) A brief opening statement identifying the Facility I.D., the equipment A/N, P/O, or Device I.D. and the reason(s) for testing (applicable rules permit conditions, etc.). Include a copy of the Permit-to-Construct, Permit-to-Operate, or Facility Permit. Also identify the test dates, the personnel on hand for the test, names, titles and phone numbers of responsible test firm and facility personnel.
- 3) A summary of the Source Test results, and properly formatted source test data. Results shall be reported
- 4) A brief process description. Indicate equipment operation during testing; as well as any other information which may influence the final report.
- 5) A “self-critique” of anything that transpired during the test which you feel is useful in the interpretation of the test results.
- 6) A simple schematic diagram of the process, showing the sampling location, with respect to the upstream and downstream flow disturbances. Also include a cross-sectional

Metal Melting Test Plan

-18-

Date: 3/27/19

diagram of the stack or duct at the sampling location, depicting the sampling points with respect to compass direction.

- 7) The sampling and analytical procedures. Be specific about all aspects of sampling and analysis. Include diagrams of test equipment and methods.
- 8) Complete raw field data, including production data indicative of the testing interval, lab analyses, and the test results (show all calculations).
- 9) Current calibration data regarding all sampling and measuring equipment utilized during testing. This also includes all laboratory calibrations. (see District Source Testing Manual, Chapter III or "Quality Assurance Handbook For Air Pollution Measurement Systems", Vol. III, U.S. EPA-600/4-77-0276).
- 10) All calculations concerning intermediate process, emission, and/or flow information must be shown and included in the final report. This also applies to calculations concerning laboratory analyses.

Metal Melting Test Plan

-19-

Date: 3/27/19

## **APPENDICIES**

Metal Melting Test Plan

-20-

Date: 3/27/19

## **APPENDIX A**

### **Process Operating Parameters and Results Reporting Requirements**

The following process operating parameters shall be recorded during testing at each location in addition to those specifically required by the applicable source test method:

- 1) Start and End time of each sample run. Note if the sample run must be stopped and restarted due to insufficient sample volume during a single heat.
- 2) Ambient Temperature shall be monitored and recorded before and after each test (°F).
- 3) Ambient Relative Humidity shall be monitored and recorded before and after each test (%).
- 4) Ambient Barometric Pressure shall be monitored and recorded before and after each test (in. Hg).
- 5) Total sampling time for each run (min.).
- 6) Specific material processed during each test run, this should be supported by positive material identification or certification documents.
- 7) Material condition (new/re-run/recycled/etc.).
- 8) Number of heats performed during sampling.
- 9) Total material charged during sampling (lbs.).
- 10) Average baghouse pressure differential during sampling (in. H<sub>2</sub>O).
- 11) Average HEPA filter pressure differential during sampling (in. H<sub>2</sub>O).
- 12) Stack temperature at sample location shall be monitored and recorded every 15 minutes during sampling (°F).
- 13) Description of all sources venting to the APCS during testing.
- 14) Velocity measurements at capture hood or furnace control system slots (fpm).

Test results summary shall at a minimum document the following:

1. Summary of Process and Test Conditions
2. Summary of Results for Particulate Emissions
  - a) Sample Time
  - b) Exhaust Flow Rate (acfm)
  - c) Exhaust Flow Rate (dscfm)
  - d) Emissions (grains/dscf)
  - e) Mass Emissions (lbs/hr)
3. Summary of Results for Chromium and Hexavalent Chromium
  - a) Sample Time
  - b) Exhaust Flow Rate (acfm)
  - c) Exhaust Flow Rate (dscfm)
  - d) Emissions (µg/dscm)
  - e) Emissions (µg/dscf)
  - f) Mass Emissions (lbs/hr)
4. Summary of Results for Multiple Metals Testing
  - a) Sample Time
  - b) Exhaust Flow Rate (acfm)



Metal Melting Test Plan

-22-

Date: 3/27/19

- c) Exhaust Flow Rate (dscfm)
- d) Emissions ( $\mu\text{g/dscm}$ )
- e) Emissions ( $\mu\text{g/dscf}$ )
- f) Mass Emissions (lbs/hr)

Metal Melting Test Plan



-23-

Date: 3/27/19



## **APPENDIX B**

Facility Process Flow Diagrams & Photos  
(Confidential Do Not Distribute)



***Figure 6: Facility A - Basic Process Flow Diagram***



**Figure 8: Facility B – Basic Process Flow Diagram**




***Figure 8: Facility C – Basic Process Flow Diagram***



Metal Melting Test Plan

-27-

Date: 3/27/19



**APPENDIX J**

**SCAQMD CHECKLIST FOR SOURCE TEST REPORTS, FORM STR.**

## SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

### ENGINEERING FORM STR CHECK LIST FOR SOURCE TEST REPORTS

Please check off all the following items to verify that the information is provided in the source test report, and then send the checklist along with the source test report.

- [ X ] Brief description of the equipment tested.
- [ X ] Brief process description, including maximum and normal operating temperatures, pressures, through-put, etc.
- [ X ] Operating conditions under which test was performed.
- [ X ] Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, along with upstream and downstream locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
- [ X ] Field and laboratory data forms, strip charts and analyses.
- [ X ] Brief description of sampling and analytical methods for each gaseous and particulate constituent measured.
- [ X ] Calculations for volumetric flow rates and emission rates.
- [ X ] Description of calibration and quality assurance procedures.
- [ X ] Determination that the testing laboratory qualifies as an “independent testing laboratory” under Rule 304 (no conflict of interest).